CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRSUBD20221459Address:3221 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:	
Sanitary Sewer Construction Inspection	Eric Sharp	Partial	Wednesday, September 21, 2022	
Informational: 1 Misc	Bair excavating starting working from MH C-1 towards D-1 and backfilled some between A-5 and C-1. 9/7/22 ES			
	Bair excavating finished line from C-1 to D-1 and set D-1 and stubbed out. Also began laying pipe towards MH C-2. 9/8/22 ES			
	Bair Excavating pipe crew worked on backfilling areas along A line. Mike from CFS was onsite doing compaction testing. 9/9/22 ES			
	Bair Excavating working on stub lines between C-1 and D-1 and between C-1 and C-2. They began stubbing out from A-5 towards A-6 in order to get inverts poured this afternoon. They will be working on getting C-2 set today. 9/12/22 ES			
	Bair Excavating installed MH C-2 and started backfilling areas. 9/12/22 ES			
	Bair Excavating working or compaction testing. 9/13/	n backfilling lines C and D. C 22 ES	FS was on site doing	
	Bair began working on A li testing also. 9/14/22 ES	ine out from A-5, CFS was o	nsite doing compaction	

		Bair working on line A from A-5 towards A-6. Got MH A-6 base set and wyes for service lines on this section laid in. 9/15/22 ES	
		Bair working on laying pipe out from service lines and turning wye connections out. 9/16/22 ES	
Informat	ional:		
2	Misc	 9-19-22 RH. Contractor continued to install main between MH A-6 to A-7. 9-20-22 RH. Contractor installed MH A-7 and started to dig out trench to A-8. Laterals have not been installed between A-6 to A-7 yet. Compaction has not been completed between MH A-5 and A-6 yet. 9-21-22 RH. MH A-8 was installed. Compaction has started being tested between MH A-5 and A-6. Laterals started being dug between A-6 to A-7. 	

Comments: