

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220348
Address: 2621 SW HOOK FARM LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Not Ready	Thursday, September 22, 2022

Corrective Action Required:

1	Misc	-Address rafters landing on blocks throughout provide engineering provide way to view top of blocks -seal gaps in fire block and penetrations into furr down in pantry (see beam and entry wall) MUST USE APPROVED METHOD -mid way strap 2" dwv in bed 4 closet -seal penetrations in RA joist space above basement linen closet -seal penetrations in RA joist space above bed 3
---	------	---

Comments: