

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214341
Address: 3125 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Thursday, September 22, 2022

Corrective Action Required:

2 Misc

- pay all fees
- address damaged water meter pit,ring, lid
- install kitchen hood or land electrical to box
- hardware at rear door
- steps to basement not to exceed 7 3/4

Comments: