

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220330
Address: 1804 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Residential	Mitchell Schwarz	Failed	Thursday, September 22, 2022

Informational:	
1 Misc	check bonding of pool cover at time of final
Corrective Action Required:	
2 Misc	-could not verify pool cover bonding -outlet required to code E4203.1.3

Comments: