

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214474
Address: 1913 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, September 22, 2022

Corrective Action Required:

1	Misc	-NO ACCESS FOR INTERIOR INSPECTION, HOUSE LOCKED, NO KEY IN LOCKBOX -install hood or box with cover at kitchen, (exposed romex) -provide security screws at rear deck door -repair rock garage wall -outlet cover plates, see garage and 2nd floor bath -label dedicated outlets at garage and unfinished space as not GFCI protected
---	------	--

Comments: