

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220427
Address: 3549 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, September 22, 2022

Corrective Action Required:

1	Misc	-basement stairs, handrail required to start at point above top rise of flight -provide anti siphon device at spigot main water line basement, shear off set screw head after tightening -label all dedicated receptacles at unfinished spaces as not GFCI protected -seal all penetrations in siding, seal across top of AC disconnect and meter can -downspouts and sump pump min 36" discharge from foundation
---	------	---

Comments: