CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20220518Address:3545 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, September 22, 2022
Corrective Action Required:			
	 -final driveway inspection required, contact development services to schedule -seal all penetrations in siding, seal across top of AC disconnect and meter can -downspouts and sump pump min 36" discharge from foundation -secure weather outlet boxes at exterior -provide (2) 1/2" through bolts each post/beam connection at deck -label all dedicated receptacles at unfinished spaces as not GFCI protected 		

Comments: