

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220011
Address: 3542 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, September 22, 2022

Corrective Action Required:

1	Misc	-tape/mud garage ceiling at garage door bracket penetrations -mark bedroom breaker locations at service panel -provide mid rail support at basement stairs handrail -tempered glass at 2nd floor stairs next to handrail and landing windows -uncover water meter lid -nail off joist hangers at deck -seal all penetrations in siding, seal across top of AC disconnect and meter can -downspouts and sump pump min 36" discharge from foundation
---	------	---

Comments: