

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20220006  
Address: 3538 SE CORBIN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Failed	Thursday, September 22, 2022

Corrective Action Required:

1	Misc	-seal all penetrations in siding, seal across top of AC disconnect and meter can -downspouts and sump pump min 36" discharge from foundation -(2) 1/2" through bolts each post/beam connection at deck -shear off set screw head anti siphon device basement on spigot -provide mid rail support at basement stairs handrail
---	------	--

**Comments:**