

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220047
Address: 2102 SW RED BARN LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------------|----------|------------------------------|
| Occupancy Inspection - Codes Residential | Mitchell Schwarz | Failed | Thursday, September 22, 2022 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | -address to be properly illuminated -obtain lawn irrigation permit -gutters -sod -garage door to be self closing -handrail required at garage stairs to code -label all non GFCI protected outlets in unfinished spaces -(2) 1/2" through bolts at each deck post to beam connection |
|---|------|---|

Comments: