

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216160
Address: 2102 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|-----------------|----------|----------------------------|
| Occupancy Inspection - Codes Residential | Michael Harkins | Failed | Friday, September 23, 2022 |

Corrective Action Required:

| | | |
|---|--------------------------|---|
| 1 | Miscellaneous Correction | MAINTAIN GUTTER BUDDY REMOVE SILT AND WEEDS Clean steet, gutters of mud & gravel Provide guardrail front stoop over 30" to grade Tighten self closing hinges so garage door is self closing Water heater pressure relief valve discharge pipe to terminate not more than 6" and not less than 2 times pipe diameter above floor (2018 IRC P2804.6.1 (10) Lower water meter lid to grade level maintain 14" to 18" meter to lid |
|---|--------------------------|---|

Comments: