

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213536
Address: 2353 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Failed	Friday, September 23, 2022

Corrective Action Required:

1	Misc	-Inspection incomplete -Provide all AFCI protection per code -Provide lockouts at all hardwired appliances -Driveway inspection pending -No power at kitchen receptacles -Not ready
---	------	--

Comments: