

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211709
Address: 2357 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Failed	Friday, September 23, 2022

Corrective Action Required:

1	Misc	-Open electrical box at garage door exterior -Provide handrail at garage entry -Anchor column base at mechanical room -Provide ledger to house connection per code -Provide missing joist hangers at deck
---	------	---

Comments: