

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213528
Address: 2361 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Failed	Friday, September 23, 2022

Corrective Action Required:

1	Misc	-Pay all fees -Clean debris from storm inlet and remove gutter buddy -Provide AFCI protection and lockouts per code -Provide bonding of whirlpool motor per E4209.5 and manufacturer -Missing cover plates at basement bar -Provide secondary lock at SGD -Provide ledger attachment and missing hangers at deck
---	------	--

Comments: