

## ANALYTICAL REPORT

September 21, 2022

Work Order: 1FI1787

Page 1 of 3

Report To
Adam Nacke City of Lee's Summit - Public Works Dept. 220 SE Green Str Lees Summit, MO 64063

Work Order Information
Date Received: 09/20/2022 9:51AM Collector: Nacke, Adam Phone: (816) 969-7428 PO Number: Routine Analysis

Project : Holthouse Construction

Project Number: Chapel Ridge Townhomes

Analyte	Result	MRL	Batch	Method	Analyst	Analyzed	Qualifier
<b>1FI1787-01</b>	South Main			Matrix:Drink Wtr		Collected: 09/20/22 08:37	
Total Coliforms	<1.0 MPN/100ml	1.0	1FI0959	9223B-QT	CLJ	09/20/22 16:30	
E. Coli	<1.0 MPN/100ml	1.0	1FI0959	9223B-QT	CLJ	09/20/22 16:30	
<b>1FI1787-02</b>	Middle Main			Matrix:Drink Wtr		Collected: 09/20/22 08:29	
Total Coliforms	<1.0 MPN/100ml	1.0	1FI0959	9223B-QT	CLJ	09/20/22 16:30	
E. Coli	<1.0 MPN/100ml	1.0	1FI0959	9223B-QT	CLJ	09/20/22 16:30	
<b>1FI1787-03</b>	3 North Main			Matrix:Drink Wtr		Collected: 09/20/22 08:25	
Total Coliforms	<1.0 MPN/100ml	1.0	1FI0959	9223B-QT	CLJ	09/20/22 16:30	
E. Coli	<1.0 MPN/100ml	1.0	1FI0959	9223B-QT	CLJ	09/20/22 16:30	

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Samples were preserved in accordance with 40 CFR for pH adjustment unless otherwise noted. MRL= Method Reporting Limit.*

City of Lee's Summit - Public Works Dept.  
220 SE Green Str  
Lees Summit, MO 64063

September 21, 2022

Page 2 of 3

Work Order: 1FI1787

**Certified Analyses included in this Report**

Method/Matrix	Analyte	Certifications
<b>9223B-QT in Drink Wtr</b>		
	Total Coliforms	KS-KC,MO-KC
	E. Coli	KS-KC,MO-KC

  

Code	Description	Number	Expires
KS-KC	Kansas Department of Health and Environment-KC	E-10110	04/30/2023
KS-NT	Kansas Department of Health and Environment (NELAP)	E-10287	10/31/2022
MO-KC	Missouri Department of Natural Resources	140	04/30/2023
SIA1X	Iowa Dept. of Natural Resources (updated certificate pending)	95	02/01/2024

End of Report



Keystone Laboratories, Inc.

Carolyn Jackson  
Project Manager

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Samples were preserved in accordance with 40 CFR for pH adjustment unless otherwise noted. MRL= Method Reporting Limit.*

# Keystone

LABORATORIES, INC.

600 E. 17th St. S  
 Newton, IA, 50208  
 Phone: 641-792-8451

3012 Ansborough Ave  
 Waterloo, IA, 50701  
 Phone: 319-235-4440

X 835 S St. Paul  
 Kansas City, KS, 66105  
 Phone: 913-321-7856

205 E Van Buren St  
 Centerville, IA, 52544  
 Phone: 641-437-7023

## CHAIN OF CUSTODY RECORD

### PRINT OR TYPE INFO BELOW:

<b>SAMPLER:</b> Adam Nacke <b>SITE NAME:</b> Chapel ridge townhomes <b>ADDRESS:</b> NE Akin Dr <b>CITY/ST/ZIP:</b> Lee's Summit MO <b>PHONE:</b>		<b>REPORT TO:</b> <b>NAME:</b> Adam nacke <b>CO. NAME:</b> City of Lee's Summit <b>ADDRESS:</b> 220 SE Green St <b>CITY/ST/ZIP:</b> Lee's Summit MO 64093 <b>PHONE:</b> 816-977-5652 <b>Email:</b> Adam.Nacke@cityofls.net		<b>BILL TO:</b> <b>NAME:</b> Travis Holthouse <b>CO. NAME:</b> Holthouse Construction <b>ADDRESS:</b> P.O. Box 1197 <b>CITY/ST/ZIP:</b> Liberty, MO 64069 <b>PHONE:</b> 816-781-6796 <b>Email:</b> Travis@holthouseconstruction.com	
--	--	--	--	---	--

CLIENT SAMPLE #	DATE	TIME	# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED		LAB USE ONLY
						Total Coliform		
South Main	9/20/22	8:37 AM	1	DW G	X			Wk Order #: <b>FI1787</b>
Middle main	9/20/22	8:39 AM	1	DW G	X			Short Hold:
<del>1 North main</del>	<del>9/20/22</del>	<del>8:35 AM</del>	1	<del>DW G</del>	<del>X</del>			Rush:
<del>2 North main</del>	<del>9/20/22</del>	<del>8:35 AM</del>	1	<del>DW G</del>	<del>X</del>			Temp. <b>OC</b>
3 North main	9/20/22	8:35 AM	1	DW G	X			Sample Condition <b>BK</b>
								Sample # <b>FI1787-01</b>

Relinquished by: (Signature) <i>Steve Pollock</i>	Date: 9/20/22 Time: 9:12 Am	Received by: (Signature) <i>Myra</i>	Date: 9/20/22 Time: 9:20 AM	Remarks:
Relinquished by: (Signature) <i>Myra</i>	Date: 9-20-22 Time: 9:51	Received for Lab by: (Signature) <i>Carroll Green</i>	Date: 09/20/22 Time: 09:51	