

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20216366

Address: 3635 NE AKIN DR, Unit:WTR, LEES SUMMIT, MO 640643691 NE AKIN DR, Unit:WTR, LEES SUMMIT,  
MO 640643695 NE AKIN DR, Unit:WTR, LEES SUMMIT, MO 640643635 NE AKIN DR,  
Unit:A, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Coliform Test 1</b>	Adam Nacke	Passed	Monday, September 26, 2022

Informational:

1 Misc

6-1-22 AN there are are 3 mains south, middle and north. South line will be 1 test and middle will be 1 test and north will be 3 test

8-15-22 AN spoke with Brent from water and he informed me that water samples are not required because a back flows are in place

8-18-22 AN water department has come back and told us that they now want water samples from the 3 lines

9-26-22 AN water samples passed for all three mains. File attached

**Comments:**