

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214340
Address: 3121 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Monday, September 26, 2022

Corrective Action Required:

1	Misc	-pay all fees -meter well to grade level -provide attic access above garage -handrail at garage stairs to code -provide ladder to code in basement window well -uncover covered manhole
---	------	--

Comments: