



September 23, 2022

Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082

**RE: Revision to second floor framing for Lot #25 Cobey Creek – 520 SE Carter Rd.
Lee's Summit, MO 64082 – Permit # PRRES20220422**

- Second floor framing shall be revised as shown in image below:
- Install (3) 1-3/4" x 9-1/4" LVL underneath new GT bearing at new wall location.



Sincerely,

Bradley Huxol

Bradley Huxol, PE

