

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20224162
Address: 3221 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Sediment Control (ESC) Inspection	Eric Sharp	Partial	Monday, September 26, 2022

Informational:
1 Misc Erosion control measures installed mostly on the pergola park 5th plat areas. 9/6/22 ES

Erosion control measures installed on 5 plat areas below this permit are intact and functioning. 9/12/22. ES

Erosion control installed, intact and functioning. 9/26/22 ES

Comments: