

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220859
Address: 537 SE CARTER RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, September 27, 2022

Corrective Action Required:

1	Misc	-seal all top plate penetrations - see garage, 1st floor bath, kitchen -fireblock plumbing chase garage -fireblock dryer duct garage wall -secure all NM per code at kitchen, basement (secure within 8" of box) -support ridge both ends at covered porch -provide ridge straps at front covered porch per plans -provide H2.5 hold downs all rafters and 6" truss screws at covered porch rafters on blocks per engineer letter
---	------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: