

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20222629  
Address: 510 SW 3RD ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Michael Harkins	Failed	Tuesday, September 27, 2022

Corrective Action Required:

1	Miscellaneous Correction	Nail exterior sheathing per plan 6" edges & 10" in field per plan pop Fire caulk l upward penetrations throughout Address bores within 2" Of the top & bottom of joist No plate overlap NE corner storage room Provide anchor bolts within 12" of plate break & end of plate
---	--------------------------	--

Comments: