

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20223245  
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Michael Harkins	Partial	Tuesday, September 27, 2022

Informational:

1 Misc

In-wall ok below:

-Clean room 02-1A046; Consultation 02-1A047B; SV office 02-1A058  
- 1A056 - OK 9/6/22  
- RM 021A083 EAST, WEST, SOUTH WALLS OK TO COVER,

Corrective Action Required:

2 Miscellaneous  
Correction

- RM 02-1A083 INSTALL BACKORDERED PANEL SOUTH WALL -

**Comments:**