

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213681
Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Robb Popp	Failed	Tuesday, September 27, 2022

Informational:

1 Misc

-Provide address at disconnect and meters
PARTIAL PASS ONE MORE METER BANK TO COMPLETE

PANEL H2A

HOUSE, MAINTENANCE, 133, 135, 136, 137, 138, 140,
142, 235, 236, 237, 238, 239, 240, 254, 336, 338, 339, 340, 341, 342, 343,

PANEL H22

HOUSE, 135, 149, 151, 152, 153, 154, 155, 156, 157, 158, 159, 160,
252, 253, 255, 257, 259, 261, 263, 256, 258, 260,
, 352, 354, 356, 357, 358, 359, 360, 361, 363, 365, 367,

Corrective Action Required:

2 Misc

H2 B-

-CONNECT METALLIC WATER PIPING TO GROUNDING ELECTRODE SYSTEM
-PROVIDE PROPER, LISTED CLAMP FOR UFER

Comments: