

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213548
Address: 2100 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Robb Popp	Partial	Wednesday, September 28, 2022

Corrective Action Required:		
1	THIRD FLOOR	AREA A -RC AT UNITS AND CORRIDORS -1ST LAYER AT UNITS
Corrective Action Required:		
2	SECOND FLOOR	AREA A -RC AT UNITS AND CORRIDORS
Corrective Action Required:		
3	FIRST FLOOR	AREA B -CLUBHOUSE TRUSSES OK FOR PRE ROCK

Comments: