

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215084
Address: 2614 SW FARM FIELD RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Wednesday, September 28, 2022

Corrective Action Required:

2	Misc	-gutters -splash block and sump pump discharge to extend 36" from foundation -landing at deck stairs to be completed and 36" in the direction of travel -stairs to basement greater than 3/8 difference in rise. See top step 6 1/2" others 7 1/2" -water heater relief valve discharge pipe not to code -complete landscaping at front and rear of lot
---	------	---

Comments: