

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20223245
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Michael Harkins	Partial	Wednesday, September 28, 2022

Informational:

1 Misc

- ROOM 2A116 1 ST LAYER SCREW PATTERN TYPE F2 UL U469 -
- ROOM 2A040 2ND LAYER SCREW PATTERN, ROOM 02-1A094 1ST LAYER ABOVE CEILING GRID -
- RM 02-1A094 2ND LAYER ABOVE CEILING GRID WEST & SOUTH WALLS, SCREW PATTERN 1ST OF 3 LAYERS SOFFIT NORTH WALL -
- RM 02-1A094 2ND LAYER TYPE C SCREW PATTERN AT SOFFIT -

Comments: