

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215084  
Address: 2614 SW FARM FIELD RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Wednesday, September 28, 2022

Corrective Action Required:

2	Misc	-pay all fees -gutters -splash block and sump pump discharge to extend 36" from foundation -landing at deck stairs to be completed and 36" in the direction of travel -stairs to basement greater than 3/8 difference in rise. See top step 6 1/2" others 7 1/2" -water heater relief valve discharge pipe not to code -complete landscaping at front and rear of lot
---	------	---

Comments: