

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20220956  
Address: 520 NE TOWN CENTRE DR, Unit:A, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Fire Line - Hydrostatic Test</b>	Adam Nacke	Passed	Tuesday, September 27, 2022

Informational:

1	Misc	9-27-22 AN. Private water main with 4 hydrants on it. hydro test at 200 psi for 2 hours 1:26pm
		9-27-22 AN 3:26pm hydrostatic test passed at 200psi for 2 hours
		9-28-22 AN. ( Correction ) there was only 3 hydrants on the mega storage job

**Comments:**