

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20221597
Address: 1499 SW MARKET ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Wednesday, September 28, 2022

Corrective Action Required:

1	Misc	-Complete all items for other departments -Complete exterior and parking lot lighting -Complete exterior canopies -Complete electrical for exterior lighting -Provide address at back door -Provide accessible restroom signage -Provide vertical grab bar, mirror in restrooms -Side wall grab bar to be 12" max spacing and 54" min from back wall -Secure mc in riser room -Cover plates in stock room -Provide accessible counter at checkout
---	------	---

****OK TO STOCK ONLY**

Comments: