

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# Temporary Certificate of Occupancy

---

**Permit #:** PRRES20213593  
**Address:** 2143 NW KILLARNEY LN, LEES SUMMIT, MO 64081  
**Inspected On:** Thursday, September 29, 2022  
**Inspected By:** Michael Harkins  
**Expiration Date:** 10/29/2022 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Michael Harkins	Temporary C of O	Thursday, September 29, 2022

**Corrective Action Required:**

- |   |      |  |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none"><li>- Pay all fees</li><li>- Obtain an irrigation permit and submit a back flow certification</li><li>- Seal top of meter can and A/C disconnect</li><li>- Splash blocks to discharge minimum of 36" away from foundation</li><li>- Provide 6" clearance siding to grade</li><li>- Lower water meter to 14-18"</li><li>- Add gravel to water meter pit</li></ul> |
|---|------|--|

TCO expiration 10/29/22