

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215616
Address: 2103 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Not Ready	Thursday, September 29, 2022

Corrective Action Required:

1	Miscellaneous Correction	Provide 1 1/2 bearing deck beam Provide (2) through bolts deck beam to post connection PAY NOT READY FEE
---	--------------------------	--

Comments: