

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220956
Address: 520 NE TOWN CENTRE DR, Unit:A, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Backflow Preventer and Vault		Partial	Thursday, September 29, 2022

Informational:
1 Misc 9-29-22 AN spoke with Jeremy form site rite and let him know that they need to get a floor poured in the vault and a permanently installed pump and pumped to day light or storm or a gravity drain . Also needs steps

Comments: