CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215415

Address: 2122 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Michael Harkins Not Ready Friday, September 30,

Residential 2022

Corrective Action Required:

1 Miscellaneous SUBMIT AS GRADED PLOT PLAN

Correction SECURE IRRIGATION CONDUIT AND SEAL PENETRATION

MAINTAIN SILT FENCE UNTIL SOD COMPLETE

REMOVE TRASH & CONSTRUCTION DEBRIS FROM WINDOW WELL PROVIDE

COVER FOR DRAIN TILE

Pay all fees

irrigation permit submit back flow certification

COMPLETE sod / landscaping

Seal exterior penetrations (irrigation & cable, phone) Steps at patio over the 3/8" variance allowed by code

Comments: