

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20220570  
Address: 1120 NW MAIN ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Roof Drain</b>	John Jackson	Partial	Friday, September 30, 2022

Informational:

1	Misc	08/23/22 Tuesday JMJ ( Central Plumbing Const. ) 8" Roof drain pipe was installed on the South and Westside of structure.
---	------	--

Informational:

2	Misc	On Tuesday, 9-27-2022. Central Plumbing installed storm sewer. Field Inlet Structure ST-G1 and G2 were set with HDPE (3) 8" riser plastic clean out pipes. Contractor also placed 18" HDPE pipe between both field inlets and back field.
---	------	---

**Comments:**