

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PR20222818

Address: 451 SE OLDHAM PKWY, Unit:C, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Robb Popp	Partial	Friday, September 30, 2022

Corrective Action Required:

1	Misc	-Strap top plate lapped less than 4' -Provide anchor bolts within 12" of plate breaks -Complete MEPs and holddowns **TRUSSES OK TO COVER
---	------	---

**Comments:**