

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222410
Address: 2063 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Not Ready	Friday, September 30, 2022

Corrective Action Required:

1	Miscellaneous Correction	Address over bored joist above service panel at SEC cable Nail Cs-16 straps per manufactures installation instructions per Everstead letter (nails)
---	--------------------------	---

Comments: