

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20215387

Address: 914 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081932 NW BLACK TWIG CIR, LEES SUMMIT, MO
64081900 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Site Visit	Eric Sharp	Partial	Friday, September 30, 2022

Informational:

1	Misc	Temperature was too cold to start the compressor for air and vacuum testing. Jeremiah had the wrong diameter for the mandrel testing. He had the right size delivered on site. RP 2-23-22
---	------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Corrective Action Required:

2	Misc	Did air test from manhole C-1 to C-2, but couldn't air test C-1 to A-5 because clean outs weren't sealed. RP 2-24-22
---	------	----------------------------------------------------------------------------------------------------------------------

Informational:

3	Misc	No work being done today that needs inspection. RP 2-25-22
---	------	------------------------------------------------------------

Informational:

4	Misc	No work being done on site today. RP 2-28-22
---	------	----------------------------------------------

Informational:

5	Misc	ESS is on site grading dirt. RP 3-3-22
---	------	----------------------------------------

Informational:

6	Misc	No work being done on site today. RP 3-10-22
---	------	----------------------------------------------

Informational:

7	Misc	ESS is grading the site today. RP 3-14-22
---	------	-------------------------------------------

Informational:

8	Misc	Too wet to work today with last nights rain, plus more rain coming to the area. No erosion issues to report. RP 3-22-22
---	------	-------------------------------------------------------------------------------------------------------------------------

Informational:

9 Misc
Informational:
10 Misc

No utility work or grading being done today. RP 4-6-22

No work being done today with rain. 5/25/22 ES

Construction continues on townhomes. 9/27/22 ES

TH Construction continues. 9/28/22 ES

Framing, concrete and other crews continue working on townhomes. 9/30/22
ES

Comments: