

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20216411
Address: 710 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Eric Sharp	Partial	Friday, September 30, 2022

Informational:

1 Misc

All American construction onsite had setup sidewalk in front of building. with chalk line set for the ramps to come down for ADA access. 9/28/22 ES

All American poured concrete in front of building with flat ramp entrance coming in from ADA spots to west of entryway. 9/30/22 ES

Comments: