

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213815
Address: 1905 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------------|----------|--------------------------|
| Occupancy Inspection - Codes Residential | Patrick Schonfeldt | Failed | Monday, October 03, 2022 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -resolve outstanding inspection fee -handrail at deck stairs shall terminate above top of bottom rise of flight -(2) 1/2" through bolts each post/beam connection at deck -provide attic ventilation at covered deck -install hardware garage door -garage door must be self closing and latching -install light fixtures 2nd floor bath and bedroom -provide handrail basement stairs -provide guard or wall with rock at bottom flight basement stairs |
|---|------|--|

Comments: