

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213548
Address: 2100 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Partial	Friday, September 30, 2022

Corrective Action Required:

1	THIRD FLOOR	AREA "A" UNITS AND CORRIDOR APPROVED
---	-------------	---

	AREA "B" UNITS AND CORRIDOR APPROVED
--	---

Corrective Action Required:

2	SECOND FLOOR	AREA A UNITS AND CORRIDOR APPROVED
---	--------------	---------------------------------------

	AREA B -Seal penetrations dead spaces in corridors outside of 225 225-protect dwv at laundry, 222-ok 223-seal draft stop at corridor, structural strap at corridor, nail structural strap in corridor, nail structural straps at bath, add stud at bathroom,-NO ACCESS 231-240 storage units ok 220-OK 221-SEAL NEW PLATE PENETRATIONS 239-Add stud-use stud grade material 219-seal dead space at master bath, 218-ok
--	--

217-ok
216-ok

Corrective Action Required:

3 FIRST FLOOR AREA A
9/2/22
UNITS 123,124,125,126,127,128,130,132,134

Corrective Action Required:

4 ELEVATOR 1

Corrective Action Required:

5 STAIR TOWER 1 -PROVIDE VERTICAL FIREBLOCKING MAX 10' OC AT SHARED WALL

Corrective Action Required:

6 STAIR TOWER 2 -PROVIDE VERTICAL FIREBLOCKING MAX 10' OC AT SHARED WALL

Corrective Action Required:

7 STAIR TOWER 3

Corrective Action Required:

8 STAIR TOWER 4

Comments: