CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213548

Address: 2100 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Rated Assembly Inspection Robb Popp Partial Monday, October 03,

2022

Corrective Action Required:

1 THIRD FLOOR AREA A

-RC AT UNITS AND CORRIDORS

-1ST LAYER AT UNITS

Corrective Action Required:

2 SECOND FLOOR AREA A

-RC AT UNITS AND CORRIDORS
-1ST LAYER ALL EXCEPT AS NOTED:

**229 MISSING SCREWS

229,228,230-CORRECT ROCK TO PASS THROUGH

Corrective Action Required:

3 FIRST FLOOR AREA A

-RC AT UNITS AND CORRIDOR EXCEPT AS NOTED:

-FIREBLOCK CEILING LINE AT 103A, ADD SUPPORT AT CORRIDOR OUTIDE OF

134, 129-NOT READY

AREA B

-CLUBHOUSE TRUSSES OK FOR PRE ROCK

Comments: