

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20221422

Address: 3503 SW MARKET ST, LEES SUMMIT, MO 640823505 SW MARKET ST, LEES SUMMIT, MO 640823507
SW MARKET ST, LEES SUMMIT, MO 640823509 SW MARKET ST, LEES SUMMIT, MO
640823501 SW MARKET ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Patrick Schonfeldt	Failed	Monday, October 03, 2022

Corrective Action Required:

1	Misc	SUBMIT REVISED PLANS FOR APPROVAL THAT INCLUDE UL DESIGN OF RATED DEMISING WALL, TBD ON DESIGN UNTIL UL DESIGN IS APPROVED, SCREW PATTERN CURRENTLY 12" OC, SOLID BLOCK BETWEEN STUDS AT BOTTOM EDGE TO ALLOW FOR EDGE SCREWS, FIRE CAULK PENETRATIONS AT FIREWALL, STENCIL AND IDENTIFY RATING ON WALL ABOVE CEILING PER IBC 703.7
---	------	---

Comments: