

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214879
Address: 1920 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Monday, October 03, 2022

Corrective Action Required:

1	Misc	-resolve outstanding inspection fee -submit as graded plot plan for review and approval -2nd floor stairs, basement stairs 34"-38" height handrail IRC R311.7.8.1 -provide approved hanger at trpl and dbl deck beam to ledger connection at deck -(2) 1/2" through bolts each post/beam connection at deck
---	------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: