

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211323
Address: 3130 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, October 04, 2022

Corrective Action Required:

1 Misc

- garage to be checked when converted back from sales office
- address open electrical near A/c
- garage door to be self closing AND LACTCHING
- handrail required at stairs in garage handrail to meet code requirements 34-38" from nosing of tread to handrail

Comments: