

PELLA BUILDING SYSTEMS
906 W 9TH ST
PELLA, IA 50219

REACTIONS & ANCHOR BOLTS
FOR
MEGA Storage
DLR ADDRESS 1
DLR ADDRESS 2

LEES SUMMIT
520 NE TOWN CENTRE DRIVE
LEE'S SUMMIT MO
11 12



Richard Joyce

BUILDING LAYOUT

Width (ft)= 65.0
Length (ft)= 70.0
Eave Height (ft)= 16.1/ 15.9
Roof Slope (rise/12)= 0.50/ 0.50

BUILDING LOADS

Roof Dead Load (psf)= 2.0
Wall Dead Load
Left Endwall (psf)= 2.0
Right Endwall (psf)= 2.0
Front Sidewall (psf)= 2.0
Back Sidewall (psf)= 2.0
Live Load (psf)= 20.0
Collateral Load (psf)= 0.5
Snow Load (psf)= 13.4
Minimum Snow (psf)= 16.0
Wind Speed (mph)= 103.0
Wind Code = IBC 18
Closed/Open = C
Exposure = C
Internal Wind Coeff = -0.18, +0.18
Importance - Wind = 1.00
Importance - Seismic = 1.00
Seismic Design Category= B
Seismic Coeff (Fa*Ss) = 0.16

Designer :
Detailer : JB

8/25/22

* Dead	Collat	Live	Snow	Rain	Basic	Wind_Load_Ratio	Seismic
* Load	Load	Load	Load	Load	Wind	Deflect_Factor	Load
2.0	0.5	20.0	13.4	0.0	19.2	0.54	0.60
							0.04

*	Wind	Wind	
*	Press	Suct	
	16.8	-18.5	.. Ext Column
	16.8	-18.5	.. Girt/Header
	16.8	-18.5	.. Jamb
	20.8	-27.7	.. Ext Panel
	44.3	-28.4	.. Parapet Girt
	10.0	-10.0	.. Int Column
	10.0	-10.0	.. Int Panel
	8.5	-6.1	.. Bracing
	12.9	-9.1	.. Bracing, Edge
	28.8	-19.2	.. Bracing, Parapet

* Surf	---Wind_1--		---Wind_2--		Long_Wind	
* Id	Left	Right	Left	Right	1	2
1	0.38	-0.61	0.75	-0.22	-0.65	-0.65
2	-1.14	-0.66	-0.78	-0.30	-1.14	-0.66
3	-0.66	-1.14	-0.30	-0.78	-0.66	-1.14
4	-0.58	0.40	-0.22	0.78	-0.65	-0.65

[illegible]

0	0	16	1.00	1.00	0.75	0.00	0.00	0.00	0.00	0.00	0.45	0.00	0.00	0.00	0.00	0.45	0.0
		0.00															
0	0	17	1.00	1.00	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.45	0.00	0.00	0.00	0.45	0.0
		0.00															
0	0	18	1.00	1.00	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.45	0.00	0.00	0.45	0.0
		0.00															
0	0	19	1.00	1.00	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.45	0.00	0.45	0.0
		0.00															
0	0	20	1.00	1.00	0.00	0.75	0.00	0.00	0.00	0.00	0.45	0.00	0.00	0.00	0.00	0.45	0.0
		0.00															
0	0	21	1.00	1.00	0.00	0.75	0.00	0.00	0.00	0.00	0.00	0.45	0.00	0.00	0.00	0.45	0.0
		0.00															
0	0	22	1.00	1.00	0.00	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.45	0.00	0.00	0.45	0.0
		0.00															
0	0	23	1.00	1.00	0.00	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.45	0.00	0.45	0.0
		0.00															
0	0	24	1.00	1.00	0.00	0.75	0.75	0.00	0.00	0.00	0.45	0.00	0.00	0.00	0.00	0.45	0.0
		0.00															
0	0	25	1.00	1.00	0.00	0.75	0.75	0.00	0.00	0.00	0.00	0.45	0.00	0.00	0.00	0.45	0.0
		0.00															
0	0	26	1.00	1.00	0.00	0.75	0.75	0.00	0.00	0.00	0.00	0.00	0.45	0.00	0.00	0.45	0.0
		0.00															
0	0	27	1.00	1.00	0.00	0.75	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.45	0.00	0.45	0.0
		0.00															
0	0	28	0.60	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.60	0.00	0.00	0.60	0.00	0.0
		0.00															
0	0	29	0.60	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.60	0.60	0.00	0.0
		0.00															
0	0	30	0.60	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.60	0.00	0.00	0.60	0.0
		0.00															
0	0	31	0.60	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.60	0.00	0.60	0.0
		0.00															
0	0	32	0.60	0.00	0.00	0.00	0.00	0.00	0.60	0.00	0.00	0.00	0.00	0.00	0.00	0.60	0.0
		0.00															
0	0	33	0.60	0.00	0.00	0.00	0.00	0.00	0.00	0.60	0.00	0.00	0.00	0.00	0.00	0.60	0.0
		0.00															
0	0	34	0.60	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.60	0.00	0.00	0.00	0.00	0.60	0.0
		0.00															
0	0	35	0.60	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.60	0.00	0.00	0.00	0.60	0.0
		0.00															
0	0	36	1.03	1.03	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.7
		0.00															
0	0	37	1.03	1.03	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-0.7
		0.00															
3	0	38	1.02	1.02	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.5
		0.00															
3	0	39	1.02	1.02	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-0.5
		0.00															
3	0	40	1.02	1.02	0.00	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.5
		0.00															
3	0	41	1.02	1.02	0.00	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-0.5
		0.00															
3	0	42	1.02	1.02	0.00	0.75	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.5
		0.00															
3	0	43	1.02	1.02	0.00	0.75	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-0.5
		0.00															
0	0	44	0.57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.7
		0.00															
0	0	45	0.57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-0.7
		0.00															
0	0	46	1.00	1.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0
		0.00															
0	0	47	1.00	1.00	0.00	0.01	0.00	0.00	0.00	0.00	0.45	0.00	0.00	0.00	0.00	0.45	0.0
		0.00															

0	0	48	1.00	1.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.45	0.00	0.00	0.00	0.45	0.0
			0.00														
0	0	49	1.00	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.7
			0.00														
0	0	50	1.00	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-0.7
			0.00														
0	0	51	0.60	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.7
			0.00														
0	0	52	0.60	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-0.7
			0.00														
0	0	53	1.00	1.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0
			0.00														
0	0	54	1.00	1.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0
			0.00														
0	0	55	1.00	1.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.45	0.0
			0.00														
0	0	56	1.01	1.01	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0
			0.00														

*AUXILIARY LOADS:

				No.	-Add_Load-	
				Add	Id	Coef
*No.	Id	Name				
2	1	MIN_SNOW	2	1	1.00	
				2	1.00	
	2	UNB_SL	4	3	1.00	
				4	0.40	
				5	1.00	
				6	0.37	

*ADDITIONAL LOADS:

		Surf		Basic		Load		Load				---Surface---	
												Start	End
* No.	Id	Id	Load	Type	Orn	W1	W2	D1	D2				
6	1	2	U_SNOW	D	T	-16.00	-16.00	0.00	30.03			0.00	70.00
	2	3	U_SNOW	D	T	-16.00	-16.00	0.00	35.03			0.00	70.00
	3	2	U_SNOW	D	T	-13.44	-13.44	0.00	30.03			0.00	70.00
	4	2	U_SNOW	D	T	-13.44	-13.44	9.09	30.03			0.00	70.00
	5	3	U_SNOW	D	T	-13.44	-13.44	0.00	35.03			0.00	70.00
	6	3	U_SNOW	D	T	-13.44	-13.44	0.00	19.01			0.00	70.00

Frame Line	Column Line	-----Foundation_Loads(k)-----						Anchor_Bolt	
		Max_Positive			Max_Negative			No.	Dia
		Load	Horz	Vert	Load	Horz	Vert		

A	2	1	0.48	-0.03	2	-0.41	-0.35		
		3	0.00	0.83	4	-0.41	-0.37		
A	3	1	0.46	-0.03	2	-0.41	-0.35		
		3	0.00	0.83	4	-0.41	-0.37		
A	4	1	0.46	-0.03	2	-0.42	-0.34		
		3	0.00	0.83	5	0.46	-0.37		
A	5	1	0.48	-0.03	2	-0.42	-0.34		
		3	0.00	0.83	5	0.48	-0.37		
A	6	1	0.48	-0.03	2	-0.43	-0.34		
		3	0.00	0.83	5	0.48	-0.37		
A	7	3	0.00	0.83	4	0.00	-0.27		
		3	0.00	0.83	4	0.00	-0.27		
A	8	1	0.48	-0.23	2	-0.43	-0.15		
		3	0.00	0.83	6	0.48	-0.37		
A	9	1	0.48	-0.23	2	-0.42	-0.15		
		3	0.00	0.83	6	0.48	-0.37		
A	10	1	0.46	-0.23	2	-0.42	-0.15		
		3	0.00	0.83	6	0.46	-0.37		
A	11	1	0.46	-0.23	2	-0.41	-0.15		
		3	0.00	0.83	7	-0.41	-0.37		
A	12	1	0.46	-0.23	2	-0.41	-0.15		
		3	0.00	0.83	7	-0.41	-0.37		
A	13	1	0.48	-0.23	2	-0.41	-0.15		
		3	0.00	0.83	7	-0.41	-0.37		

P	13	1	0.48	-0.03	2	-0.41	-0.35		
		3	0.00	0.83	4	-0.41	-0.37		
P	12	1	0.46	-0.03	2	-0.41	-0.35		
		3	0.00	0.83	4	-0.41	-0.37		
P	11	1	0.46	-0.03	2	-0.41	-0.35		
		3	0.00	0.83	4	-0.41	-0.37		
P	10	1	0.46	-0.03	2	-0.42	-0.34		
		3	0.00	0.83	5	0.46	-0.37		
P	9	1	0.48	-0.03	2	-0.42	-0.34		
		3	0.00	0.83	5	0.48	-0.37		
P	8	1	0.48	-0.03	2	-0.43	-0.34		
		3	0.00	0.83	5	0.48	-0.37		
P	7	3	0.00	0.83	4	0.00	-0.27		
		3	0.00	0.83	4	0.00	-0.27		
P	6	1	0.48	-0.23	2	-0.43	-0.15		
		3	0.00	0.83	6	0.48	-0.37		
P	5	1	0.48	-0.23	2	-0.42	-0.15		
		3	0.00	0.83	6	0.48	-0.37		
P	4	1	0.46	-0.23	2	-0.42	-0.15		
		3	0.00	0.83	6	0.46	-0.37		
P	3	1	0.46	-0.23	2	-0.41	-0.15		
		3	0.00	0.83	7	-0.41	-0.37		
P	2	1	0.48	-0.23	2	-0.41	-0.15		
		3	0.00	0.83	7	-0.41	-0.37		

A	14	1	0.05	0.01	2	-0.04	-0.15		
		3	0.00	0.44	4	-0.04	-0.16		
D	14	3	0.00	0.85	4	0.00	-0.35		
		3	0.00	0.85	4	0.00	-0.35		
G	14	3	0.00	0.85	4	0.00	-0.35		
		3	0.00	0.85	4	0.00	-0.35		

J	14	3	0.00	0.85	4	0.00	-0.35	
		3	0.00	0.85	4	0.00	-0.35	
M	14	3	0.00	0.85	4	0.00	-0.35	
		3	0.00	0.85	4	0.00	-0.35	
P	14	1	0.05	0.01	2	-0.04	-0.15	
		3	0.00	0.44	4	-0.04	-0.16	

P	1	1	0.05	0.01	2	-0.04	-0.15	
		3	0.00	0.44	4	-0.04	-0.16	
M	1	3	0.00	0.85	4	0.00	-0.35	
		3	0.00	0.85	4	0.00	-0.35	
J	1	3	0.00	0.85	4	0.00	-0.35	
		3	0.00	0.85	4	0.00	-0.35	
G	1	3	0.00	0.85	4	0.00	-0.35	
		3	0.00	0.85	4	0.00	-0.35	
D	1	3	0.00	0.85	4	0.00	-0.35	
		3	0.00	0.85	4	0.00	-0.35	
A	1	1	0.05	0.01	2	-0.04	-0.15	
		3	0.00	0.44	4	-0.04	-0.16	

D *	2	1	0.24	-0.11	2	-0.24	-0.74	
		3	0.00	1.62	4	-0.24	-0.79	
D *	3	1	0.24	-0.11	2	-0.24	-0.74	
		3	0.00	1.62	4	-0.24	-0.79	
D *	4	1	0.24	-0.11	2	-0.24	-0.74	
		3	0.00	1.62	4	-0.24	-0.79	
D *	5	1	0.24	-0.11	2	-0.24	-0.74	
		3	0.00	1.62	4	-0.24	-0.79	
D *	6	1	0.26	-0.11	2	-0.26	-0.73	
		3	0.00	1.62	4	-0.26	-0.79	
D *	7	1	0.26	-0.30	2	-0.26	-0.53	
		3	0.00	1.62	4	-0.26	-0.58	
D *	8	1	0.26	-0.50	2	-0.26	-0.35	
		3	0.00	1.62	7	-0.26	-0.79	
D *	9	1	0.24	-0.50	2	-0.24	-0.35	
		3	0.00	1.62	7	-0.24	-0.79	
D *	10	1	0.24	-0.50	2	-0.24	-0.35	
		3	0.00	1.62	7	-0.24	-0.79	
D *	11	1	0.24	-0.50	2	-0.24	-0.35	
		3	0.00	1.62	7	-0.24	-0.79	
D *	12	1	0.24	-0.50	2	-0.24	-0.35	
		3	0.00	1.62	7	-0.24	-0.79	
D *	13	1	0.24	-0.50	2	-0.24	-0.35	
		3	0.00	1.62	7	-0.24	-0.79	

@5	7	8	0.24	-0.11	2	-0.24	-0.21	
		3	0.00	0.58	4	-0.24	-0.23	
@9	7	8	0.24	-0.11	2	-0.24	-0.21	
		3	0.00	0.58	4	-0.24	-0.23	

@19	7	8	0.24	-0.11	2	-0.24	-0.21	
		3	0.00	0.58	4	-0.24	-0.23	
@23	7	8	0.24	-0.11	2	-0.24	-0.21	
		3	0.00	0.58	4	-0.24	-0.23	

D * Frame Lines: D G J M								

Load Id	Load Combination
1	0.6Dead+0.6Wind_Right2+0.6Wind_Suction
2	Dead+0.6Wind_Pressure+0.6Wind_Long1
3	Dead+Collateral+Live
4	0.6Dead+0.6Wind_Pressure+0.6Wind_Long1
5	0.6Dead+0.6Wind_Suction+0.6Wind_Long1

BRACING/PANEL SHEAR REACTIONS:

			-----Bracing(k)-----							
---Wall--		Column_Line		----Wind----		--Seismic---		Panel_Shear(lb/ft)		
Loc	Line	Start	End	Horz	Vert	Horz	Vert	Wind	Seis	
----	----	-----	-----	-----	-----	-----	-----	-----	-----	
Long								127.21	13.00	
L_EW								15.35	1.69	
Tran								30.70	2.58	
Tran								30.70	2.58	
Tran								30.70	2.58	
Tran								30.70	2.58	
R_EW								15.35	1.69	

Building Data

Code	=IBC 18
Length	= 70.00
Width	= 65.00
Left Eave Height	= 16.08
Right Eave Height	= 15.88

Seismic Formula

Base Shear, V = $0.667 \cdot I_e \cdot F_a \cdot S_s \cdot W / R$

Vmin = $0.044 \cdot S_{ds} \cdot I_e \cdot W$

Vmax = $S_{d1} \cdot I_e \cdot W / (T \cdot R)$

T(Moment_Frame) = 0.266

Shear Force, E = $\Omega \cdot \rho \cdot V$

T(Braced_Frame) = 0.165

$F_a \cdot S_s$ = 0.160

Zone/Design Category= B

I_e = 1.200

S_1 = 0.068

S_{d1} = 0.107

S_{ds} = 0.105

Seismic Dead Load

Roof Dead = 2.50 (psf)

Roof Total = 2.50 (psf)

Endwall Dead = 2.00 (psf)

Sidewall Dead = 2.00 (psf)

Interior Wall Dead = 2.00 (psf)

Seismic Forces

Longitudinal Panel

R = 3.00, Ω = 3.00

@ 30.0 W = 21.32 (k)

Force, V = 0.91 (k)

Force, E = 2.73 (k)

Transverse Panel

R = 3.00, Ω = 3.00

L_EW W = 2.57 (k)

Force, V = 0.11 (k)

Force, E = 0.33 (k)

@ 14.0 W = 3.93 (k)

Force, V = 0.17 (k)

Force, E = 0.50 (k)

@ 28.0 W = 3.93 (k)

Force, V = 0.17 (k)

Force, E = 0.50 (k)

@ 42.0 W = 3.93 (k)
 Force, V = 0.17 (k)
 Force, E = 0.50 (k)

@ 56.0 W = 3.93 (k)
 Force, V = 0.17 (k)
 Force, E = 0.50 (k)

R_EW W = 2.57 (k)
 Force, V = 0.11 (k)
 Force, E = 0.33 (k)

Total Base Shear
 Longitudinal
 Force, V = 0.91 (k)
 Transverse
 Force, V = 0.89 (k)

=====

```
*=====
*11 12                Roof Design Input File                8/25/22   2:32pm
*=====
```

```
*( 1)VERSION/UNITS:
*VERSION      Units(I/M)
*  '2.01'      'I'
```

```
*( 2)JOB IDENTIFICATION:
*   Job Id
*   '11 12'
```

```
*( 3)DESIGN CODE:
*Design Steel_Code      ---Build---      Code      Seismic
* Code      Cold      Country      Code      Year      Label      Zone
*  'WS'      'NAUS16'      '----'      'IBC '      '18'      'IBC 18 '      'B '

```

```
*( 4)DESIGN CONSTANTS:
* ---Steel_Yield---      Stress      Strength_Factors
* C_Sec Z_Sec O_Sec      Ratio      Wind      Seismic
* 55.0 55.0 55.0      1.03      1.0000      1.0000

```

```
*( 5)DEFLECTION LIMITS:
* -----Purlin----- --Roof_Panel--
* Live Wind Total      Live Wind
* 180. 150.      0.      60. 60.
```

```
*( 6)REPORTS:
*Input
*Echo Purlin Panel
*  'I'      '2'      'Y'
```

```
*( 7)BUILDING SHAPE:
* Build      Build      L_Eave      R_Eave      Peak      L_Roof      No.
* Width      Length      Height      Height      Offset      Slope      Wall
* 65.0000      70.0000      16.0833      15.8750      30.0000      0.500      8

```

```
*( 8)WALL OPTIONS:
*Wall Design Detail      -----Notch-----      Base_Type      Base_Trim
* Id Option Option      Depth Width Ext Parapet      Panel Jamb      Panel Jamb
* 1 'NYYY' 'YYYY'      1.500 1.500 1.500 0.0000      'O ' 'O '      'Y ' 'Y '
* 2 'NYYY' 'YYYY'      1.500 11.250 1.500 0.0000      'O ' 'O '      'Y ' 'Y '
* 3 'NYYY' 'YYYY'      1.500 1.500 1.500 0.0000      'O ' 'O '      'Y ' 'Y '
* 4 'NYYY' 'YYYY'      1.500 11.250 1.500 0.0000      'O ' 'O '      'Y ' 'Y '

```

```
*( 9)INTERIOR WALL OPTIONS:
*Wall Design Detail      ----Notch---      Base_Type      Base_Trim
* Id Option Option      Depth Width Panel Jamb      Panel Jamb
* 6 'NYYY' 'YYYY'      0.000 0.000 '-' '-'      'N ' 'N '
* 7 'NYYY' 'YYYY'      0.000 0.000 '-' '-'      'N ' 'N '
* 8 'NYYY' 'YYYY'      0.000 0.000 '-' '-'      'N ' 'N '

```

```
*(10)STEP ELEVATION:
*No.      Base      Eave      Step      -Slope_Offset-
*Step      Start      End      Elev      Height      Type      Start      End
* 1      0.0000      70.0000      0.0000      0.0000      '-'      0.0000      0.0000

```

```
*(11)HALL SYSTEM:
* No. Hall      -----Notch-----      ----Wall_Id
*-----
*Hall Id Type Orn Opt      Width Height Locate Offset Length Depth Width L R S
*E
*0

```

* (12) WALL PARTITIONS:

*Sets Of	Wall			Wall			Column
* Walls	Id	(L/T)	Offset	Length	Quan	Location	Side
3	6	'T'	0.0000	65.0000	4	14.0000	'L'
						28.0000	'L'
						42.0000	'L'
						56.0000	'L'
	7	'L'	30.0000	14.0000	1	0.0000	'F'
	8	'L'	30.0000	14.0000	4	14.0000	'F'
						28.0000	'F'
						42.0000	'F'
						56.0000	'F'

* (13) SPECIAL WALLS:

* No.	--Location--		-----Offset----		Material		---Extend---		Base	Frame
*Wall	Use	Id	Start	End	Type	Thick	Type	Offset	Opt	Opt
0										

* (14) RECESS:

* No.	-Location-									Wall_Id
*Recess	Use	Id	Type	Orn	Offset	Width	Depth	Height	Option	L C R
0										

* (15) BAY SPACING:

*Wall	Sets Of	Bay	No.
* Id	Bays	Width	Bays
1	1	5.0000	13
2	1	14.0000	5
3	1	5.0000	13
4	1	14.0000	5
5	2	28.0000	2
		14.0000	1
6	1	5.0000	13
7	1	4.6667	3
8	1	4.6667	3

* (16) BAY OPENINGS:

*No.	Wall	Bay	Bay		Bay	Open	Open	Sill		Access	Jamb_Type	Head		
Set	Id	Id	Offset	Type	Depth	Width	Height	Height	Opt	Id	Lt	Rt	Type	D
*Open														
Depth														
10	2	1	1.0000	2	35.0000	12.0000	14.0000	0.0000	'-'	'DOOR62	'C	'C	'C	6
.000	2	2	1.0000	2	35.0000	12.0000	14.0000	0.0000	'-'	'DOOR62	'C	'C	'C	6
.000	2	3	1.0000	2	35.0000	12.0000	14.0000	0.0000	'-'	'DOOR62	'C	'C	'C	6
.000	2	4	1.0000	2	35.0000	12.0000	14.0000	0.0000	'-'	'DOOR62	'C	'C	'C	6
.000	2	5	1.0000	2	35.0000	12.0000	14.0000	0.0000	'-'	'DOOR62	'C	'C	'C	6
.000	4	1	1.0000	2	30.0000	12.0000	14.0000	0.0000	'-'	'DOOR62	'C	'C	'C	6
.000	4	2	1.0000	2	30.0000	12.0000	14.0000	0.0000	'-'	'DOOR62	'C	'C	'C	6
.000	4	3	1.0000	2	30.0000	12.0000	14.0000	0.0000	'-'	'DOOR62	'C	'C	'C	6
.000	4	4	1.0000	2	30.0000	12.0000	14.0000	0.0000	'-'	'DOOR62	'C	'C	'C	6
.000	4	5	1.0000	2	30.0000	12.0000	14.0000	0.0000	'-'	'DOOR62	'C	'C	'C	6

* (17) OPEN WALLS:

```

*No.    -Location-  --Bay_Id--  Wall    ----Type---  Base  Full
*Wall   Use        Id  Start  End    Height  Use        Id Opt  Type  Load
0

*(18)ADDITIONAL RAFTERS:
*No.    Raf  Location      Raf    -----Offset-----  Raf  Raf  Raf  Set
*Raf    Id  Use   Id   Locate  Start      End    Type  Rot  Opt  Depth
0

*(19)ROOF PURLINS:
*Purlin      Flg_Strap      Set    Purlin    Max_Unbr
* Type      Opt  OS   IS    Offset  Depth    Lap    Length
'ZB'      '-'  'C'  'N'    0.000  0.000    1.0000  0.0000

*(20)PURLIN SPACING:
*   Peak      No    ---Purlin---
*   Space  Purlins  Location Rot
0.0000    12      5.0000 'N'
                  10.0000 'N'
                  15.0000 'N'
                  20.0000 'N'
                  25.0000 'N'
                  30.0000 'N'
                  35.0000 'Y'
                  40.0000 'Y'
                  45.0000 'Y'
                  50.0000 'Y'
                  55.0000 'Y'
                  60.0000 'Y'

*(21)PURLIN SIZE:
*   No.    Part
0

*(22)EAVE STRUT:
*Wall   Eave_Strut
* Id     Type  Depth  Gutter
2       '-'   0.000  'N'
4       '-'   0.000  'N'

*(23)EXTERIOR WALL PANEL:
*Wall   -----Wall_Panel-----
* Id     Part      Rot Opt  Screw  Color
1       'CUSPANL '  '-' '-'  'S--'  'A1 '
2       'CUSPANL '  '-' '-'  'S--'  'A1 '
3       'CUSPANL '  '-' '-'  'S--'  'A1 '
4       'CUSPANL '  '-' '-'  'S--'  'A1 '

*(24)INTERIOR WALL PANEL:
*Wall   -----Wall_Panel-----
* Id     Part      Rot Opt  Screw  Color
6       'PBR29    '  'R' '-'  'S--'  'GL '
7       'PBR29    '  'R' '-'  'S--'  'GL '
8       'PBR29    '  'R' '-'  'S--'  'GL '

*(25)ROOF PANEL:
* Panel      Panel  Screw  -----Standing_Seam-----
* Size      Opt    Type    Use  Type  Clip  Seam Type      Clamp
'PBR26     '  '-'    'S--'  'N'  '3U'  3.000  '-----'  'N'

*(26)EXTERIOR WIND FRAMING:
*Wall Panel  Brace      Wall No.
* Id  Shear  Type  Opt  Dead Bay
1     'Y'    'N'  '-'  2.00  0
2     'Y'    'N'  '-'  2.00  0

```

3	'Y'	'N'	'-'	2.00	0
4	'Y'	'N'	'-'	2.00	0
5	'Y'	'N'	'-'	2.50	0

* (27) INTERIOR WIND FRAMING:

*	Panel	Brace	Wall	No.
*	Shear	Type	Opt	Dead Bay
	'Y'	'N'	'-'	2.00 0
	'Y'	'N'	'-'	2.00 0

* (28) BASIC LOADS:

*							---Deflection---		
*	Dead	Collat	Live	Snow	Rain	Basic	Load_Ratio		
*	Load	Load	Load	Load	Load	Wind	Snow	Wind	Seis
	2.0	0.5	20.0	13.4	0.0	19.2	1.00	0.54	1.00

* (29) WIND PRESSURE/SUCTION:

*	Wind	Wind		
*	Press	Suct		
	16.0	-17.9	..	Purlins
	16.0	-20.8	..	Panels

* (30) ROOF EDGE & CORNER ZONES:

*Surf	No	Zone			---Purlin---		---Panel----			
*	Id	Zone	Id	Width	Length	Press	Suct	Press	Suct	
	2	7	1	0.00	0.00	1.00	1.00	1.00	1.00	.. Interior
			2	9.52	9.52	1.00	1.45	1.00	1.74	.. Middle
			7	3.18	9.52	1.00	2.15	1.00	3.13	.. Corner top-left
			8	3.18	9.52	1.00	2.15	1.00	3.13	.. Corner top-right
			11	6.35	3.18	1.00	2.15	1.00	3.13	.. Corner Gable top-left
			12	6.35	3.18	1.00	2.15	1.00	3.13	.. Corner Gable top-right
			15	9.52	9.52	1.00	1.93	1.00	2.30	.. Exterior
	3	7	1	0.00	0.00	1.00	1.00	1.00	1.00	.. Interior
			2	9.52	9.52	1.00	1.45	1.00	1.74	.. Middle
			9	3.18	9.52	1.00	2.15	1.00	3.13	.. Corner bot-right
			10	3.18	9.52	1.00	2.15	1.00	3.13	.. Corner bot-left
			13	6.35	3.18	1.00	2.15	1.00	3.13	.. Corner Gable bot-right
			14	6.35	3.18	1.00	2.15	1.00	3.13	.. Corner Gable bot-left
			15	9.52	9.52	1.00	1.93	1.00	2.30	.. Exterior

* (31) PURLIN DESIGN LOADS:

*	No_Des	Load							Wind	Wind	Aux_Load
*	Loads	Id	Dead	Collat	Live	Snow	Drift	Rain	Press	Suct	Id Coef
	18	1	1.00	1.00	1.00	0.00	0.00	0.00	0.00	0.00	0 0.00
		2	1.00	1.00	0.00	1.00	0.00	0.00	0.00	0.00	0 0.00
		3	1.00	1.00	0.00	1.00	1.00	0.00	0.00	0.00	0 0.00
		4	1.00	1.00	0.75	0.00	0.00	0.00	0.45	0.00	0 0.00
		5	1.00	1.00	0.00	0.75	0.00	0.00	0.45	0.00	0 0.00
		6	1.00	1.00	0.00	0.75	0.75	0.00	0.45	0.00	0 0.00
		7	0.60	0.00	0.00	0.00	0.00	0.00	0.00	0.60	0 0.00
		8	1.00	1.00	0.00	0.01	0.00	0.00	0.00	0.00	1 1.00
		9	1.00	1.00	0.00	0.01	0.00	0.00	0.45	0.00	1 0.75
		10	1.00	1.00	0.00	0.50	0.00	0.00	0.00	0.00	4 1.00
		11	1.00	1.00	0.00	0.50	0.00	0.00	0.00	0.00	5 1.00
		12	1.00	1.00	0.00	0.50	0.00	0.00	0.00	0.00	6 1.00
		13	1.00	1.00	0.00	0.50	0.00	0.00	0.00	0.00	7 1.00
		14	1.00	1.00	0.00	0.50	0.00	0.00	0.00	0.00	2 1.00
		15	1.00	1.00	0.00	0.50	0.00	0.00	0.00	0.00	3 1.00
		16	1.00	1.00	0.00	1.00	0.00	0.00	0.00	0.00	2 -1.00
		17	1.00	1.00	0.00	1.00	0.00	0.00	0.00	0.00	3 -1.00
		18	1.00	1.00	0.00	0.01	0.00	0.00	0.00	0.00	8 1.00

* (32) PURLIN DESIGN LOADS: Deflection

*	No_Des	Load							Wind	Wind	Aux_Load
*	Loads	Id	Dead	Collat	Live	Snow	Drift	Rain	Press	Suct	Id Coef

18	19	1.00	1.00	1.00	0.00	0.00	0.00	0.00	0.00	0	0.00
	20	1.00	1.00	0.00	1.00	0.00	0.00	0.00	0.00	0	0.00
	21	1.00	1.00	0.00	1.00	1.00	0.00	0.00	0.00	0	0.00
	22	1.00	1.00	0.75	0.00	0.00	0.00	0.75	0.00	0	0.00
	23	1.00	1.00	0.00	0.75	0.00	0.00	0.75	0.00	0	0.00
	24	1.00	1.00	0.00	0.75	0.75	0.00	0.75	0.00	0	0.00
	25	0.60	0.00	0.00	0.00	0.00	0.00	0.00	1.00	0	0.00
	26	1.00	1.00	0.00	0.01	0.00	0.00	0.00	0.00	1	1.00
	27	1.00	1.00	0.00	0.01	0.00	0.00	0.75	0.00	1	0.75
	28	1.00	1.00	0.00	0.50	0.00	0.00	0.00	0.00	4	1.00
	29	1.00	1.00	0.00	0.50	0.00	0.00	0.00	0.00	5	1.00
	30	1.00	1.00	0.00	0.50	0.00	0.00	0.00	0.00	6	1.00
	31	1.00	1.00	0.00	0.50	0.00	0.00	0.00	0.00	7	1.00
	32	1.00	1.00	0.00	0.50	0.00	0.00	0.00	0.00	2	1.00
	33	1.00	1.00	0.00	0.50	0.00	0.00	0.00	0.00	3	1.00
	34	1.00	1.00	0.00	1.00	0.00	0.00	0.00	0.00	2	-1.00
	35	1.00	1.00	0.00	1.00	0.00	0.00	0.00	0.00	3	-1.00
	36	1.00	1.00	0.00	0.01	0.00	0.00	0.00	0.00	8	1.00

* (33) PANEL DESIGN LOADS:

* No_Des	Load							Wind	Wind	Aux_Load	
* Loads	Id	Dead	Collat	Live	Snow	Drift	Rain	Press	Suct	Id	Coef
9	1	1.00	0.00	1.00	0.00	0.00	0.00	0.00	0.00	0	0.00
	2	1.00	0.00	0.00	1.00	0.00	0.00	0.00	0.00	0	0.00
	3	1.00	0.00	0.00	1.00	1.00	0.00	0.00	0.00	0	0.00
	4	1.00	0.00	0.75	0.00	0.00	0.00	0.45	0.00	0	0.00
	5	1.00	0.00	0.00	0.75	0.00	0.00	0.45	0.00	0	0.00
	6	0.60	0.00	0.00	0.00	0.00	0.00	0.00	0.60	0	0.00
	7	1.00	0.00	0.00	0.01	0.00	0.00	0.00	0.00	1	1.00
	8	1.00	0.00	0.00	0.01	0.00	0.00	0.45	0.00	1	0.75
	9	1.00	1.00	0.00	0.01	0.00	0.00	0.00	0.00	8	1.00

* (34) PANEL DESIGN LOADS: Deflection

* No_Des	Load							Wind	Wind	Aux_Load	
* Loads	Id	Dead	Collat	Live	Snow	Drift	Rain	Press	Suct	Id	Coef
7	10	0.00	0.00	1.00	0.00	0.00	0.00	0.00	0.00	0	0.00
	11	0.00	0.00	0.00	1.00	0.00	0.00	0.00	0.00	0	0.00
	12	0.00	0.00	0.00	1.00	1.00	0.00	0.00	0.00	0	0.00
	13	0.00	0.00	0.00	0.00	0.00	0.00	1.00	0.00	0	0.00
	14	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.00	0	0.00
	15	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.00	1	1.00
	16	1.00	1.00	0.00	0.01	0.00	0.00	0.00	0.00	8	1.00

* (35) AUXILIARY LOADS:

* No.	Aux	Aux	No._Add	Add_Load		
* Aux	Id	Name	Combs	Id	Coef	
8	1	'MIN_SNOW	' 2	1	1.00	
				2	1.00	
	2	'PAT_SL_1	' 1	3	0.50	
	3	'PAT_SL_2	' 1	7	0.50	
	4	'PAT_SL_3	' 2	3	0.50	
				4	0.50	
	5	'PAT_SL_4	' 2	4	0.50	
				5	0.50	
	6	'PAT_SL_5	' 2	5	0.50	
				6	0.50	
	7	'PAT_SL_6	' 2	6	0.50	
				7	0.50	

8	'UNB_SL	'	4	8	1.00
				9	0.40
				10	1.00
				11	0.37

*(36) ADDITIONAL LOADS:

*No.	Add	Surf	Basic	Load	Load	F		D		---Surface---
*Add	Id	Id	Load	Type	Orn	W1	W2	D1	D2	Start End
11	1	2	'U_SNOW'	'D'	'T'	-16.00	-16.00	0.0000	30.0260	0.000 70.000
	2	3	'U_SNOW'	'D'	'T'	-16.00	-16.00	0.0000	35.0304	0.000 70.000
	3	0	'U_SNOW'	'D'	'L'	-13.44	-13.44	0.0000	14.0000	0.000 0.000
	4	0	'U_SNOW'	'D'	'L'	-13.44	-13.44	14.0000	28.0000	0.000 0.000
	5	0	'U_SNOW'	'D'	'L'	-13.44	-13.44	28.0000	42.0000	0.000 0.000
	6	0	'U_SNOW'	'D'	'L'	-13.44	-13.44	42.0000	56.0000	0.000 0.000
	7	0	'U_SNOW'	'D'	'L'	-13.44	-13.44	56.0000	70.0000	0.000 0.000
	8	2	'U_SNOW'	'D'	'T'	-13.44	-13.44	0.0000	30.0260	0.000 70.000
	9	2	'U_SNOW'	'D'	'T'	-13.44	-13.44	9.0934	30.0260	0.000 70.000
	10	3	'U_SNOW'	'D'	'T'	-13.44	-13.44	0.0000	35.0304	0.000 70.000
	11	3	'U_SNOW'	'D'	'T'	-13.44	-13.44	0.0000	19.0065	0.000 70.000

*(37) PURLIN BREAK:

*Opt	No.	Location
'-'	0	

*(38) PANEL SCREWS:

*No.	Locate	Id	Zone	Part	Dia	Limit	Washer	Dia	-----Spacing-----
3	'ROOF'	0	'INT'	'#17A'	0.209	2.900	0.500	11.429	5.714 0.000
	'ROOF'	0	'EDGE'	'#17A'	0.209	2.900	0.500	11.429	5.714 0.000
	'ROOF'	0	'CORN'	'#17A'	0.209	2.900	0.500	11.429	5.714 0.000

*(39) ADDITIONAL ROOF FRAMING:

*No.	Id	Use	Orn	Offset	Start	End	Type	Opt	Rot	Part
0										

*(40) CONNECTION SCREWS:

*No.	Use	Part	Limit	Qty
1	'LAP'	'#1A'	2.05	6

*AUXILIARY LOAD DESCRIPTIONS:

* Aux	Id	Description
	1	Minimum snow load
	2	Pattern snow load
	3	Pattern snow load
	4	Pattern snow load
	5	Pattern snow load
	6	Pattern snow load
	7	Pattern snow load
	8	Unbalanced snow load

*ADDITIONAL LOAD DESCRIPTIONS:

* Add	Id	Description
	1	Minimum snow load surface 2
	2	Minimum snow load surface 3
	3	Pattern snow load bay 1
	4	Pattern snow load bay 2
	5	Pattern snow load bay 3
	6	Pattern snow load bay 4
	7	Pattern snow load bay 5
	8	Unbalanced snow load surface 2

```
*      9  Unbalanced snow load surface 2
*     10  Unbalanced snow load surface 3
*     11  Unbalanced snow load surface 3
*
* Code file used was ROOFIBC.18N Version 4.5
```


STRUCTURAL CODE:

Design Basis : WS - Working Stress
Cold Formed Steel : NAUS16

BUILDING CODE:

Wind Code : IBC 18
Seismic Zone : B

MODULUS OF ELASTICITY

Cold Formed Steel : 29500 (ksi)

SURFACE LAYOUT:

Surface Id	Length	No. Row
2	30.026	5

PURLIN LOCATION:

Purlin Id	Surf Offset	Space	Load Width	Dead Load	Show Report	-----Max_Load----- Id UC Report
1	5.004	5.004	5.004	0.53		4 0.94 Moment
2	10.009	5.004	5.004	0.53		4 0.94 Moment
3	15.013	5.004	5.004	0.53	Y	4 0.94 Moment
4	20.017	5.004	5.004	0.53		4 0.94 Moment
5	25.022	5.004	5.004	0.53		4 0.94 Moment
	30.026	5.004				

				Average=	0.53	

LAYOUT:

Bay Id	Part	Bay Width	---Lap(ft)--- Left Right		No. Brace	Unit Weight	Total Weight
1	6X25Z14	28.00		1.00	0	81.2	406.0
2	6X25Z16	28.00	1.00	1.00	0	70.2	351.0
3	6X25Z16	14.00	1.00		0	35.1	175.5
Total (lb)=						186.5	932.5

LOAD COMBINATIONS:

4 - Dead+Collateral+0.75Live+0.45Wind_Pressure

ROOF PURLIN
Surface Id = 2
Purlin Id = 3
Offset = 15.01

PURLIN LAYOUT:

Bay Id	Part	Design Length (ft)	---Lap(ft)---		Load Width	No. Brace	Unit Weight	Available Reduction	
			Left	Right				Out	In
1	6X25Z14	14.00			5.00	0	39.2	0.00	0.70
1	6X25Z14	14.00		1.00	5.00	0	42.0	0.00	0.70
2	6X25Z16	14.00	1.00		5.00	0	35.1	0.00	0.70
2	6X25Z16	14.00		1.00	5.00	0	35.1	0.00	0.70
3	6X25Z16	14.00	1.00		5.00	0	35.1	0.00	0.70

LOAD ID 1 : Dead+Collateral+Live

REACTIONS:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----					
	Left Sup	Left Lap	Right Lap	Right Sup	Left Sup	Left Lap	Mid-Span Mom	Span Loc	Right Lap	Right Sup
1	0.62			-0.95	0.00		-1.73	5.55		2.28
1	0.82		-0.65	-0.76	2.28		-0.67	7.25	1.18	1.89
2	0.80	0.69		-0.77	1.89	1.14	-0.98	7.14		1.67
2	0.73		-0.73	-0.84	1.67		-0.70	6.48	1.69	2.48
3	0.96	0.85		-0.61	2.48	1.57	-1.65	8.57		0.00

STRENGTH/DEFLECTION:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
1	RSup	-0.95	6.04	0.16	RSup	2.28	2.79	0.82	RSup	0.70	-0.36	
1	LSup	0.82	6.04	0.13	LSup	2.28	2.77	0.83	LSup	0.70	-0.07	
2	RSup	-0.77	3.86	0.20	RSup	1.67	2.06	0.81	RSup	0.66	-0.20	
2	RLap	-0.73	3.86	0.19	RLap	1.69	2.05	0.83	RLap	0.67	-0.09	
3	LLap	0.85	3.86	0.22	MidS	-1.65	1.93	0.86	LLap	0.64	-0.40	

UNBRACED LENGTH:

Bay Id	Major (ft)	-----Minor(ft)-----					-----Mom1/Mom2-----					-----Cb-----				
		LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
1	14.0	11.1	1.0	1.0	1.0	2.9	1.00	1.00	1.00	1.00	0.00	1.14	1.00	1.00	1.00	1.77
2	14.0	3.8	3.8	1.0	2.3	1.0	0.00	0.00	1.00	0.00	0.63	1.85	1.85	1.00	1.79	1.18
3	14.0	1.0	2.0	1.0	1.0	2.7	0.60	0.00	1.00	1.00	0.00	1.20	1.76	1.00	1.00	1.79
4	14.0	3.0	1.0	1.0	3.0	1.0	0.00	1.00	1.00	0.00	0.68	1.82	1.00	1.00	1.82	1.15
5	14.0	1.0	2.1	1.0	1.0	10.9	0.63	0.00	1.00	1.00	1.00	1.18	1.75	1.00	1.00	1.14

LOAD ID 2 : Dead+Collateral+Snow

REACTIONS:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----					
	Left Sup	Left Lap	Right Lap	Right Sup	Left Sup	Left Lap	Mid-Span Mom	Span Loc	Right Lap	Right Sup

1	0.44			-0.67	0.00		-1.22	5.55		1.61
1	0.58		-0.46	-0.54	1.61		-0.48	7.25	0.84	1.33
2	0.57	0.49		-0.55	1.33	0.81	-0.69	7.14		1.18
2	0.52		-0.52	-0.60	1.18		-0.49	6.48	1.19	1.75
3	0.68	0.60		-0.43	1.75	1.11	-1.17	8.57		0.00

STRENGTH/DEFLECTION:

Bay	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
Id	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
1	RSup	-0.67	6.04	0.11	RSup	1.61	2.79	0.58	RSup	0.50	-0.26	
1	LSup	0.58	6.04	0.10	LSup	1.61	2.77	0.58	LSup	0.49	-0.05	
2	RSup	-0.55	3.86	0.14	RSup	1.18	2.06	0.57	RSup	0.47	-0.14	
2	RLap	-0.52	3.86	0.13	RLap	1.19	2.05	0.58	RLap	0.47	-0.06	
3	LLap	0.60	3.86	0.16	MidS	-1.17	1.93	0.61	LLap	0.45	-0.28	

UNBRACED LENGTH:

Bay	Major	-----Minor(ft)-----					-----Mom1/Mom2-----					-----Cb-----				
Id	(ft)	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
1	14.0	11.1	1.0	1.0	1.0	2.9	1.00	1.00	1.00	1.00	0.00	1.14	1.00	1.00	1.00	1.77
2	14.0	3.8	3.8	1.0	2.3	1.0	0.00	0.00	1.00	0.00	0.63	1.85	1.85	1.00	1.79	1.18
3	14.0	1.0	2.0	1.0	1.0	2.7	0.60	0.00	1.00	1.00	0.00	1.20	1.76	1.00	1.00	1.79
4	14.0	3.0	1.0	1.0	3.0	1.0	0.00	1.00	1.00	0.00	0.68	1.82	1.00	1.00	1.82	1.15
5	14.0	1.0	2.1	1.0	1.0	10.9	0.63	0.00	1.00	1.00	1.00	1.18	1.75	1.00	1.00	1.14

LOAD ID 3 : Dead+Collateral+Snow+Snow_Drift

REACTIONS:

Bay	-----Shear(k)-----				-----Moment(f-k)-----					
Id	Left Sup	Left Lap	Right Lap	Right Sup	Left Sup	Left Lap	Mid-Span Mom	Span Loc	Right Lap	Right Sup
1	0.44			-0.67	0.00		-1.22	5.55		1.61
1	0.58		-0.46	-0.54	1.61		-0.48	7.25	0.84	1.33
2	0.57	0.49		-0.55	1.33	0.81	-0.69	7.14		1.18
2	0.52		-0.52	-0.60	1.18		-0.49	6.48	1.19	1.75
3	0.68	0.60		-0.43	1.75	1.11	-1.17	8.57		0.00

STRENGTH/DEFLECTION:

Bay	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
Id	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
1	RSup	-0.67	6.04	0.11	RSup	1.61	2.79	0.58	RSup	0.50	-0.26	
1	LSup	0.58	6.04	0.10	LSup	1.61	2.77	0.58	LSup	0.49	-0.05	
2	RSup	-0.55	3.86	0.14	RSup	1.18	2.06	0.57	RSup	0.47	-0.14	
2	RLap	-0.52	3.86	0.13	RLap	1.19	2.05	0.58	RLap	0.47	-0.06	
3	LLap	0.60	3.86	0.16	MidS	-1.17	1.93	0.61	LLap	0.45	-0.28	

UNBRACED LENGTH:

Bay	Major	-----Minor(ft)-----					-----Mom1/Mom2-----					-----Cb-----				
Id	(ft)	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
1	14.0	11.1	1.0	1.0	1.0	2.9	1.00	1.00	1.00	1.00	0.00	1.14	1.00	1.00	1.00	1.77
2	14.0	3.8	3.8	1.0	2.3	1.0	0.00	0.00	1.00	0.00	0.63	1.85	1.85	1.00	1.79	1.18
3	14.0	1.0	2.0	1.0	1.0	2.7	0.60	0.00	1.00	1.00	0.00	1.20	1.76	1.00	1.00	1.79
4	14.0	3.0	1.0	1.0	3.0	1.0	0.00	1.00	1.00	0.00	0.68	1.82	1.00	1.00	1.82	1.15
5	14.0	1.0	2.1	1.0	1.0	10.9	0.63	0.00	1.00	1.00	1.00	1.18	1.75	1.00	1.00	1.14

LOAD ID 4 : Dead+Collateral+0.75Live+0.45Wind_Pressure

REACTIONS:

Bay	-----Shear(k)-----				-----Moment(f-k)-----					
-----	---------------------	--	--	--	------------------------	--	--	--	--	--

Bay Id	Left Sup	Left Lap	Right Lap	Right Sup	Left Sup	Left Lap	Mid-Span Mom	Loc	Right Lap	Right Sup
---	---	---	---	---	---	---	---	---	---	---
1	0.69			-1.04	0.00		-1.90	5.55		2.51
1	0.90		-0.71	-0.83	2.51		-0.74	7.25	1.30	2.07
2	0.88	0.76		-0.85	2.07	1.25	-1.07	7.14		1.83
2	0.80		-0.80	-0.93	1.83		-0.76	6.48	1.86	2.72
3	1.06	0.94		-0.67	2.72	1.73	-1.82	8.57		0.00

STRENGTH/DEFLECTION:

Bay	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
Id	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
---	---	---	---	---	---	---	---	---	---	---	---	---
1	RSup	-1.04	6.04	0.17	RSup	2.51	2.79	0.90	RSup	0.77	-0.40	
1	LSup	0.90	6.04	0.15	LSup	2.51	2.77	0.91	LSup	0.77	-0.07	
2	RSup	-0.85	3.86	0.22	RSup	1.83	2.06	0.89	RSup	0.73	-0.22	
2	RLap	-0.80	3.86	0.21	RLap	1.86	2.05	0.91	RLap	0.74	-0.09	
3	LLap	0.94	3.86	0.24	MidS	-1.82	1.93	0.94	LLap	0.70	-0.44	

UNBRACED LENGTH:

Bay Id	Major (ft)	Minor(ft)					Mom1/Mom2					Cb				
---	---	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
1	14.0	11.1	1.0	1.0	1.0	2.9	1.00	1.00	1.00	1.00	0.00	1.14	1.00	1.00	1.00	1.77
2	14.0	3.8	3.8	1.0	2.3	1.0	0.00	0.00	1.00	0.00	0.63	1.85	1.85	1.00	1.79	1.18
3	14.0	1.0	2.0	1.0	1.0	2.7	0.60	0.00	1.00	1.00	0.00	1.20	1.76	1.00	1.00	1.79
4	14.0	3.0	1.0	1.0	3.0	1.0	0.00	1.00	1.00	0.00	0.68	1.82	1.00	1.00	1.82	1.15
5	14.0	1.0	2.1	1.0	1.0	10.9	0.63	0.00	1.00	1.00	1.00	1.18	1.75	1.00	1.00	1.14

LOAD ID 5 : Dead+Collateral+0.75Snow+0.45Wind_Pressure

REACTIONS:

Bay Id	Left Sup	Left Lap	Right Lap	Right Sup	Left Sup	Left Lap	Mid-Span Mom	Loc	Right Lap	Right Sup
---	---	---	---	---	---	---	---	---	---	---
1	0.55			-0.83	0.00		-1.52	5.55		2.01
1	0.72		-0.57	-0.67	2.01		-0.59	7.25	1.04	1.66
2	0.70	0.61		-0.68	1.66	1.00	-0.86	7.14		1.46
2	0.64		-0.64	-0.74	1.46		-0.61	6.48	1.48	2.18
3	0.85	0.75		-0.54	2.18	1.38	-1.45	8.57		0.00

STRENGTH/DEFLECTION:

Bay	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
Id	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
---	---	---	---	---	---	---	---	---	---	---	---	---
1	RSup	-0.83	6.04	0.14	RSup	2.01	2.79	0.72	RSup	0.62	-0.32	
1	LSup	0.72	6.04	0.12	LSup	2.01	2.77	0.73	LSup	0.61	-0.06	
2	RSup	-0.68	3.86	0.18	RSup	1.46	2.06	0.71	RSup	0.58	-0.17	
2	RLap	-0.64	3.86	0.17	RLap	1.48	2.05	0.73	RLap	0.59	-0.08	
3	LLap	0.75	3.86	0.19	MidS	-1.45	1.93	0.75	LLap	0.56	-0.35	

UNBRACED LENGTH:

Bay Id	Major (ft)	Minor(ft)					Mom1/Mom2					Cb				
---	---	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
1	14.0	11.1	1.0	1.0	1.0	2.9	1.00	1.00	1.00	1.00	0.00	1.14	1.00	1.00	1.00	1.77
2	14.0	3.8	3.8	1.0	2.3	1.0	0.00	0.00	1.00	0.00	0.63	1.85	1.85	1.00	1.79	1.18
3	14.0	1.0	2.0	1.0	1.0	2.7	0.60	0.00	1.00	1.00	0.00	1.20	1.76	1.00	1.00	1.79
4	14.0	3.0	1.0	1.0	3.0	1.0	0.00	1.00	1.00	0.00	0.68	1.82	1.00	1.00	1.82	1.15
5	14.0	1.0	2.1	1.0	1.0	10.9	0.63	0.00	1.00	1.00	1.00	1.18	1.75	1.00	1.00	1.14

LOAD ID 6 : Dead+Collateral+0.75Snow+0.45Wind_Pressure+0.75Snow_Drift

REACTIONS:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----					
	Left Sup	Left Lap	Right Lap	Right Sup	Left Sup	Left Lap	Mid-Span Mom	Loc	Right Lap	Right Sup
1	0.55			-0.83	0.00		-1.52	5.55		2.01
1	0.72		-0.57	-0.67	2.01		-0.59	7.25	1.04	1.66
2	0.70	0.61		-0.68	1.66	1.00	-0.86	7.14		1.46
2	0.64		-0.64	-0.74	1.46		-0.61	6.48	1.48	2.18
3	0.85	0.75		-0.54	2.18	1.38	-1.45	8.57		0.00

STRENGTH/DEFLECTION:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
1	RSup	-0.83	6.04	0.14	RSup	2.01	2.79	0.72	RSup	0.62	-0.32	
1	LSup	0.72	6.04	0.12	LSup	2.01	2.77	0.73	LSup	0.61	-0.06	
2	RSup	-0.68	3.86	0.18	RSup	1.46	2.06	0.71	RSup	0.58	-0.17	
2	RLap	-0.64	3.86	0.17	RLap	1.48	2.05	0.73	RLap	0.59	-0.08	
3	LLap	0.75	3.86	0.19	MidS	-1.45	1.93	0.75	LLap	0.56	-0.35	

UNBRACED LENGTH:

Bay Id	Major (ft)	-----Minor(ft)-----					-----Mom1/Mom2-----					-----Cb-----				
		LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
1	14.0	11.1	1.0	1.0	1.0	2.9	1.00	1.00	1.00	1.00	0.00	1.14	1.00	1.00	1.00	1.77
2	14.0	3.8	3.8	1.0	2.3	1.0	0.00	0.00	1.00	0.00	0.63	1.85	1.85	1.00	1.79	1.18
3	14.0	1.0	2.0	1.0	1.0	2.7	0.60	0.00	1.00	1.00	0.00	1.20	1.76	1.00	1.00	1.79
4	14.0	3.0	1.0	1.0	3.0	1.0	0.00	1.00	1.00	0.00	0.68	1.82	1.00	1.00	1.82	1.15
5	14.0	1.0	2.1	1.0	1.0	10.9	0.63	0.00	1.00	1.00	1.00	1.18	1.75	1.00	1.00	1.14

LOAD ID 7 : 0.6Dead+0.6Wind_Suction

REACTIONS:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----					
	Left Sup	Left Lap	Right Lap	Right Sup	Left Sup	Left Lap	Mid-Span Mom	Loc	Right Lap	Right Sup
1	-0.54			0.71	0.00		1.50	6.08		-1.70
1	-0.54		0.39	0.47	-1.70		0.34	7.53	-0.74	-1.16
2	-0.51	-0.44		0.49	-1.16	-0.69	0.67	7.15		-1.01
2	-0.44		0.49	0.56	-1.01		0.36	6.18	-1.31	-1.84
3	-0.72	-0.65		0.53	-1.84	-1.16	1.45	8.03		0.00

STRENGTH/DEFLECTION:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
1	RSup	0.71	6.04	0.12	MidS	1.50	2.33	0.65	RSup	0.52	0.32	
1	LSup	-0.54	6.04	0.09	LSup	-1.70	2.63	0.64	LSup	0.52	0.01	
2	RSup	0.49	3.86	0.13	RSup	-1.01	1.93	0.53	RSup	0.41	0.14	
2	RLap	0.49	3.86	0.13	RLap	-1.31	1.93	0.68	RLap	0.51	0.02	
3	LLap	-0.65	3.86	0.17	MidS	1.45	1.84	0.79	LLap	0.47	0.36	

UNBRACED LENGTH:

Bay Id	Major (ft)	-----Minor(ft)-----					-----Mom1/Mom2-----					-----Cb-----				
		LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
1	14.0	11.1	11.1	11.1	11.1	1.0	1.00	1.00	1.00	1.00	1.00	1.13	1.13	1.13	1.13	1.00
2	14.0	1.0	1.0	5.6	1.0	1.0	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.11	1.00	1.00
3	14.0	1.0	1.0	8.1	8.1	1.0	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.12	1.12	1.00
4	14.0	1.0	5.8	5.8	1.0	1.0	1.00	1.00	1.00	1.00	1.00	1.00	1.11	1.11	1.00	1.00
5	14.0	1.0	1.0	10.8	10.8	10.8	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.13	1.13	1.13

LOAD ID 8 : Dead+Collateral+MIN_SNOW

REACTIONS:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----					
	Left Sup	Left Lap	Right Lap	Right Sup	Left Sup	Left Lap	Mid-Span Mom	Loc	Right Lap	Right Sup
1	0.51			-0.78	0.00		-1.42	5.55		1.88
1	0.67		-0.53	-0.62	1.88		-0.55	7.25	0.97	1.55
2	0.66	0.57		-0.63	1.55	0.94	-0.80	7.14		1.37
2	0.60		-0.60	-0.69	1.37		-0.57	6.48	1.39	2.04
3	0.79	0.70		-0.50	2.04	1.29	-1.36	8.57		0.00

STRENGTH/DEFLECTION:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
1	RSup	-0.78	6.04	0.13	RSup	1.88	2.79	0.67	RSup	0.58	-0.30	
1	LSup	0.67	6.04	0.11	LSup	1.88	2.76	0.68	LSup	0.57	-0.06	
2	RSup	-0.63	3.86	0.16	RSup	1.37	2.05	0.67	RSup	0.55	-0.16	
2	RLap	-0.60	3.86	0.16	RLap	1.39	2.05	0.68	RLap	0.55	-0.07	
3	LLap	0.70	3.86	0.18	MidS	-1.36	1.93	0.71	LLap	0.52	-0.33	

UNBRACED LENGTH:

Bay Id	Major (ft)	-----Minor(ft)-----					-----Mom1/Mom2-----					-----Cb-----				
		LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
1	14.0	11.0	1.0	1.0	1.0	3.0	1.00	1.00	1.00	1.00	-0.03	1.13	1.00	1.00	1.00	1.83
2	14.0	4.1	4.1	1.0	2.4	1.0	-0.04	-0.04	1.00	-0.04	0.63	1.95	1.95	1.00	1.87	1.18
3	14.0	1.0	2.0	1.0	1.0	2.9	0.60	-0.03	1.00	1.00	-0.06	1.20	1.81	1.00	1.00	1.89
4	14.0	3.1	1.0	1.0	3.2	1.0	-0.04	1.00	1.00	-0.05	0.68	1.89	1.00	1.00	1.91	1.15
5	14.0	1.0	2.2	1.0	1.0	10.8	0.63	-0.03	1.00	1.00	1.00	1.18	1.79	1.00	1.00	1.13

LOAD ID 9 : Dead+Collateral+0.45Wind_Pressure+0.75MIN_SNOW

REACTIONS:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----					
	Left Sup	Left Lap	Right Lap	Right Sup	Left Sup	Left Lap	Mid-Span Mom	Loc	Right Lap	Right Sup
1	0.60			-0.92	0.00		-1.67	5.55		2.20
1	0.79		-0.62	-0.73	2.20		-0.65	7.25	1.14	1.82
2	0.77	0.67		-0.74	1.82	1.10	-0.94	7.14		1.61
2	0.70		-0.71	-0.82	1.61		-0.67	6.48	1.63	2.39
3	0.93	0.82		-0.59	2.39	1.52	-1.60	8.57		0.00

STRENGTH/DEFLECTION:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
1	RSup	-0.92	6.04	0.15	RSup	2.20	2.79	0.79	RSup	0.68	-0.35	
1	LSup	0.79	6.04	0.13	LSup	2.20	2.76	0.80	LSup	0.67	-0.07	
2	RSup	-0.74	3.86	0.19	RSup	1.61	2.05	0.78	RSup	0.64	-0.19	
2	RLap	-0.71	3.86	0.18	RLap	1.63	2.05	0.80	RLap	0.65	-0.08	
3	LLap	0.82	3.86	0.21	MidS	-1.60	1.93	0.83	LLap	0.61	-0.39	

UNBRACED LENGTH:

Bay Id	Major (ft)	-----Minor(ft)-----					-----Mom1/Mom2-----					-----Cb-----				
		LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
1	14.0	11.0	1.0	1.0	1.0	3.0	1.00	1.00	1.00	1.00	-0.03	1.13	1.00	1.00	1.00	1.83
2	14.0	4.1	4.1	1.0	2.4	1.0	-0.04	-0.04	1.00	-0.04	0.63	1.95	1.95	1.00	1.87	1.18

3	14.0	1.0	2.0	1.0	1.0	2.9	0.60-0.03	1.00	1.00-0.06	1.20	1.81	1.00	1.00	1.89
4	14.0	3.1	1.0	1.0	3.2	1.0	-0.04	1.00	1.00-0.05	0.68	1.89	1.00	1.00	1.91
5	14.0	1.0	2.2	1.0	1.0	10.8	0.63-0.03	1.00	1.00	1.00	1.18	1.79	1.00	1.00

LOAD ID 10 : Dead+Collateral+Snow/2+PAT_SL_3

REACTIONS:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----					
	Left Sup	Left Lap	Right Lap	Right Sup	Left Sup	Left Lap	Mid-Span Mom	Loc	Right Lap	Right Sup
1	0.44			-0.68	0.00		-1.19	5.47		1.70
1	0.61		-0.43	-0.51	1.70		-0.61	7.63	0.53	1.00
2	0.35	0.30		-0.29	1.00	0.68	-0.32	7.59		0.62
2	0.29		-0.31	-0.35	0.62		-0.31	6.36	0.70	1.03
3	0.40	0.35		-0.25	1.03	0.66	-0.67	8.60		0.00

STRENGTH/DEFLECTION:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
1	RSup	-0.68	6.04	0.11	RSup	1.70	2.79	0.61	RSup	0.52	-0.24	
1	LSup	0.61	6.04	0.10	LSup	1.70	2.77	0.61	LSup	0.52	-0.09	
2	LLap	0.30	3.86	0.08	LLap	0.68	2.05	0.33	LLap	0.27	-0.05	
2	RLap	-0.31	3.86	0.08	RLap	0.70	2.05	0.34	RLap	0.28	-0.04	
3	LLap	0.35	3.86	0.09	MidS	-0.67	1.93	0.35	LLap	0.27	-0.16	

UNBRACED LENGTH:

Bay Id	Major (ft)	-----Minor(ft)-----					-----Mom1/Mom2-----					-----Cb-----				
		LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
1	14.0	10.8	1.0	1.0	1.0	3.2	1.00	1.00	1.00	1.00-0.03		1.13	1.00	1.00	1.00	1.82
2	14.0	3.9	3.9	1.0	1.7	1.0	-0.03-0.03	1.00-0.13	0.53			1.90	1.90	1.00	1.96	1.24
3	14.0	1.0	2.8	1.0	1.0	2.7	0.67	0.00	1.00	1.00	0.00	1.15	1.81	1.00	1.00	1.80
4	14.0	2.7	1.0	1.0	3.0	1.0	0.00	1.00	1.00	0.00	0.68	1.80	1.00	1.00	1.81	1.15
5	14.0	1.0	2.2	1.0	1.0	10.8	0.64	0.00	1.00	1.00	1.00	1.17	1.75	1.00	1.00	1.14

LOAD ID 11 : Dead+Collateral+Snow/2+PAT_SL_4

REACTIONS:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----					
	Left Sup	Left Lap	Right Lap	Right Sup	Left Sup	Left Lap	Mid-Span Mom	Loc	Right Lap	Right Sup
1	0.24			-0.40	0.00		-0.62	5.20		1.16
1	0.53		-0.50	-0.58	1.16		-0.61	6.68	0.98	1.52
2	0.60	0.52		-0.51	1.52	0.96	-0.74	7.54		0.92
2	0.32		-0.28	-0.32	0.92		-0.19	6.96	0.65	0.95
3	0.39	0.34		-0.25	0.95	0.58	-0.70	8.48		0.00

STRENGTH/DEFLECTION:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
1	RSup	-0.40	6.04	0.07	RSup	1.16	2.77	0.42	RSup	0.35	-0.11	
1	LSup	0.53	6.04	0.09	LSup	1.16	2.80	0.41	LSup	0.36	-0.09	
2	LLap	0.52	3.86	0.13	LLap	0.96	2.07	0.46	LLap	0.39	-0.15	
2	LSup	0.32	3.86	0.08	LSup	0.92	2.02	0.46	LSup	0.36	0.00	
3	LLap	0.34	3.86	0.09	MidS	-0.70	1.93	0.36	LLap	0.24	-0.18	

UNBRACED LENGTH:

Bay Id	Major (ft)	-----Minor(ft)-----					-----Mom1/Mom2-----					-----Cb-----				
		LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup

1	14.0	10.4	1.0	1.0	3.6	3.6	1.00	1.00	1.00	0.00	0.00	1.14	1.00	1.00	1.80	1.80
2	14.0	3.0	1.0	1.0	2.5	1.0	-0.06	1.00	1.00	-0.04	0.64	1.90	1.00	1.00	1.85	1.17
3	14.0	1.0	2.3	1.0	1.0	2.2	0.63	-0.03	1.00	1.00	-0.02	1.18	1.82	1.00	1.00	1.80
4	14.0	4.1	4.1	1.0	3.2	1.0	0.00	0.00	1.00	0.00	0.68	1.89	1.89	1.00	1.85	1.15
5	14.0	1.0	2.0	1.0	1.0	11.0	0.61	0.00	1.00	1.00	1.00	1.19	1.74	1.00	1.00	1.14

LOAD ID 12 : Dead+Collateral+Snow/2+PAT_SL_5

REACTIONS:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----					
	Left Sup	Left Lap	Right Lap	Right Sup	Left Sup	Left Lap	Mid-Span Mom	Mid-Span Loc	Right Lap	Right Sup
1	0.26			-0.38	0.00		-0.74	5.66		0.86
1	0.31		-0.29	-0.34	0.86		-0.17	6.68	0.75	1.06
2	0.54	0.46		-0.58	1.06	0.57	-0.74	6.73		1.37
2	0.56		-0.47	-0.55	1.37		-0.63	7.09	0.76	1.27
3	0.41	0.37		-0.23	1.27	0.88	-0.58	8.97		0.00

STRENGTH/DEFLECTION:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
1	RSup	-0.38	6.04	0.06	RSup	0.86	2.80	0.31	RSup	0.27	-0.16	
1	LSup	0.31	6.04	0.05	LSup	0.86	2.76	0.31	LSup	0.26	0.01	
2	RSup	-0.58	3.86	0.15	RSup	1.37	2.05	0.67	RSup	0.54	-0.15	
2	LSup	0.56	3.86	0.15	LSup	1.37	2.04	0.67	LSup	0.54	-0.12	
3	LLap	0.37	3.86	0.09	LLap	0.88	2.05	0.43	LLap	0.35	-0.12	

UNBRACED LENGTH:

Bay Id	Major (ft)	-----Minor(ft)-----					-----Mom1/Mom2-----					-----Cb-----				
		LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
1	14.0	11.3	1.0	1.0	1.0	2.7	1.00	1.00	1.00	1.00	0.00	1.14	1.00	1.00	1.00	1.76
2	14.0	4.0	4.0	1.0	3.6	1.0	0.00	0.00	1.00	0.00	0.71	1.90	1.90	1.00	1.88	1.14
3	14.0	1.0	1.7	1.0	1.0	3.1	0.53	-0.13	1.00	1.00	-0.03	1.24	1.94	1.00	1.00	1.86
4	14.0	3.2	1.0	1.0	2.0	1.0	-0.03	1.00	1.00	-0.03	0.60	1.86	1.00	1.00	1.82	1.20
5	14.0	1.0	2.9	1.0	1.0	10.1	0.69	0.00	1.00	1.00	1.00	1.14	1.78	1.00	1.00	1.14

LOAD ID 13 : Dead+Collateral+Snow/2+PAT_SL_6

REACTIONS:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----					
	Left Sup	Left Lap	Right Lap	Right Sup	Left Sup	Left Lap	Mid-Span Mom	Mid-Span Loc	Right Lap	Right Sup
1	0.25			-0.39	0.00		-0.70	5.52		0.95
1	0.34		-0.26	-0.30	0.95		-0.30	7.39	0.42	0.70
2	0.31	0.26		-0.34	0.70	0.42	-0.32	6.68		0.91
2	0.49		-0.54	-0.62	0.91		-0.61	6.18	1.24	1.83
3	0.69	0.61		-0.43	1.83	1.18	-1.14	8.64		0.00

STRENGTH/DEFLECTION:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
1	RSup	-0.39	6.04	0.06	RSup	0.95	2.79	0.34	RSup	0.29	-0.15	
1	LSup	0.34	6.04	0.06	LSup	0.95	2.77	0.34	LSup	0.29	-0.04	
2	RSup	-0.34	3.86	0.09	RSup	0.91	2.03	0.45	RSup	0.36	-0.05	
2	RLap	-0.54	3.86	0.14	RLap	1.24	2.05	0.61	RLap	0.49	-0.10	
3	LLap	0.61	3.86	0.16	MidS	-1.14	1.93	0.59	LLap	0.47	-0.27	

UNBRACED LENGTH:

Bay	Major	-----Minor(ft)-----					-----Mom1/Mom2-----					-----Cb-----				
Id	(ft)	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
1	14.0	11.0	1.0	1.0	1.0	3.0	1.00	1.00	1.00	1.00	0.00	1.14	1.00	1.00	1.00	1.77
2	14.0	3.8	3.8	1.0	2.0	1.0	0.00	0.00	1.00	0.00	0.60	1.84	1.84	1.00	1.77	1.20
3	14.0	1.0	1.9	1.0	7.5	3.6	0.60	0.00	1.00	1.00	0.00	1.20	1.77	1.00	1.14	1.83
4	14.0	2.6	1.0	1.0	3.1	1.0	-0.10	1.00	1.00	-0.04	0.68	1.97	1.00	1.00	1.88	1.15
5	14.0	1.0	2.4	1.0	1.0	10.6	0.65	-0.03	1.00	1.00	1.00	1.17	1.80	1.00	1.00	1.13

LOAD ID 14 : Dead+Collateral+Snow/2+PAT_SL_1

REACTIONS:

Bay	-----Shear(k)-----				-----Moment(f-k)-----					
Id	Left	Left	Right	Right	Left	Left	Mid-Span		Right	Right
	Sup	Lap	Lap	Sup	Sup	Lap	Mom	Loc	Lap	Sup
1	0.46			-0.65	0.00		-1.32	5.77		1.37
1	0.37		-0.22	-0.27	1.37		-0.14	8.12	0.41	0.66
2	0.32	0.27		-0.33	0.66	0.36	-0.44	6.91		0.71
2	0.30		-0.30	-0.34	0.71		-0.27	6.55	0.69	1.01
3	0.39	0.35		-0.25	1.01	0.63	-0.68	8.56		0.00

STRENGTH/DEFLECTION:

Bay	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
Id	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
1	RSup	-0.65	6.04	0.11	MidS	-1.32	2.63	0.50	RSup	0.43	-0.30	
1	LSup	0.37	6.04	0.06	LSup	1.37	2.73	0.50	LSup	0.42	0.02	
2	RSup	-0.33	3.86	0.08	RSup	0.71	2.06	0.35	RSup	0.28	-0.10	
2	LSup	0.30	3.86	0.08	LSup	0.71	2.04	0.35	LSup	0.28	-0.03	
3	LLap	0.35	3.86	0.09	MidS	-0.68	1.93	0.35	LLap	0.26	-0.16	

UNBRACED LENGTH:

Bay	Major	-----Minor(ft)-----					-----Mom1/Mom2-----					-----Cb-----				
Id	(ft)	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
1	14.0	11.3	1.0	1.0	1.0	2.7	1.00	1.00	1.00	1.00	-0.06	1.13	1.00	1.00	1.00	1.85
2	14.0	5.6	5.6	1.0	2.4	1.0	0.00	0.00	1.00	0.00	0.62	1.96	1.96	1.00	1.84	1.19
3	14.0	1.0	1.5	1.0	1.0	2.7	0.55	0.00	1.00	1.00	0.00	1.23	1.74	1.00	1.00	1.79
4	14.0	3.1	1.0	1.0	3.0	1.0	0.00	1.00	1.00	0.00	0.68	1.83	1.00	1.00	1.82	1.15
5	14.0	1.0	2.1	1.0	1.0	10.9	0.63	0.00	1.00	1.00	1.00	1.18	1.75	1.00	1.00	1.14

LOAD ID 15 : Dead+Collateral+Snow/2+PAT_SL_2

REACTIONS:

Bay	-----Shear(k)-----				-----Moment(f-k)-----					
Id	Left	Left	Right	Right	Left	Left	Mid-Span		Right	Right
	Sup	Lap	Lap	Sup	Sup	Lap	Mom	Loc	Lap	Sup
1	0.26			-0.39	0.00		-0.71	5.56		0.92
1	0.33		-0.27	-0.31	0.92		-0.26	7.18	0.52	0.81
2	0.34	0.29		-0.30	0.81	0.49	-0.45	7.40		0.56
2	0.26		-0.34	-0.39	0.56		-0.15	5.56	1.12	1.48
3	0.66	0.58		-0.45	1.48	0.86	-1.28	8.33		0.00

STRENGTH/DEFLECTION:

Bay	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
Id	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
1	RSup	-0.39	6.04	0.06	RSup	0.92	2.79	0.33	RSup	0.28	-0.15	
1	LSup	0.33	6.04	0.05	LSup	0.92	2.76	0.33	LSup	0.28	-0.02	
2	RSup	-0.30	3.86	0.08	RSup	0.56	2.07	0.27	RSup	0.23	-0.10	

1	RSup	-0.67	6.04	0.11	RSup	1.62	2.79	0.58	RSup	0.50	-0.26
1	LSup	0.58	6.04	0.10	LSup	1.62	2.77	0.59	LSup	0.50	-0.05
2	RSup	-0.56	3.86	0.14	RSup	1.31	2.05	0.64	RSup	0.52	-0.12
2	LSup	0.56	3.86	0.14	LSup	1.31	2.05	0.64	LSup	0.52	-0.12
3	LLap	0.37	3.86	0.10	LLap	0.89	2.05	0.44	LLap	0.35	-0.11

UNBRACED LENGTH:

Bay	Major	-----Minor(ft)-----					-----Mom1/Mom2-----					-----Cb-----				
Id	(ft)	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
1	14.0	11.1	1.0	1.0	1.0	2.9	1.00	1.00	1.00	1.00	0.00	1.14	1.00	1.00	1.00	1.77
2	14.0	3.8	3.8	1.0	2.2	1.0	0.00	0.00	1.00	0.00	0.62	1.85	1.85	1.00	1.79	1.19
3	14.0	1.0	2.0	1.0	1.0	3.0	0.60	0.00	1.00	1.00	0.00	1.20	1.76	1.00	1.00	1.80
4	14.0	3.0	1.0	1.0	1.9	1.0	0.00	1.00	1.00	0.00	0.60	1.80	1.00	1.00	1.76	1.20
5	14.0	1.0	3.1	1.0	1.0	9.9	0.70	-0.04	1.00	1.00	1.00	1.14	1.84	1.00	1.00	1.13

LOAD ID 18 : Dead+Collateral+UNB_SL

REACTIONS:

Bay	-----Shear(k)-----				-----Moment(f-k)-----					
Id	Left Sup	Left Lap	Right Lap	Right Sup	Left Sup	Left Lap	Mid-Span Mom	Loc	Right Lap	Right Sup
1	0.59			-0.90	0.00		-1.64	5.55		2.16
1	0.77		-0.61	-0.72	2.16		-0.64	7.25	1.12	1.79
2	0.76	0.65		-0.73	1.79	1.08	-0.93	7.14		1.58
2	0.69		-0.69	-0.80	1.58		-0.66	6.48	1.60	2.35
3	0.91	0.81		-0.58	2.35	1.49	-1.57	8.57		0.00

STRENGTH/DEFLECTION:

Bay	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
Id	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
1	RSup	-0.90	6.04	0.15	RSup	2.16	2.79	0.78	RSup	0.67	-0.34	
1	LSup	0.77	6.04	0.13	LSup	2.16	2.76	0.78	LSup	0.66	-0.06	
2	RSup	-0.73	3.86	0.19	RSup	1.58	2.05	0.77	RSup	0.63	-0.19	
2	RLap	-0.69	3.86	0.18	RLap	1.60	2.05	0.78	RLap	0.63	-0.08	
3	LLap	0.81	3.86	0.21	MidS	-1.57	1.93	0.81	LLap	0.60	-0.38	

UNBRACED LENGTH:

Bay	Major	-----Minor(ft)-----					-----Mom1/Mom2-----					-----Cb-----				
Id	(ft)	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
1	14.0	11.0	1.0	1.0	1.0	3.0	1.00	1.00	1.00	1.00	-0.03	1.13	1.00	1.00	1.00	1.83
2	14.0	4.1	4.1	1.0	2.4	1.0	-0.04	-0.04	1.00	-0.04	0.63	1.95	1.95	1.00	1.87	1.18
3	14.0	1.0	2.0	1.0	1.0	2.9	0.60	-0.03	1.00	1.00	-0.06	1.20	1.81	1.00	1.00	1.89
4	14.0	3.1	1.0	1.0	3.2	1.0	-0.04	1.00	1.00	-0.05	0.68	1.89	1.00	1.00	1.91	1.15
5	14.0	1.0	2.2	1.0	1.0	10.8	0.63	-0.03	1.00	1.00	1.00	1.18	1.79	1.00	1.00	1.13

DEFLECTION:

LOAD ID 19 : Dead+Collateral+Live

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
1	-0.36	1.87	0.19
1	-0.07	1.87	0.04
2	-0.20	1.87	0.11
2	-0.09	1.87	0.05
3	-0.40	0.93	0.43

LOAD ID 20 : Dead+Collateral+Snow

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.26	1.87	0.14
1	-0.05	1.87	0.03
2	-0.14	1.87	0.07
2	-0.06	1.87	0.03
3	-0.28	0.93	0.30

LOAD ID 21 : Dead+Collateral+Snow+Snow_Drift

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.26	1.87	0.14
1	-0.05	1.87	0.03
2	-0.14	1.87	0.07
2	-0.06	1.87	0.03
3	-0.28	0.93	0.30

LOAD ID 22 : Dead+Collateral+0.75Live+0.41Wind_Pressure

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.39	2.24	0.17
1	-0.07	2.24	0.03
2	-0.21	2.24	0.09
2	-0.09	2.24	0.04
3	-0.43	1.12	0.38

LOAD ID 23 : Dead+Collateral+0.75Snow+0.41Wind_Pressure

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.31	2.24	0.14
1	-0.06	2.24	0.03
2	-0.17	2.24	0.07
2	-0.07	2.24	0.03
3	-0.34	1.12	0.30

LOAD ID 24 : Dead+Collateral+0.75Snow+0.41Wind_Pressure+0.75Snow_Drift

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.31	2.24	0.14
1	-0.06	2.24	0.03
2	-0.17	2.24	0.07
2	-0.07	2.24	0.03
3	-0.34	1.12	0.30

LOAD ID 25 : 0.6Dead+0.54Wind_Suction

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	0.29	2.24	0.13
1	0.01	2.24	0.00
2	0.13	2.24	0.06
2	0.02	2.24	0.01
3	0.32	1.12	0.29

LOAD ID 26 : Dead+Collateral+MIN_SNOW

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.30	1.87	0.16
1	-0.06	1.87	0.03
2	-0.16	1.87	0.09
2	-0.07	1.87	0.04
3	-0.33	0.93	0.35

LOAD ID 27 : Dead+Collateral+0.41Wind_Pressure+0.75MIN_SNOW

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.34	2.24	0.15
1	-0.06	2.24	0.03
2	-0.18	2.24	0.08
2	-0.08	2.24	0.04
3	-0.37	1.12	0.33

LOAD ID 28 : Dead+Collateral+Snow/2+PAT_SL_3

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.24	1.87	0.13
1	-0.09	1.87	0.05
2	-0.05	1.87	0.03
2	-0.04	1.87	0.02
3	-0.16	0.93	0.17

LOAD ID 29 : Dead+Collateral+Snow/2+PAT_SL_4

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.11	1.87	0.06
1	-0.09	1.87	0.05
2	-0.15	1.87	0.08
2	0.00	1.87	0.00
3	-0.18	0.93	0.19

LOAD ID 30 : Dead+Collateral+Snow/2+PAT_SL_5

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.16	1.87	0.09
1	0.01	1.87	0.00
2	-0.15	1.87	0.08
2	-0.12	1.87	0.06
3	-0.12	0.93	0.12

LOAD ID 31 : Dead+Collateral+Snow/2+PAT_SL_6

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.15	1.87	0.08
1	-0.04	1.87	0.02
2	-0.05	1.87	0.03
2	-0.10	1.87	0.05
3	-0.27	0.93	0.29

LOAD ID 32 : Dead+Collateral+Snow/2+PAT_SL_1			

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.30	1.87	0.16
1	0.02	1.87	0.01
2	-0.10	1.87	0.05
2	-0.03	1.87	0.02
3	-0.16	0.93	0.18

LOAD ID 33 : Dead+Collateral+Snow/2+PAT_SL_2			

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.15	1.87	0.08
1	-0.02	1.87	0.01
2	-0.10	1.87	0.05
2	0.03	1.87	0.02
3	-0.33	0.93	0.36

LOAD ID 34 : Dead+Collateral+Snow-PAT_SL_1			

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.11	1.87	0.06
1	-0.10	1.87	0.05
2	-0.12	1.87	0.07
2	-0.07	1.87	0.03
3	-0.28	0.93	0.30

LOAD ID 35 : Dead+Collateral+Snow-PAT_SL_2			

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.26	1.87	0.14
1	-0.05	1.87	0.03
2	-0.12	1.87	0.07
2	-0.12	1.87	0.07
3	-0.11	0.93	0.12

LOAD ID 36 : Dead+Collateral+UNB_SL			

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.34	1.87	0.18
1	-0.06	1.87	0.03
2	-0.19	1.87	0.10
2	-0.08	1.87	0.04
3	-0.38	0.93	0.41

SURFACE LAYOUT:

Surface Id	Length	No. Row
3	35.030	7

PURLIN LOCATION:

Purlin Id	Surf Offset	Space	Load Width	Dead Load	Show Report	-----Max_Load----- Id UC Report
2	5.004	5.004	5.004	0.53		4 0.94 Moment
3	10.009	5.004	5.004	0.53		4 0.94 Moment
4	15.013	5.004	5.004	0.53	Y	4 0.94 Moment
5	20.017	5.004	5.004	0.53		4 0.94 Moment
6	25.022	5.004	5.004	0.53		4 0.94 Moment
7	30.026	5.004	5.004	0.53		4 0.94 Moment
	35.030	5.004				

Average= 0.62

LAYOUT:

Bay Id	Part	Bay Width	---Lap(ft)--- Left Right	No. Brace	Unit Weight	Total Weight
1	6X25Z14	28.00		1.00 0	81.2	568.4
2	6X25Z16	28.00	1.00 1.00	0	70.2	491.4
3	6X25Z16	14.00	1.00	0	35.1	245.7
Total (lb)=					186.5	1305.5

LOAD COMBINATIONS:

4 - Dead+Collateral+0.75Live+0.45Wind_Pressure

ROOF PURLIN
Surface Id = 3
Purlin Id = 4
Offset = 15.01

PURLIN LAYOUT:

Bay Id	Part	Design Length (ft)	---Lap(ft)---		Load Width	No. Brace	Unit Weight	Available Reduction	
			Left	Right				Out	In
1	6X25Z14	14.00			5.00	0	39.2	0.00	0.70
1	6X25Z14	14.00		1.00	5.00	0	42.0	0.00	0.70
2	6X25Z16	14.00	1.00		5.00	0	35.1	0.00	0.70
2	6X25Z16	14.00		1.00	5.00	0	35.1	0.00	0.70
3	6X25Z16	14.00	1.00		5.00	0	35.1	0.00	0.70

LOAD ID 1 : Dead+Collateral+Live

REACTIONS:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----					
	Left Sup	Left Lap	Right Lap	Right Sup	Left Sup	Left Lap	Mid-Span Mom	Span Loc	Right Lap	Right Sup
1	0.62			-0.95	0.00		-1.73	5.55		2.28
1	0.82		-0.65	-0.76	2.28		-0.67	7.25	1.18	1.89
2	0.80	0.69		-0.77	1.89	1.14	-0.98	7.14		1.67
2	0.73		-0.73	-0.84	1.67		-0.70	6.48	1.69	2.48
3	0.96	0.85		-0.61	2.48	1.57	-1.65	8.57		0.00

STRENGTH/DEFLECTION:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
1	RSup	-0.95	6.04	0.16	RSup	2.28	2.79	0.82	RSup	0.70	-0.36	
1	LSup	0.82	6.04	0.13	LSup	2.28	2.77	0.83	LSup	0.70	-0.07	
2	RSup	-0.77	3.86	0.20	RSup	1.67	2.06	0.81	RSup	0.66	-0.20	
2	RLap	-0.73	3.86	0.19	RLap	1.69	2.05	0.83	RLap	0.67	-0.09	
3	LLap	0.85	3.86	0.22	MidS	-1.65	1.93	0.86	LLap	0.64	-0.40	

UNBRACED LENGTH:

Bay Id	Major (ft)	-----Minor(ft)-----					-----Mom1/Mom2-----					-----Cb-----				
		LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
1	14.0	11.1	1.0	1.0	1.0	2.9	1.00	1.00	1.00	1.00	0.00	1.14	1.00	1.00	1.00	1.77
2	14.0	3.8	3.8	1.0	2.3	1.0	0.00	0.00	1.00	0.00	0.63	1.85	1.85	1.00	1.79	1.18
3	14.0	1.0	2.0	1.0	1.0	2.7	0.60	0.00	1.00	1.00	0.00	1.20	1.76	1.00	1.00	1.79
4	14.0	3.0	1.0	1.0	3.0	1.0	0.00	1.00	1.00	0.00	0.68	1.82	1.00	1.00	1.82	1.15
5	14.0	1.0	2.1	1.0	1.0	10.9	0.63	0.00	1.00	1.00	1.00	1.18	1.75	1.00	1.00	1.14

LOAD ID 2 : Dead+Collateral+Snow

REACTIONS:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----					
	Left Sup	Left Lap	Right Lap	Right Sup	Left Sup	Left Lap	Mid-Span Mom	Span Loc	Right Lap	Right Sup

1	0.44			-0.67	0.00		-1.22	5.55		1.61
1	0.58		-0.46	-0.54	1.61		-0.48	7.25	0.84	1.33
2	0.57	0.49		-0.55	1.33	0.81	-0.69	7.14		1.18
2	0.52		-0.52	-0.60	1.18		-0.49	6.48	1.19	1.75
3	0.68	0.60		-0.43	1.75	1.11	-1.17	8.57		0.00

STRENGTH/DEFLECTION:

Bay	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
Id	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
1	RSup	-0.67	6.04	0.11	RSup	1.61	2.79	0.58	RSup	0.50	-0.26	
1	LSup	0.58	6.04	0.10	LSup	1.61	2.77	0.58	LSup	0.49	-0.05	
2	RSup	-0.55	3.86	0.14	RSup	1.18	2.06	0.57	RSup	0.47	-0.14	
2	RLap	-0.52	3.86	0.13	RLap	1.19	2.05	0.58	RLap	0.47	-0.06	
3	LLap	0.60	3.86	0.16	MidS	-1.17	1.93	0.61	LLap	0.45	-0.28	

UNBRACED LENGTH:

Bay	Major	-----Minor(ft)-----					-----Mom1/Mom2-----					-----Cb-----				
Id	(ft)	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
1	14.0	11.1	1.0	1.0	1.0	2.9	1.00	1.00	1.00	1.00	0.00	1.14	1.00	1.00	1.00	1.77
2	14.0	3.8	3.8	1.0	2.3	1.0	0.00	0.00	1.00	0.00	0.63	1.85	1.85	1.00	1.79	1.18
3	14.0	1.0	2.0	1.0	1.0	2.7	0.60	0.00	1.00	1.00	0.00	1.20	1.76	1.00	1.00	1.79
4	14.0	3.0	1.0	1.0	3.0	1.0	0.00	1.00	1.00	0.00	0.68	1.82	1.00	1.00	1.82	1.15
5	14.0	1.0	2.1	1.0	1.0	10.9	0.63	0.00	1.00	1.00	1.00	1.18	1.75	1.00	1.00	1.14

LOAD ID 3 : Dead+Collateral+Snow+Snow_Drift

REACTIONS:

Bay	-----Shear(k)-----				-----Moment(f-k)-----					
Id	Left Sup	Left Lap	Right Lap	Right Sup	Left Sup	Left Lap	Mid-Span Mom	Right Loc	Right Lap	Right Sup
1	0.44			-0.67	0.00		-1.22	5.55		1.61
1	0.58		-0.46	-0.54	1.61		-0.48	7.25	0.84	1.33
2	0.57	0.49		-0.55	1.33	0.81	-0.69	7.14		1.18
2	0.52		-0.52	-0.60	1.18		-0.49	6.48	1.19	1.75
3	0.68	0.60		-0.43	1.75	1.11	-1.17	8.57		0.00

STRENGTH/DEFLECTION:

Bay	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
Id	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
1	RSup	-0.67	6.04	0.11	RSup	1.61	2.79	0.58	RSup	0.50	-0.26	
1	LSup	0.58	6.04	0.10	LSup	1.61	2.77	0.58	LSup	0.49	-0.05	
2	RSup	-0.55	3.86	0.14	RSup	1.18	2.06	0.57	RSup	0.47	-0.14	
2	RLap	-0.52	3.86	0.13	RLap	1.19	2.05	0.58	RLap	0.47	-0.06	
3	LLap	0.60	3.86	0.16	MidS	-1.17	1.93	0.61	LLap	0.45	-0.28	

UNBRACED LENGTH:

Bay	Major	-----Minor(ft)-----					-----Mom1/Mom2-----					-----Cb-----				
Id	(ft)	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
1	14.0	11.1	1.0	1.0	1.0	2.9	1.00	1.00	1.00	1.00	0.00	1.14	1.00	1.00	1.00	1.77
2	14.0	3.8	3.8	1.0	2.3	1.0	0.00	0.00	1.00	0.00	0.63	1.85	1.85	1.00	1.79	1.18
3	14.0	1.0	2.0	1.0	1.0	2.7	0.60	0.00	1.00	1.00	0.00	1.20	1.76	1.00	1.00	1.79
4	14.0	3.0	1.0	1.0	3.0	1.0	0.00	1.00	1.00	0.00	0.68	1.82	1.00	1.00	1.82	1.15
5	14.0	1.0	2.1	1.0	1.0	10.9	0.63	0.00	1.00	1.00	1.00	1.18	1.75	1.00	1.00	1.14

LOAD ID 4 : Dead+Collateral+0.75Live+0.45Wind_Pressure

REACTIONS:

Bay	-----Shear(k)-----				-----Moment(f-k)-----					
-----	---------------------	--	--	--	------------------------	--	--	--	--	--

Bay Id	Left Sup	Left Lap	Right Lap	Right Sup	Left Sup	Left Lap	Mid-Span Mom	Loc	Right Lap	Right Sup
---	---	---	---	---	---	---	---	---	---	---
1	0.69			-1.04	0.00		-1.90	5.55		2.51
1	0.90		-0.71	-0.83	2.51		-0.74	7.25	1.30	2.07
2	0.88	0.76		-0.85	2.07	1.25	-1.07	7.14		1.83
2	0.80		-0.80	-0.93	1.83		-0.76	6.48	1.86	2.72
3	1.06	0.94		-0.67	2.72	1.73	-1.82	8.57		0.00

STRENGTH/DEFLECTION:

Bay	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
Id	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
---	---	---	---	---	---	---	---	---	---	---	---	---
1	RSup	-1.04	6.04	0.17	RSup	2.51	2.79	0.90	RSup	0.77	-0.40	
1	LSup	0.90	6.04	0.15	LSup	2.51	2.77	0.91	LSup	0.77	-0.07	
2	RSup	-0.85	3.86	0.22	RSup	1.83	2.06	0.89	RSup	0.73	-0.22	
2	RLap	-0.80	3.86	0.21	RLap	1.86	2.05	0.91	RLap	0.74	-0.09	
3	LLap	0.94	3.86	0.24	MidS	-1.82	1.93	0.94	LLap	0.70	-0.44	

UNBRACED LENGTH:

Bay Id	Major (ft)	Minor(ft)					Mom1/Mom2					Cb				
---	---	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
1	14.0	11.1	1.0	1.0	1.0	2.9	1.00	1.00	1.00	1.00	0.00	1.14	1.00	1.00	1.00	1.77
2	14.0	3.8	3.8	1.0	2.3	1.0	0.00	0.00	1.00	0.00	0.63	1.85	1.85	1.00	1.79	1.18
3	14.0	1.0	2.0	1.0	1.0	2.7	0.60	0.00	1.00	1.00	0.00	1.20	1.76	1.00	1.00	1.79
4	14.0	3.0	1.0	1.0	3.0	1.0	0.00	1.00	1.00	0.00	0.68	1.82	1.00	1.00	1.82	1.15
5	14.0	1.0	2.1	1.0	1.0	10.9	0.63	0.00	1.00	1.00	1.00	1.18	1.75	1.00	1.00	1.14

LOAD ID 5 : Dead+Collateral+0.75Snow+0.45Wind_Pressure

REACTIONS:

Bay Id	Left Sup	Left Lap	Right Lap	Right Sup	Left Sup	Left Lap	Mid-Span Mom	Loc	Right Lap	Right Sup
---	---	---	---	---	---	---	---	---	---	---
1	0.55			-0.83	0.00		-1.52	5.55		2.01
1	0.72		-0.57	-0.67	2.01		-0.59	7.25	1.04	1.66
2	0.70	0.61		-0.68	1.66	1.00	-0.86	7.14		1.46
2	0.64		-0.64	-0.74	1.46		-0.61	6.48	1.48	2.18
3	0.85	0.75		-0.54	2.18	1.38	-1.45	8.57		0.00

STRENGTH/DEFLECTION:

Bay	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
Id	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
---	---	---	---	---	---	---	---	---	---	---	---	---
1	RSup	-0.83	6.04	0.14	RSup	2.01	2.79	0.72	RSup	0.62	-0.32	
1	LSup	0.72	6.04	0.12	LSup	2.01	2.77	0.73	LSup	0.61	-0.06	
2	RSup	-0.68	3.86	0.18	RSup	1.46	2.06	0.71	RSup	0.58	-0.17	
2	RLap	-0.64	3.86	0.17	RLap	1.48	2.05	0.73	RLap	0.59	-0.08	
3	LLap	0.75	3.86	0.19	MidS	-1.45	1.93	0.75	LLap	0.56	-0.35	

UNBRACED LENGTH:

Bay Id	Major (ft)	Minor(ft)					Mom1/Mom2					Cb				
---	---	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
1	14.0	11.1	1.0	1.0	1.0	2.9	1.00	1.00	1.00	1.00	0.00	1.14	1.00	1.00	1.00	1.77
2	14.0	3.8	3.8	1.0	2.3	1.0	0.00	0.00	1.00	0.00	0.63	1.85	1.85	1.00	1.79	1.18
3	14.0	1.0	2.0	1.0	1.0	2.7	0.60	0.00	1.00	1.00	0.00	1.20	1.76	1.00	1.00	1.79
4	14.0	3.0	1.0	1.0	3.0	1.0	0.00	1.00	1.00	0.00	0.68	1.82	1.00	1.00	1.82	1.15
5	14.0	1.0	2.1	1.0	1.0	10.9	0.63	0.00	1.00	1.00	1.00	1.18	1.75	1.00	1.00	1.14

LOAD ID 6 : Dead+Collateral+0.75Snow+0.45Wind_Pressure+0.75Snow_Drift

REACTIONS:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----					
	Left Sup	Left Lap	Right Lap	Right Sup	Left Sup	Left Lap	Mid-Span Mom	Loc	Right Lap	Right Sup
1	0.55			-0.83	0.00		-1.52	5.55		2.01
1	0.72		-0.57	-0.67	2.01		-0.59	7.25	1.04	1.66
2	0.70	0.61		-0.68	1.66	1.00	-0.86	7.14		1.46
2	0.64		-0.64	-0.74	1.46		-0.61	6.48	1.48	2.18
3	0.85	0.75		-0.54	2.18	1.38	-1.45	8.57		0.00

STRENGTH/DEFLECTION:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
1	RSup	-0.83	6.04	0.14	RSup	2.01	2.79	0.72	RSup	0.62	-0.32	
1	LSup	0.72	6.04	0.12	LSup	2.01	2.77	0.73	LSup	0.61	-0.06	
2	RSup	-0.68	3.86	0.18	RSup	1.46	2.06	0.71	RSup	0.58	-0.17	
2	RLap	-0.64	3.86	0.17	RLap	1.48	2.05	0.73	RLap	0.59	-0.08	
3	LLap	0.75	3.86	0.19	MidS	-1.45	1.93	0.75	LLap	0.56	-0.35	

UNBRACED LENGTH:

Bay Id	Major (ft)	-----Minor(ft)-----					-----Mom1/Mom2-----					-----Cb-----				
		LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
1	14.0	11.1	1.0	1.0	1.0	2.9	1.00	1.00	1.00	1.00	0.00	1.14	1.00	1.00	1.00	1.77
2	14.0	3.8	3.8	1.0	2.3	1.0	0.00	0.00	1.00	0.00	0.63	1.85	1.85	1.00	1.79	1.18
3	14.0	1.0	2.0	1.0	1.0	2.7	0.60	0.00	1.00	1.00	0.00	1.20	1.76	1.00	1.00	1.79
4	14.0	3.0	1.0	1.0	3.0	1.0	0.00	1.00	1.00	0.00	0.68	1.82	1.00	1.00	1.82	1.15
5	14.0	1.0	2.1	1.0	1.0	10.9	0.63	0.00	1.00	1.00	1.00	1.18	1.75	1.00	1.00	1.14

LOAD ID 7 : 0.6Dead+0.6Wind_Suction

REACTIONS:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----					
	Left Sup	Left Lap	Right Lap	Right Sup	Left Sup	Left Lap	Mid-Span Mom	Loc	Right Lap	Right Sup
1	-0.55			0.70	0.00		1.53	6.13		-1.64
1	-0.51		0.29	0.35	-1.64		0.21	8.34	-0.55	-0.87
2	-0.39	-0.34		0.38	-0.87	-0.50	0.54	7.16		-0.74
2	-0.33		0.46	0.53	-0.74		0.22	5.36	-1.28	-1.77
3	-0.71	-0.64		0.54	-1.77	-1.09	1.48	7.97		0.00

STRENGTH/DEFLECTION:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
1	RSup	0.70	6.04	0.12	MidS	1.53	2.33	0.66	RSup	0.51	0.33	
1	LSup	-0.51	6.04	0.08	LSup	-1.64	2.63	0.62	LSup	0.50	-0.01	
2	RSup	0.38	3.86	0.10	RSup	-0.74	1.93	0.39	RSup	0.30	0.12	
2	RLap	0.46	3.86	0.12	RLap	-1.28	1.93	0.66	RLap	0.50	-0.01	
3	LLap	-0.64	3.86	0.17	MidS	1.48	1.84	0.80	LLap	0.45	0.37	

UNBRACED LENGTH:

Bay Id	Major (ft)	-----Minor(ft)-----					-----Mom1/Mom2-----					-----Cb-----				
		LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
1	14.0	11.2	11.2	11.2	11.2	1.0	1.00	1.00	1.00	1.00	1.00	1.13	1.13	1.13	1.13	1.00
2	14.0	1.0	1.0	4.9	1.0	1.0	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.10	1.00	1.00
3	14.0	1.0	1.0	8.4	8.4	1.0	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.12	1.12	1.00
4	14.0	1.0	5.2	5.2	1.0	1.0	1.00	1.00	1.00	1.00	1.00	1.00	1.11	1.11	1.00	1.00
5	14.0	1.0	1.0	10.9	10.9	10.9	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.13	1.13	1.13

LOAD ID 8 : Dead+Collateral+MIN_SNOW

REACTIONS:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----					
	Left Sup	Left Lap	Right Lap	Right Sup	Left Sup	Left Lap	Mid-Span Mom	Loc	Right Lap	Right Sup
1	0.51			-0.78	0.00		-1.42	5.55		1.88
1	0.67		-0.53	-0.62	1.88		-0.55	7.25	0.97	1.55
2	0.66	0.57		-0.63	1.55	0.94	-0.80	7.14		1.37
2	0.60		-0.60	-0.69	1.37		-0.57	6.48	1.39	2.04
3	0.79	0.70		-0.50	2.04	1.29	-1.36	8.57		0.00

STRENGTH/DEFLECTION:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
1	RSup	-0.78	6.04	0.13	RSup	1.88	2.79	0.67	RSup	0.58	-0.30	
1	LSup	0.67	6.04	0.11	LSup	1.88	2.76	0.68	LSup	0.57	-0.06	
2	RSup	-0.63	3.86	0.16	RSup	1.37	2.05	0.67	RSup	0.55	-0.16	
2	RLap	-0.60	3.86	0.16	RLap	1.39	2.05	0.68	RLap	0.55	-0.07	
3	LLap	0.70	3.86	0.18	MidS	-1.36	1.93	0.71	LLap	0.52	-0.33	

UNBRACED LENGTH:

Bay Id	Major (ft)	-----Minor(ft)-----					-----Mom1/Mom2-----					-----Cb-----				
		LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
1	14.0	11.0	1.0	1.0	1.0	3.0	1.00	1.00	1.00	1.00	-0.03	1.13	1.00	1.00	1.00	1.83
2	14.0	4.1	4.1	1.0	2.4	1.0	-0.04	-0.04	1.00	-0.04	0.63	1.95	1.95	1.00	1.87	1.18
3	14.0	1.0	2.0	1.0	1.0	2.9	0.60	-0.03	1.00	1.00	-0.06	1.20	1.81	1.00	1.00	1.89
4	14.0	3.1	1.0	1.0	3.2	1.0	-0.04	1.00	1.00	-0.05	0.68	1.89	1.00	1.00	1.91	1.15
5	14.0	1.0	2.2	1.0	1.0	10.8	0.63	-0.03	1.00	1.00	1.00	1.18	1.79	1.00	1.00	1.13

LOAD ID 9 : Dead+Collateral+0.45Wind_Pressure+0.75MIN_SNOW

REACTIONS:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----					
	Left Sup	Left Lap	Right Lap	Right Sup	Left Sup	Left Lap	Mid-Span Mom	Loc	Right Lap	Right Sup
1	0.60			-0.92	0.00		-1.67	5.55		2.20
1	0.79		-0.62	-0.73	2.20		-0.65	7.25	1.14	1.82
2	0.77	0.67		-0.74	1.82	1.10	-0.94	7.14		1.61
2	0.70		-0.71	-0.82	1.61		-0.67	6.48	1.63	2.39
3	0.93	0.82		-0.59	2.39	1.52	-1.60	8.57		0.00

STRENGTH/DEFLECTION:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
1	RSup	-0.92	6.04	0.15	RSup	2.20	2.79	0.79	RSup	0.68	-0.35	
1	LSup	0.79	6.04	0.13	LSup	2.20	2.76	0.80	LSup	0.67	-0.07	
2	RSup	-0.74	3.86	0.19	RSup	1.61	2.05	0.78	RSup	0.64	-0.19	
2	RLap	-0.71	3.86	0.18	RLap	1.63	2.05	0.80	RLap	0.65	-0.08	
3	LLap	0.82	3.86	0.21	MidS	-1.60	1.93	0.83	LLap	0.61	-0.39	

UNBRACED LENGTH:

Bay Id	Major (ft)	-----Minor(ft)-----					-----Mom1/Mom2-----					-----Cb-----				
		LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
1	14.0	11.0	1.0	1.0	1.0	3.0	1.00	1.00	1.00	1.00	-0.03	1.13	1.00	1.00	1.00	1.83
2	14.0	4.1	4.1	1.0	2.4	1.0	-0.04	-0.04	1.00	-0.04	0.63	1.95	1.95	1.00	1.87	1.18

3	14.0	1.0	2.0	1.0	1.0	2.9	0.60-0.03	1.00	1.00-0.06	1.20	1.81	1.00	1.00	1.89
4	14.0	3.1	1.0	1.0	3.2	1.0	-0.04	1.00	1.00-0.05	0.68	1.89	1.00	1.00	1.91
5	14.0	1.0	2.2	1.0	1.0	10.8	0.63-0.03	1.00	1.00	1.00	1.18	1.79	1.00	1.00

LOAD ID 10 : Dead+Collateral+Snow/2+PAT_SL_3

REACTIONS:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----					
	Left Sup	Left Lap	Right Lap	Right Sup	Left Sup	Left Lap	Mid-Span Mom	Loc	Right Lap	Right Sup
1	0.44			-0.68	0.00		-1.19	5.47		1.70
1	0.61		-0.43	-0.51	1.70		-0.61	7.63	0.53	1.00
2	0.35	0.30		-0.29	1.00	0.68	-0.32	7.59		0.62
2	0.29		-0.31	-0.35	0.62		-0.31	6.36	0.70	1.03
3	0.40	0.35		-0.25	1.03	0.66	-0.67	8.60		0.00

STRENGTH/DEFLECTION:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
1	RSup	-0.68	6.04	0.11	RSup	1.70	2.79	0.61	RSup	0.52	-0.24	
1	LSup	0.61	6.04	0.10	LSup	1.70	2.77	0.61	LSup	0.52	-0.09	
2	LLap	0.30	3.86	0.08	LLap	0.68	2.05	0.33	LLap	0.27	-0.05	
2	RLap	-0.31	3.86	0.08	RLap	0.70	2.05	0.34	RLap	0.28	-0.04	
3	LLap	0.35	3.86	0.09	MidS	-0.67	1.93	0.35	LLap	0.27	-0.16	

UNBRACED LENGTH:

Bay Id	Major (ft)	-----Minor(ft)-----					-----Mom1/Mom2-----					-----Cb-----				
		LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
1	14.0	10.8	1.0	1.0	1.0	3.2	1.00	1.00	1.00	1.00-0.03		1.13	1.00	1.00	1.00	1.82
2	14.0	3.9	3.9	1.0	1.7	1.0	-0.03-0.03	1.00-0.13	0.53			1.90	1.90	1.00	1.96	1.24
3	14.0	1.0	2.8	1.0	1.0	2.7	0.67	0.00	1.00	1.00	0.00	1.15	1.81	1.00	1.00	1.80
4	14.0	2.7	1.0	1.0	3.0	1.0	0.00	1.00	1.00	0.00	0.68	1.80	1.00	1.00	1.81	1.15
5	14.0	1.0	2.2	1.0	1.0	10.8	0.64	0.00	1.00	1.00	1.00	1.17	1.75	1.00	1.00	1.14

LOAD ID 11 : Dead+Collateral+Snow/2+PAT_SL_4

REACTIONS:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----					
	Left Sup	Left Lap	Right Lap	Right Sup	Left Sup	Left Lap	Mid-Span Mom	Loc	Right Lap	Right Sup
1	0.24			-0.40	0.00		-0.62	5.20		1.16
1	0.53		-0.50	-0.58	1.16		-0.61	6.68	0.98	1.52
2	0.60	0.52		-0.51	1.52	0.96	-0.74	7.54		0.92
2	0.32		-0.28	-0.32	0.92		-0.19	6.96	0.65	0.95
3	0.39	0.34		-0.25	0.95	0.58	-0.70	8.48		0.00

STRENGTH/DEFLECTION:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
1	RSup	-0.40	6.04	0.07	RSup	1.16	2.77	0.42	RSup	0.35	-0.11	
1	LSup	0.53	6.04	0.09	LSup	1.16	2.80	0.41	LSup	0.36	-0.09	
2	LLap	0.52	3.86	0.13	LLap	0.96	2.07	0.46	LLap	0.39	-0.15	
2	LSup	0.32	3.86	0.08	LSup	0.92	2.02	0.46	LSup	0.36	0.00	
3	LLap	0.34	3.86	0.09	MidS	-0.70	1.93	0.36	LLap	0.24	-0.18	

UNBRACED LENGTH:

Bay Id	Major (ft)	-----Minor(ft)-----					-----Mom1/Mom2-----					-----Cb-----				
		LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup

1	14.0	10.4	1.0	1.0	3.6	3.6	1.00	1.00	1.00	0.00	0.00	1.14	1.00	1.00	1.80	1.80
2	14.0	3.0	1.0	1.0	2.5	1.0	-0.06	1.00	1.00	-0.04	0.64	1.90	1.00	1.00	1.85	1.17
3	14.0	1.0	2.3	1.0	1.0	2.2	0.63	-0.03	1.00	1.00	-0.02	1.18	1.82	1.00	1.00	1.80
4	14.0	4.1	4.1	1.0	3.2	1.0	0.00	0.00	1.00	0.00	0.68	1.89	1.89	1.00	1.85	1.15
5	14.0	1.0	2.0	1.0	1.0	11.0	0.61	0.00	1.00	1.00	1.00	1.19	1.74	1.00	1.00	1.14

LOAD ID 12 : Dead+Collateral+Snow/2+PAT_SL_5

REACTIONS:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----					
	Left Sup	Left Lap	Right Lap	Right Sup	Left Sup	Left Lap	Mid-Span Mom	Mid-Span Loc	Right Lap	Right Sup
1	0.26			-0.38	0.00		-0.74	5.66		0.86
1	0.31		-0.29	-0.34	0.86		-0.17	6.68	0.75	1.06
2	0.54	0.46		-0.58	1.06	0.57	-0.74	6.73		1.37
2	0.56		-0.47	-0.55	1.37		-0.63	7.09	0.76	1.27
3	0.41	0.37		-0.23	1.27	0.88	-0.58	8.97		0.00

STRENGTH/DEFLECTION:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
1	RSup	-0.38	6.04	0.06	RSup	0.86	2.80	0.31	RSup	0.27	-0.16	
1	LSup	0.31	6.04	0.05	LSup	0.86	2.76	0.31	LSup	0.26	0.01	
2	RSup	-0.58	3.86	0.15	RSup	1.37	2.05	0.67	RSup	0.54	-0.15	
2	LSup	0.56	3.86	0.15	LSup	1.37	2.04	0.67	LSup	0.54	-0.12	
3	LLap	0.37	3.86	0.09	LLap	0.88	2.05	0.43	LLap	0.35	-0.12	

UNBRACED LENGTH:

Bay Id	Major (ft)	-----Minor(ft)-----					-----Mom1/Mom2-----					-----Cb-----				
		LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
1	14.0	11.3	1.0	1.0	1.0	2.7	1.00	1.00	1.00	1.00	0.00	1.14	1.00	1.00	1.00	1.76
2	14.0	4.0	4.0	1.0	3.6	1.0	0.00	0.00	1.00	0.00	0.71	1.90	1.90	1.00	1.88	1.14
3	14.0	1.0	1.7	1.0	1.0	3.1	0.53	-0.13	1.00	1.00	-0.03	1.24	1.94	1.00	1.00	1.86
4	14.0	3.2	1.0	1.0	2.0	1.0	-0.03	1.00	1.00	-0.03	0.60	1.86	1.00	1.00	1.82	1.20
5	14.0	1.0	2.9	1.0	1.0	10.1	0.69	0.00	1.00	1.00	1.00	1.14	1.78	1.00	1.00	1.14

LOAD ID 13 : Dead+Collateral+Snow/2+PAT_SL_6

REACTIONS:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----					
	Left Sup	Left Lap	Right Lap	Right Sup	Left Sup	Left Lap	Mid-Span Mom	Mid-Span Loc	Right Lap	Right Sup
1	0.25			-0.39	0.00		-0.70	5.52		0.95
1	0.34		-0.26	-0.30	0.95		-0.30	7.39	0.42	0.70
2	0.31	0.26		-0.34	0.70	0.42	-0.32	6.68		0.91
2	0.49		-0.54	-0.62	0.91		-0.61	6.18	1.24	1.83
3	0.69	0.61		-0.43	1.83	1.18	-1.14	8.64		0.00

STRENGTH/DEFLECTION:

Bay Id	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
1	RSup	-0.39	6.04	0.06	RSup	0.95	2.79	0.34	RSup	0.29	-0.15	
1	LSup	0.34	6.04	0.06	LSup	0.95	2.77	0.34	LSup	0.29	-0.04	
2	RSup	-0.34	3.86	0.09	RSup	0.91	2.03	0.45	RSup	0.36	-0.05	
2	RLap	-0.54	3.86	0.14	RLap	1.24	2.05	0.61	RLap	0.49	-0.10	
3	LLap	0.61	3.86	0.16	MidS	-1.14	1.93	0.59	LLap	0.47	-0.27	

UNBRACED LENGTH:

Bay	Major	-----Minor(ft)-----					-----Mom1/Mom2-----					-----Cb-----				
Id	(ft)	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
1	14.0	11.0	1.0	1.0	1.0	3.0	1.00	1.00	1.00	1.00	0.00	1.14	1.00	1.00	1.00	1.77
2	14.0	3.8	3.8	1.0	2.0	1.0	0.00	0.00	1.00	0.00	0.60	1.84	1.84	1.00	1.77	1.20
3	14.0	1.0	1.9	1.0	7.5	3.6	0.60	0.00	1.00	1.00	0.00	1.20	1.77	1.00	1.14	1.83
4	14.0	2.6	1.0	1.0	3.1	1.0	-0.10	1.00	1.00	-0.04	0.68	1.97	1.00	1.00	1.88	1.15
5	14.0	1.0	2.4	1.0	1.0	10.6	0.65	-0.03	1.00	1.00	1.00	1.17	1.80	1.00	1.00	1.13

LOAD ID 14 : Dead+Collateral+Snow/2+PAT_SL_1

REACTIONS:

Bay	-----Shear(k)-----				-----Moment(f-k)-----					
Id	Left	Left	Right	Right	Left	Left	Mid-Span		Right	Right
	Sup	Lap	Lap	Sup	Sup	Lap	Mom	Loc	Lap	Sup
1	0.46			-0.65	0.00		-1.32	5.77		1.37
1	0.37		-0.22	-0.27	1.37		-0.14	8.12	0.41	0.66
2	0.32	0.27		-0.33	0.66	0.36	-0.44	6.91		0.71
2	0.30		-0.30	-0.34	0.71		-0.27	6.55	0.69	1.01
3	0.39	0.35		-0.25	1.01	0.63	-0.68	8.56		0.00

STRENGTH/DEFLECTION:

Bay	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
Id	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
1	RSup	-0.65	6.04	0.11	MidS	-1.32	2.63	0.50	RSup	0.43	-0.30	
1	LSup	0.37	6.04	0.06	LSup	1.37	2.73	0.50	LSup	0.42	0.02	
2	RSup	-0.33	3.86	0.08	RSup	0.71	2.06	0.35	RSup	0.28	-0.10	
2	LSup	0.30	3.86	0.08	LSup	0.71	2.04	0.35	LSup	0.28	-0.03	
3	LLap	0.35	3.86	0.09	MidS	-0.68	1.93	0.35	LLap	0.26	-0.16	

UNBRACED LENGTH:

Bay	Major	-----Minor(ft)-----					-----Mom1/Mom2-----					-----Cb-----				
Id	(ft)	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
1	14.0	11.3	1.0	1.0	1.0	2.7	1.00	1.00	1.00	1.00	-0.06	1.13	1.00	1.00	1.00	1.85
2	14.0	5.6	5.6	1.0	2.4	1.0	0.00	0.00	1.00	0.00	0.62	1.96	1.96	1.00	1.84	1.19
3	14.0	1.0	1.5	1.0	1.0	2.7	0.55	0.00	1.00	1.00	0.00	1.23	1.74	1.00	1.00	1.79
4	14.0	3.1	1.0	1.0	3.0	1.0	0.00	1.00	1.00	0.00	0.68	1.83	1.00	1.00	1.82	1.15
5	14.0	1.0	2.1	1.0	1.0	10.9	0.63	0.00	1.00	1.00	1.00	1.18	1.75	1.00	1.00	1.14

LOAD ID 15 : Dead+Collateral+Snow/2+PAT_SL_2

REACTIONS:

Bay	-----Shear(k)-----				-----Moment(f-k)-----					
Id	Left	Left	Right	Right	Left	Left	Mid-Span		Right	Right
	Sup	Lap	Lap	Sup	Sup	Lap	Mom	Loc	Lap	Sup
1	0.26			-0.39	0.00		-0.71	5.56		0.92
1	0.33		-0.27	-0.31	0.92		-0.26	7.18	0.52	0.81
2	0.34	0.29		-0.30	0.81	0.49	-0.45	7.40		0.56
2	0.26		-0.34	-0.39	0.56		-0.15	5.56	1.12	1.48
3	0.66	0.58		-0.45	1.48	0.86	-1.28	8.33		0.00

STRENGTH/DEFLECTION:

Bay	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
Id	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
1	RSup	-0.39	6.04	0.06	RSup	0.92	2.79	0.33	RSup	0.28	-0.15	
1	LSup	0.33	6.04	0.05	LSup	0.92	2.76	0.33	LSup	0.28	-0.02	
2	RSup	-0.30	3.86	0.08	RSup	0.56	2.07	0.27	RSup	0.23	-0.10	

1	RSup	-0.67	6.04	0.11	RSup	1.62	2.79	0.58	RSup	0.50	-0.26
1	LSup	0.58	6.04	0.10	LSup	1.62	2.77	0.59	LSup	0.50	-0.05
2	RSup	-0.56	3.86	0.14	RSup	1.31	2.05	0.64	RSup	0.52	-0.12
2	LSup	0.56	3.86	0.14	LSup	1.31	2.05	0.64	LSup	0.52	-0.12
3	LLap	0.37	3.86	0.10	LLap	0.89	2.05	0.44	LLap	0.35	-0.11

UNBRACED LENGTH:

Bay	Major	-----Minor(ft)-----					-----Mom1/Mom2-----					-----Cb-----				
Id	(ft)	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
1	14.0	11.1	1.0	1.0	1.0	2.9	1.00	1.00	1.00	1.00	0.00	1.14	1.00	1.00	1.00	1.77
2	14.0	3.8	3.8	1.0	2.2	1.0	0.00	0.00	1.00	0.00	0.62	1.85	1.85	1.00	1.79	1.19
3	14.0	1.0	2.0	1.0	1.0	3.0	0.60	0.00	1.00	1.00	0.00	1.20	1.76	1.00	1.00	1.80
4	14.0	3.0	1.0	1.0	1.9	1.0	0.00	1.00	1.00	0.00	0.60	1.80	1.00	1.00	1.76	1.20
5	14.0	1.0	3.1	1.0	1.0	9.9	0.70	-0.04	1.00	1.00	1.00	1.14	1.84	1.00	1.00	1.13

LOAD ID 18 : Dead+Collateral+UNB_SL

REACTIONS:

Bay	-----Shear(k)-----				-----Moment(f-k)-----					
Id	Left	Left	Right	Right	Left	Left	Mid-Span	Right	Right	
	Sup	Lap	Lap	Sup	Sup	Lap	Mom	Loc	Lap	Sup
1	0.58			-0.88	0.00		-1.61	5.55		2.12
1	0.76		-0.60	-0.70	2.12		-0.63	7.25	1.10	1.75
2	0.75	0.64		-0.72	1.75	1.06	-0.91	7.14		1.55
2	0.68		-0.68	-0.79	1.55		-0.65	6.48	1.57	2.30
3	0.90	0.79		-0.57	2.30	1.46	-1.54	8.57		0.00

STRENGTH/DEFLECTION:

Bay	-----Shear(k)-----				-----Moment(f-k)-----				Mom+Shear		Deflect(in)	
Id	Loc	Calc	Limit	UC	Loc	Calc	Limit	UC	Loc	UC	Calc	Limit
1	RSup	-0.88	6.04	0.15	RSup	2.12	2.79	0.76	RSup	0.65	-0.34	
1	LSup	0.76	6.04	0.13	LSup	2.12	2.76	0.77	LSup	0.65	-0.06	
2	RSup	-0.72	3.86	0.19	RSup	1.55	2.05	0.75	RSup	0.62	-0.18	
2	RLap	-0.68	3.86	0.18	RLap	1.57	2.05	0.77	RLap	0.62	-0.08	
3	LLap	0.79	3.86	0.21	MidS	-1.54	1.93	0.80	LLap	0.59	-0.37	

UNBRACED LENGTH:

Bay	Major	-----Minor(ft)-----					-----Mom1/Mom2-----					-----Cb-----				
Id	(ft)	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup	LSup	LLap	MidS	RLap	RSup
1	14.0	11.0	1.0	1.0	1.0	3.0	1.00	1.00	1.00	1.00	-0.03	1.13	1.00	1.00	1.00	1.83
2	14.0	4.1	4.1	1.0	2.4	1.0	-0.04	-0.04	1.00	-0.04	0.63	1.95	1.95	1.00	1.87	1.18
3	14.0	1.0	2.0	1.0	1.0	2.9	0.60	-0.03	1.00	1.00	-0.06	1.20	1.81	1.00	1.00	1.89
4	14.0	3.1	1.0	1.0	3.2	1.0	-0.04	1.00	1.00	-0.05	0.68	1.89	1.00	1.00	1.91	1.15
5	14.0	1.0	2.2	1.0	1.0	10.8	0.63	-0.03	1.00	1.00	1.00	1.18	1.79	1.00	1.00	1.13

DEFLECTION:

LOAD ID 19 : Dead+Collateral+Live

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
1	-0.36	1.87	0.19
1	-0.07	1.87	0.04
2	-0.20	1.87	0.11
2	-0.09	1.87	0.05
3	-0.40	0.93	0.43

LOAD ID 20 : Dead+Collateral+Snow

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.26	1.87	0.14
1	-0.05	1.87	0.03
2	-0.14	1.87	0.07
2	-0.06	1.87	0.03
3	-0.28	0.93	0.30

LOAD ID 21 : Dead+Collateral+Snow+Snow_Drift

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.26	1.87	0.14
1	-0.05	1.87	0.03
2	-0.14	1.87	0.07
2	-0.06	1.87	0.03
3	-0.28	0.93	0.30

LOAD ID 22 : Dead+Collateral+0.75Live+0.41Wind_Pressure

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.39	2.24	0.17
1	-0.07	2.24	0.03
2	-0.21	2.24	0.09
2	-0.09	2.24	0.04
3	-0.43	1.12	0.38

LOAD ID 23 : Dead+Collateral+0.75Snow+0.41Wind_Pressure

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.31	2.24	0.14
1	-0.06	2.24	0.03
2	-0.17	2.24	0.07
2	-0.07	2.24	0.03
3	-0.34	1.12	0.30

LOAD ID 24 : Dead+Collateral+0.75Snow+0.41Wind_Pressure+0.75Snow_Drift

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.31	2.24	0.14
1	-0.06	2.24	0.03
2	-0.17	2.24	0.07
2	-0.07	2.24	0.03
3	-0.34	1.12	0.30

LOAD ID 25 : 0.6Dead+0.54Wind_Suction

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	0.30	2.24	0.13
1	-0.01	2.24	0.00
2	0.11	2.24	0.05
2	-0.01	2.24	0.00
3	0.33	1.12	0.30

LOAD ID 26 : Dead+Collateral+MIN_SNOW

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.30	1.87	0.16
1	-0.06	1.87	0.03
2	-0.16	1.87	0.09
2	-0.07	1.87	0.04
3	-0.33	0.93	0.35

LOAD ID 27 : Dead+Collateral+0.41Wind_Pressure+0.75MIN_SNOW

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.34	2.24	0.15
1	-0.06	2.24	0.03
2	-0.18	2.24	0.08
2	-0.08	2.24	0.04
3	-0.37	1.12	0.33

LOAD ID 28 : Dead+Collateral+Snow/2+PAT_SL_3

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.24	1.87	0.13
1	-0.09	1.87	0.05
2	-0.05	1.87	0.03
2	-0.04	1.87	0.02
3	-0.16	0.93	0.17

LOAD ID 29 : Dead+Collateral+Snow/2+PAT_SL_4

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.11	1.87	0.06
1	-0.09	1.87	0.05
2	-0.15	1.87	0.08
2	0.00	1.87	0.00
3	-0.18	0.93	0.19

LOAD ID 30 : Dead+Collateral+Snow/2+PAT_SL_5

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.16	1.87	0.09
1	0.01	1.87	0.00
2	-0.15	1.87	0.08
2	-0.12	1.87	0.06
3	-0.12	0.93	0.12

LOAD ID 31 : Dead+Collateral+Snow/2+PAT_SL_6

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.15	1.87	0.08
1	-0.04	1.87	0.02
2	-0.05	1.87	0.03
2	-0.10	1.87	0.05
3	-0.27	0.93	0.29

LOAD ID 32 : Dead+Collateral+Snow/2+PAT_SL_1			

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.30	1.87	0.16
1	0.02	1.87	0.01
2	-0.10	1.87	0.05
2	-0.03	1.87	0.02
3	-0.16	0.93	0.18

LOAD ID 33 : Dead+Collateral+Snow/2+PAT_SL_2			

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.15	1.87	0.08
1	-0.02	1.87	0.01
2	-0.10	1.87	0.05
2	0.03	1.87	0.02
3	-0.33	0.93	0.36

LOAD ID 34 : Dead+Collateral+Snow-PAT_SL_1			

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.11	1.87	0.06
1	-0.10	1.87	0.05
2	-0.12	1.87	0.07
2	-0.07	1.87	0.03
3	-0.28	0.93	0.30

LOAD ID 35 : Dead+Collateral+Snow-PAT_SL_2			

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.26	1.87	0.14
1	-0.05	1.87	0.03
2	-0.12	1.87	0.07
2	-0.12	1.87	0.07
3	-0.11	0.93	0.12

LOAD ID 36 : Dead+Collateral+UNB_SL			

Bay	DEFLECTION(in)		
Id	Calc	Limit	Ratio
---	-----	-----	-----
1	-0.34	1.87	0.18
1	-0.06	1.87	0.03
2	-0.18	1.87	0.10
2	-0.08	1.87	0.04
3	-0.37	0.93	0.40

LAP SCREW SHEAR:
Screw Part =#1A
Screw Quan =6

Surf Id	Bay Id	-----Left_Lap(k)-----				-----Right_Lap(k)-----			
		Load	Calc	Limit	UC	Load	Calc	Limit	UC
2	1					4	0.19	0.68	0.27
	2	4	0.16	0.68	0.23	4	0.23	0.68	0.33
	3	4	0.23	0.68	0.33				
3	1					4	0.19	0.68	0.27
	2	4	0.16	0.68	0.23	4	0.23	0.68	0.33
	3	4	0.23	0.68	0.33				

PANEL LAYOUT:

Surf Id	Part	Type	Gage	Yield	Surface Length	Rotation Stiffness
2	PBR26	PR	26.00	60.0	30.03	0.00
3	PBR26	PR	26.00	60.0	35.03	0.00

PANEL STRENGTH:

Surf Id	Area	Load Id	-----Support-----				-----Midspan-----			
			Offset (ft)	Moment (ft-lb/ft)			Offset (ft)	Moment (ft-lb/ft)		
				Calc	Limit	Ratio		Calc	Limit	Ratio
2	Left	1	5.0	58.2	153.1	0.38	2.0	-42.7	111.4	0.38
		2	25.0	40.7	153.1	0.27	2.0	-29.9	111.4	0.27
		3	25.0	40.7	153.1	0.27	2.0	-29.9	111.4	0.27
		4	5.0	64.0	153.1	0.42	2.0	-47.0	111.4	0.42
		5	5.0	50.9	153.1	0.33	2.0	-37.4	111.4	0.34
		6	5.0	-103	111.4	0.92	2.0	72.7	153.1	0.47
		7	5.0	47.6	153.1	0.31	2.0	-35.0	111.4	0.31
		8	5.0	56.1	153.1	0.37	2.0	-41.2	111.4	0.37
		9	25.0	56.4	153.1	0.37	28.1	-41.4	111.4	0.37
2	Center	1	5.0	58.2	153.1	0.38	2.0	-42.7	111.4	0.38
		2	25.0	40.7	153.1	0.27	2.0	-29.9	111.4	0.27
		3	25.0	40.7	153.1	0.27	2.0	-29.9	111.4	0.27
		4	5.0	64.0	153.1	0.42	2.0	-47.0	111.4	0.42
		5	5.0	50.9	153.1	0.33	2.0	-37.4	111.4	0.34
		6	5.0	-74.6	111.4	0.67	2.0	52.8	153.1	0.35
		7	5.0	47.6	153.1	0.31	2.0	-35.0	111.4	0.31
		8	5.0	56.1	153.1	0.37	2.0	-41.2	111.4	0.37
		9	25.0	56.4	153.1	0.37	28.1	-41.4	111.4	0.37
2	Right	1	5.0	58.2	153.1	0.38	2.0	-42.7	111.4	0.38
		2	25.0	40.7	153.1	0.27	2.0	-29.9	111.4	0.27
		3	25.0	40.7	153.1	0.27	2.0	-29.9	111.4	0.27
		4	5.0	64.0	153.1	0.42	2.0	-47.0	111.4	0.42
		5	5.0	50.9	153.1	0.33	2.0	-37.4	111.4	0.34
		6	5.0	-103	111.4	0.92	2.0	72.7	153.1	0.47
		7	5.0	47.6	153.1	0.31	2.0	-35.0	111.4	0.31
		8	5.0	56.1	153.1	0.37	2.0	-41.2	111.4	0.37
		9	25.0	56.4	153.1	0.37	28.1	-41.4	111.4	0.37
3	Left	1	30.0	58.1	153.1	0.38	33.1	-42.8	111.4	0.38
		2	30.0	40.7	153.1	0.27	33.1	-29.9	111.4	0.27
		3	30.0	40.7	153.1	0.27	33.1	-29.9	111.4	0.27
		4	30.0	63.9	153.1	0.42	33.1	-47.1	111.4	0.42
		5	30.0	50.9	153.1	0.33	33.1	-37.5	111.4	0.34
		6	30.0	-103	111.4	0.92	33.1	72.7	153.1	0.48
		7	30.0	47.5	153.1	0.31	33.1	-35.0	111.4	0.31
		8	30.0	56.0	153.1	0.37	33.1	-41.2	111.4	0.37
		9	5.0	55.3	153.1	0.36	2.0	-40.6	111.4	0.36
3	Center	1	30.0	58.1	153.1	0.38	33.1	-42.8	111.4	0.38
		2	30.0	40.7	153.1	0.27	33.1	-29.9	111.4	0.27
		3	30.0	40.7	153.1	0.27	33.1	-29.9	111.4	0.27
		4	30.0	63.9	153.1	0.42	33.1	-47.1	111.4	0.42
		5	30.0	50.9	153.1	0.33	33.1	-37.5	111.4	0.34
		6	30.0	-74.6	111.4	0.67	33.1	52.8	153.1	0.35
		7	30.0	47.5	153.1	0.31	33.1	-35.0	111.4	0.31
		8	30.0	56.0	153.1	0.37	33.1	-41.2	111.4	0.37
		9	5.0	55.3	153.1	0.36	2.0	-40.6	111.4	0.36

3	Right	1	30.0	58.1	153.1	0.38	33.1	-42.8	111.4	0.38
		2	30.0	40.7	153.1	0.27	33.1	-29.9	111.4	0.27
		3	30.0	40.7	153.1	0.27	33.1	-29.9	111.4	0.27
		4	30.0	63.9	153.1	0.42	33.1	-47.1	111.4	0.42
		5	30.0	50.9	153.1	0.33	33.1	-37.5	111.4	0.34
		6	30.0	-103	111.4	0.92	33.1	72.7	153.1	0.48
		7	30.0	47.5	153.1	0.31	33.1	-35.0	111.4	0.31
		8	30.0	56.0	153.1	0.37	33.1	-41.2	111.4	0.37
		9	5.0	55.3	153.1	0.36	2.0	-40.6	111.4	0.36

PANEL DEFLECTION:

Surf Id	Area	Load Id	-----Deflection (in)-----			
			Offset	Calc	Limit	Ratio
----	-----	----	-----	-----	-----	-----
2	Left	10	2.5	-0.16	1.00	0.16
		11	2.5	-0.11	1.00	0.11
		12	2.5	-0.11	1.00	0.11
		13	2.5	-0.07	1.00	0.07
		14	2.5	0.27	1.00	0.27
		15	2.5	-0.13	1.00	0.13
		16	27.5	-0.17	1.00	0.17
2	Center	10	2.5	-0.16	1.00	0.16
		11	2.5	-0.11	1.00	0.11
		12	2.5	-0.11	1.00	0.11
		13	2.5	-0.07	1.00	0.07
		14	2.5	0.20	1.00	0.20
		15	2.5	-0.13	1.00	0.13
		16	27.5	-0.17	1.00	0.17
2	Right	10	2.5	-0.16	1.00	0.16
		11	2.5	-0.11	1.00	0.11
		12	2.5	-0.11	1.00	0.11
		13	2.5	-0.07	1.00	0.07
		14	2.5	0.27	1.00	0.27
		15	2.5	-0.13	1.00	0.13
		16	27.5	-0.17	1.00	0.17
----	-----	----	-----	-----	-----	-----
3	Left	10	2.5	-0.16	1.00	0.16
		11	32.5	-0.11	1.00	0.11
		12	32.5	-0.11	1.00	0.11
		13	32.5	-0.07	1.00	0.07
		14	32.5	0.27	1.00	0.27
		15	32.5	-0.13	1.00	0.13
		16	2.5	-0.17	1.00	0.17
3	Center	10	2.5	-0.16	1.00	0.16
		11	32.5	-0.11	1.00	0.11
		12	32.5	-0.11	1.00	0.11
		13	32.5	-0.07	1.00	0.07
		14	32.5	0.20	1.00	0.20
		15	32.5	-0.13	1.00	0.13
		16	2.5	-0.17	1.00	0.17
3	Right	10	2.5	-0.16	1.00	0.16
		11	32.5	-0.11	1.00	0.11
		12	32.5	-0.11	1.00	0.11
		13	32.5	-0.07	1.00	0.07
		14	32.5	0.27	1.00	0.27
		15	32.5	-0.13	1.00	0.13
		16	2.5	-0.17	1.00	0.17

LOAD COMBINATION:

Load Id	Description
-----	-----
1	Dead+Live
2	Dead+Snow

3 Dead+Snow+Snow Drift
4 Dead+0.75Live+0.45Wind_Pressure
5 Dead+0.75Snow+0.45Wind_Pressure
6 0.6Dead+0.6Wind_Suction
7 Dead+MIN_SNOW
8 Dead+0.45Wind_Pressure+0.75MIN_SNOW
9 Dead+Collateral+UNB_SL
10 Live
11 Snow
12 Snow+Snow Drift
13 0.54Wind_Pressure
14 0.54Wind_Suction
15 MIN_SNOW
16 Dead+Collateral+UNB_SL

11 12	Roof Panel Zones	8/25/22 2:32pm
-------	------------------	----------------

PANEL:

Part	Thick (in)	Yield (ksi)	Tensile Strength (ksi)
PBR26	0.019	60.00	78.00

PURLIN SCREWS:

Part	Dia (in)	Washer (in)	Limit (k)
#17A	0.209	0.50	2.90

PANEL ZONE LAYOUT:

TABLE LONG EXCERPT:

							-Purlin(ft,in)-				Panel
Surf	-----Zone-----		---Locate(ft)---		--Surface(ft)--		Bay	Load		Min	Zone
Id	Id	Description	Start	End	Offset1	Offset2	Id	Id	Width	Thick	(ft)
2	1	Interior	19.04	50.96	19.04	30.03	2	4	5.00	0.062	5.00
2	2	Middle	9.52	60.48	9.52	30.03	2	4	5.00	0.062	5.00
2	7	Lt top corner	0.00	9.52	0.00	3.18	1	1	5.00	0.074	5.00
2	8	Rt top corner	60.48	70.00	0.00	3.18	3	1	5.00	0.062	5.00
2	11	Lt top cor gabl	0.00	3.18	3.18	9.53	1	1	5.00	0.074	5.00
2	12	Rt top cor gabl	66.82	70.00	3.18	9.53	3	1	5.00	0.062	5.00
2	15	Exterior	0.00	70.00	0.00	30.03	2	4	5.00	0.062	5.00
3	1	Interior	19.04	50.96	0.00	15.99	2	1	5.00	0.062	5.00
3	2	Middle	9.52	60.48	0.00	25.51	2	1	5.00	0.062	5.00
3	9	Rt bot corner	60.48	70.00	31.85	35.03	3	6	5.00	0.062	5.00
3	10	Lt bot corner	0.00	9.52	31.85	35.03	1	6	5.00	0.074	5.00
3	13	Rt bot cor gabl	66.82	70.00	25.50	31.85	3	6	5.00	0.062	5.00
3	14	Lt bot cor gabl	0.00	3.18	25.50	31.85	1	6	5.00	0.074	5.00
3	15	Exterior	0.00	70.00	0.00	35.03	2	6	5.00	0.062	5.00

PURLIN SCREW CHECK:

					-----Limit(k)-----			
Surf	Zone	Screw	Wind		Purlin	Panel	Screw	Max
Id	Id	Space	Suction (psf)	Load (k)	Pullout	Pullover	Tension	UC
2	1	0.95	12.48	0.06	0.23	0.37	0.77	0.26
2	2	0.95	21.72	0.10	0.23	0.37	0.77	0.45
2	7	0.95	39.06	0.19	0.27	0.37	0.77	0.68
2	8	0.95	39.06	0.19	0.23	0.37	0.77	0.81
2	11	0.95	39.06	0.19	0.27	0.37	0.77	0.68
2	12	0.95	39.06	0.19	0.23	0.37	0.77	0.81
2	15	0.95	28.70	0.14	0.23	0.37	0.77	0.59
3	1	0.95	12.48	0.06	0.23	0.37	0.77	0.26
3	2	0.95	21.72	0.10	0.23	0.37	0.77	0.45
3	9	0.95	39.06	0.19	0.23	0.37	0.77	0.81
3	10	0.95	39.06	0.19	0.27	0.37	0.77	0.68
3	13	0.95	39.06	0.19	0.23	0.37	0.77	0.81
3	14	0.95	39.06	0.19	0.27	0.37	0.77	0.68
3	15	0.95	28.70	0.14	0.23	0.37	0.77	0.59

.. No Warnings

```
*=====
*11 12                Wall Design Input File                8/25/22   2:32pm
*=====
```

```
*( 1)VERSION/UNITS:
*VERSION      Units(I/M)
*  '2.01'      'I'
```

```
*( 2)JOB IDENTIFICATION:
*   Job Id
*   '11 12'
```

```
*( 3)DESIGN CODE:
*Design Steel_Code      ---Build---      Code      Seismic
* Code      Cold      Country      Code      Year      Label      Zone
*  'WS'      'NAUS16'      '----'      'IBC '      '18'      'IBC 18 '      'B '

```

```
*( 4)DESIGN CONSTANTS:
* ---Steel_Yield---      Stress      Strength_Factors
* C_Sec Z_Sec O_Sec      Ratio      Wind      Seismic
* 55.0 55.0 55.0      1.03      1.0000      1.0000
```

```
*( 5)DEFLECTION LIMITS:
* -----Rafter-----      Girt      Panel      Part
* Live      Wind      Total      Column      Wall      Wall      Wall
* 180.      180.      0.      180.      90.      60.      90.
```

```
*( 6)REPORTS:
*   Input      Column      Wall      Door      Wall      Cable
*   Echo      Rafter      Girt      Jamb      Panel      Brace
*   'I'      'Y'      'Y'      'Y'      'Y'      'Y'
```

```
*( 7)BUILDING SHAPE:
*   Build      Build      L_Eave      R_Eave      Peak      L_Roof      No.
*   Width      Length      Height      Height      Offset      Slope      Wall
* 65.0000      70.0000      16.0833      15.8750      30.0000      0.500      8
```

```
*( 8)WALL OPTIONS:
*Wall Design Detail      -----Notch-----      Base_Type      Base_Trim
* Id      Option      Option      Depth      Width      Ext      Parapet      Panel      Jamb      Panel      Jamb
* 1      'NYYY'      'YYYY'      1.500      1.500      1.500      0.0000      'O'      'O'      'Y'      'Y'
* 2      'NYYY'      'YYYY'      1.500      11.250      1.500      0.0000      'O'      'O'      'Y'      'Y'
* 3      'NYYY'      'YYYY'      1.500      1.500      1.500      0.0000      'O'      'O'      'Y'      'Y'
* 4      'NYYY'      'YYYY'      1.500      11.250      1.500      0.0000      'O'      'O'      'Y'      'Y'
```

```
*( 9)INTERIOR WALL OPTIONS:
*Wall Design Detail      ----Notch---      Base_Type      Base_Trim
* Id      Option      Option      Depth      Width      Panel      Jamb      Panel      Jamb
* 6      'NYYY'      'YYYY'      0.000      0.000      '-'      '-'      'N'      'N'
* 7      'NYYY'      'YYYY'      0.000      0.000      '-'      '-'      'N'      'N'
* 8      'NYYY'      'YYYY'      0.000      0.000      '-'      '-'      'N'      'N'
```

```
*(10)STEP ELEVATION:
*No.      Base      Eave      Step      -Slope_Offset-
*Step      Start      End      Elev      Height      Type      Start      End
* 1      0.0000      70.0000      0.0000      0.0000      '-'      0.0000      0.0000
```

```
*(11)HALL SYSTEM:
* No. Hall      -----Notch-----      ----Wall_Id
*-----
*Hall Id      Type      Orn      Opt      Width      Height      Locate      Offset      Length      Depth      Width      L      R      S
*E
*0
```

* (12) WALL PARTITIONS:

*Sets Of	Wall			Wall			Column
* Walls	Id	(L/T)	Offset	Length	Quan	Location	Side
3	6	'T'	0.0000	65.0000	4	14.0000	'L'
						28.0000	'L'
						42.0000	'L'
						56.0000	'L'
	7	'L'	30.0000	14.0000	1	0.0000	'F'
	8	'L'	30.0000	14.0000	4	14.0000	'F'
						28.0000	'F'
						42.0000	'F'
						56.0000	'F'

* (13) SPECIAL WALLS:

* No.	--Location--		-----Offset----		Material		---Extend---		Base	Frame
*Wall	Use	Id	Start	End	Type	Thick	Type	Offset	Opt	Opt
0										

* (14) RECESS:

* No.	-Location-									Wall_Id
*Recess	Use	Id	Type	Orn	Offset	Width	Depth	Height	Option	L C R
0										

* (15) BAY SPACING:

*Wall	Sets Of	Bay	No.
* Id	Bays	Width	Bays
1	1	5.0000	13
2	1	14.0000	5
3	1	5.0000	13
4	1	14.0000	5
5	2	28.0000	2
		14.0000	1
6	1	5.0000	13
7	1	4.6667	3
8	1	4.6667	3

* (16) BAY OPENINGS:

*No.	Wall	Bay	Bay		Bay	Open	Open	Sill		Access	Jamb_Type	Head		
Set	Id	Id	Offset	Type	Depth	Width	Height	Height	Opt	Id	Lt	Rt	Type	D
*Open														
Depth														
10	2	1	1.0000	2	35.0000	12.0000	14.0000	0.0000	'-'	'DOOR62	'C	'C	'C	6
.000	2	2	1.0000	2	35.0000	12.0000	14.0000	0.0000	'-'	'DOOR62	'C	'C	'C	6
.000	2	3	1.0000	2	35.0000	12.0000	14.0000	0.0000	'-'	'DOOR62	'C	'C	'C	6
.000	2	4	1.0000	2	35.0000	12.0000	14.0000	0.0000	'-'	'DOOR62	'C	'C	'C	6
.000	2	5	1.0000	2	35.0000	12.0000	14.0000	0.0000	'-'	'DOOR62	'C	'C	'C	6
.000	4	1	1.0000	2	30.0000	12.0000	14.0000	0.0000	'-'	'DOOR62	'C	'C	'C	6
.000	4	2	1.0000	2	30.0000	12.0000	14.0000	0.0000	'-'	'DOOR62	'C	'C	'C	6
.000	4	3	1.0000	2	30.0000	12.0000	14.0000	0.0000	'-'	'DOOR62	'C	'C	'C	6
.000	4	4	1.0000	2	30.0000	12.0000	14.0000	0.0000	'-'	'DOOR62	'C	'C	'C	6
.000	4	5	1.0000	2	30.0000	12.0000	14.0000	0.0000	'-'	'DOOR62	'C	'C	'C	6

* (17) DOORS:

*No.	-Location-		Door	Door		Access
*Door	Use	Id	Locate	Width	Height	Rot Opt Id

0

* (18) OPEN WALLS:

*No.	-Location-	--Bay_Id--	Wall	----	Type----	Base	Full
*Wall	Use	Id	Start End	Height	Use Id Opt	Type	Load

0

* (19) COLUMNS:

*Wall	No.	Col	Col	Col	Col	Set
* Id	Col	Id	Type	Rot	Opt	Depth
1	14	1	'-'	'R'	'-'	6.000
		2	'C'	'F'	'-'	6.000
		3	'C'	'F'	'-'	6.000
		4	'C'	'F'	'-'	6.000
		5	'C'	'F'	'-'	6.000
		6	'C'	'F'	'-'	6.000
		7	'C'	'F'	'-'	6.000
		8	'C'	'B'	'-'	6.000
		9	'C'	'B'	'-'	6.000
		10	'C'	'B'	'-'	6.000
		11	'C'	'B'	'-'	6.000
		12	'C'	'B'	'-'	6.000
		13	'C'	'B'	'-'	6.000
		14	'-'	'R'	'-'	6.000
2	6	15	'C'	'R'	'-'	6.000
		16	'C'	'L'	'-'	6.000
		17	'C'	'L'	'-'	6.000
		18	'C'	'L'	'-'	6.000
		19	'C'	'L'	'-'	6.000
3	14	20	'C'	'L'	'-'	6.000
		21	'-'	'L'	'-'	6.000
		22	'C'	'B'	'-'	6.000
		23	'C'	'B'	'-'	6.000
		24	'C'	'B'	'-'	6.000
		25	'C'	'B'	'-'	6.000
		26	'C'	'B'	'-'	6.000
		27	'C'	'B'	'-'	6.000
		28	'C'	'F'	'-'	6.000
		29	'C'	'F'	'-'	6.000
		30	'C'	'F'	'-'	6.000
		31	'C'	'F'	'-'	6.000
		32	'C'	'F'	'-'	6.000
		33	'C'	'F'	'-'	6.000
		34	'-'	'L'	'-'	6.000
4	6	35	'C'	'L'	'-'	6.000
		36	'C'	'L'	'-'	6.000
		37	'C'	'L'	'-'	6.000
		38	'C'	'L'	'-'	6.000
		39	'C'	'L'	'-'	6.000
		40	'C'	'R'	'-'	6.000

* (20) INTERIOR COLUMNS:

*Wall	No.	Col	Col	Col	Col	Set
* Id	Col	Id	Type	Rot	Opt	Depth
6	14	41	'-'	'L'	'-'	6.000
		42	'C'	'F'	'-'	6.000
		43	'C'	'F'	'-'	6.000
		44	'C'	'F'	'-'	6.000
		45	'C'	'F'	'-'	6.000
		46	'C'	'F'	'-'	6.000
		47	'C'	'F'	'-'	6.000
		48	'C'	'B'	'-'	6.000
		49	'C'	'B'	'-'	6.000

		50		'C'		'B'	'-'	6.000
		51		'C'		'B'	'-'	6.000
		52		'C'		'B'	'-'	6.000
		53		'C'		'B'	'-'	6.000
		54		'-'		'L'	'-'	6.000
7	4	55		'-'		'F'	'-'	6.000
		56		'C'		'L'	'-'	6.000
		57		'C'		'L'	'-'	6.000
		58		'-'		'F'	'-'	6.000
8	4	59		'-'		'F'	'-'	6.000
		60		'C'		'L'	'-'	6.000
		61		'C'		'L'	'-'	6.000
		62		'-'		'F'	'-'	6.000

*(21) ADDITIONAL COLUMNS:

*No.	Col	Location		Col	Col	Col	Col	Col	Set
*Col	Id	Use	Id	Locate	Offset	Type	Rot	Opt	Depth
0									

*(22) RAFTERS:

*Wall	No.	Raf	Raf	Raf	Raf	Raf	Set
*Id	Raf	Id	Offset	Type	Rot	Opt	Depth
1	0						
2	3	1	0.0000	'O'	'-'	'-'	6.125
		2	28.0000	'O'	'-'	'-'	6.125
		3	56.0000	'O'	'-'	'-'	6.125
3	0						
4	3	4	0.0000	'O'	'-'	'-'	6.125
		5	14.0000	'O'	'-'	'-'	6.125
		6	42.0000	'O'	'-'	'-'	6.125

*(23) INTERIOR RAFTERS:

*Wall	No.	Raf	Raf	Raf	Raf	Raf	Set
*Id	Raf	Id	Offset	Type	Rot	Opt	Depth
6	0						
7	0						
8	0						

*(24) ADDITIONAL RAFTERS:

*No.	Raf	Location		Raf	-----Offset-----	Raf	Raf	Raf	Set	
*Raf	Id	Use	Id	Locate	Start	End	Type	Rot	Opt	Depth
0										

*(25) GIRT LAYOUT:

*No.	Wall	Top	Girt	Flange	Set	Max	Max_Unbr	
*Wall	Id	Type	Type	Opt	Strap	Depth	Space	Length
4	1	'CF'	'--'	'-'	'N'	6.000	10.0000	10.0000
	2	'CF'	'--'	'-'	'N'	6.000	10.0000	10.0000
	3	'CF'	'--'	'-'	'N'	6.000	10.0000	10.0000
	4	'CF'	'--'	'-'	'N'	6.000	10.0000	10.0000

*(26) GIRT LOCATION:

*No.	Wall	Set	No.	Girt
*Wall	Id	Loc	Girt	Location
4	1	'Y'	3	4.0000 8.0000 12.0000
	2	'Y'	3	4.0000 8.0000 12.0000
	3	'Y'	3	4.0000 8.0000 12.0000
	4	'Y'	3	4.0000 8.0000 12.0000

*(27) ROOF PURLINS:

*Purlin	Peak	No.	---Purlin---
*Type	Space	Purlin	Location Rot
'ZB'	0.0000	12	5.0000 'N'

```

10.0000 'N'
15.0000 'N'
20.0000 'N'
25.0000 'N'
30.0000 'N'
35.0000 'Y'
40.0000 'Y'
45.0000 'Y'
50.0000 'Y'
55.0000 'Y'
60.0000 'Y'

*(28) EXTERIOR WALL PANEL:
*Wall -----Wall_Panel-----
* Id  Part      Rot Opt  Screw  Color
  1  'CUSPANL '  '-' '---' 'S---' 'A1  '
  2  'CUSPANL '  '-' '---' 'S---' 'A1  '
  3  'CUSPANL '  '-' '---' 'S---' 'A1  '
  4  'CUSPANL '  '-' '---' 'S---' 'A1  '

*(29) INTERIOR WALL PANEL:
*Wall -----Wall_Panel-----
* Id  Part      Rot Opt  Screw  Color
  6  'PBR29  '  'R' '---' 'S---' 'GL  '
  7  'PBR29  '  'R' '---' 'S---' 'GL  '
  8  'PBR29  '  'R' '---' 'S---' 'GL  '

*(30) ROOF PANEL:
* Panel      Panel  Screw  -----Standing_Seam-----
* Size      Opt   Type    Use  Type  Clip  Seam Type      Clamp
'PBR26  '  '---'  'S---'  'N'  '3U'  3.000  '-----' 'N'

*(31) ADDITIONAL PANELS:
* No.  -Location-  -----Offset-----  Panel
*Panel Use      Id      Start      End  Part      Rot Opt  Screw  Color  Base
0
0

*(32) EXTERIOR WIND FRAMING:
*Wall Panel  Brace      Wall No.
* Id  Shear  Type  Opt  Dead Bay
  1  'Y'    'N'  '-'  2.00  0
  2  'Y'    'N'  '-'  2.00  0
  3  'Y'    'N'  '-'  2.00  0
  4  'Y'    'N'  '-'  2.00  0
  5  'Y'    'N'  '-'  2.50  0

*(33) INTERIOR WIND FRAMING:
*      Panel  Brace      Wall No.
*      Shear  Type  Opt  Dead Bay
      'Y'    'N'  '-'  2.00  0
      'Y'    'N'  '-'  2.00  0

*(34) BASIC LOADS:
*
*      Dead  Collat  Live  Snow  Rain  Basic      ---Deflection---  Wind  Seis
* Load    Load  Load  Load  Load  Wind  Load_Ratio  Load  Load
*      2.0    0.5  20.0  13.4  0.0  19.2  1.00  0.54  1.00  0.60  1.00

*(35) EDGE ZONE:
*
*      Zone      Brace
*      Width  Girt  Panel  Jamb  Width
6.433  1.07  1.00  1.07  6.433

*(36) WIND PRESSURE/SUCTION:

```


*	Wind	Wind	
*	Press	Suct	
	16.8	-18.5	.. Ext Column
	16.8	-18.5	.. Girt/Header
	16.8	-18.5	.. Jamb
	20.8	-27.7	.. Ext Panel
	44.3	-28.4	.. Parapet Girt
	10.0	-10.0	.. Int Column
	10.0	-10.0	.. Int Panel
	8.5	-6.1	.. Bracing
	12.9	-9.1	.. Bracing, Edge
	28.8	-19.2	.. Bracing, Parapet

* (37) WIND COEFFICIENTS:

*_	Surf	Wind_1		Wind_2		Long_Wind		Surface
*_	Id	Left	Right	Left	Right	1	2	Friction
	1	0.38	-0.61	0.75	-0.22	-0.65	-0.65	0.00
	2	-1.14	-0.66	-0.78	-0.30	-1.14	-0.66	0.00
	3	-0.66	-1.14	-0.30	-0.78	-0.66	-1.14	0.00
	4	-0.58	0.40	-0.22	0.78	-0.65	-0.65	0.00

* (38) COLUMN, RAFTER, BRACING DESIGN LOADS:

*No.	Load	Aux_Load						Wind_1	Wind_2	Long_Wind	Column_Wind					
eis	Id	Dead	Coll	Live	Snow	Drift	Rain	Left	Right	Left	Right	1	2	Press	Suct	S
.00	1	1.00	1.00	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0
.00	0	0.00														
.00	2	1.00	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0
.00	0	0.00														
.00	3	1.00	1.00	0.00	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0
.00	0	0.00														
.00	4	1.00	1.00	0.00	1.00	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0
.00	0	0.00														
.00	5	1.00	1.00	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0
.00	0	0.00														
.00	6	1.00	1.00	0.00	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0
.00	0	0.00														
.00	7	1.00	1.00	0.00	0.75	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0
.00	0	0.00														
.00	8	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.60	0.00	0.60	0.00	0
.00	0	0.00														
.00	9	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.60	0.60	0.00	0
.00	0	0.00														
.00	10	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.60	0.00	0.00	0.60	0
.00	0	0.00														
.00	11	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.60	0.00	0.60	0
.00	0	0.00														
.00	12	1.00	0.00	0.00	0.00	0.00	0.00	0.60	0.00	0.00	0.00	0.00	0.00	0.00	0.60	0
.00	0	0.00														
.00	13	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.60	0.00	0.00	0.00	0.00	0.00	0.60	0
.00	0	0.00														
.00	14	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.60	0.00	0.00	0.00	0.00	0.60	0
.00	0	0.00														
.00	15	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.60	0.00	0.00	0.00	0.60	0
.00	0	0.00														
.00	16	1.00	1.00	0.75	0.00	0.00	0.00	0.00	0.00	0.45	0.00	0.00	0.00	0.00	0.45	0
.00	0	0.00														
.00	17	1.00	1.00	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.45	0.00	0.00	0.00	0.45	0
.00	0	0.00														

[illegible]

[illegible]

* (39) COLUMN, RAFTER, BRACING DESIGN LOADS: Deflection

* Load																
								Wind_1		Wind_2		Long_Wind		Column_Wind		
*No.	Id	Dead	Coll	Live	Snow	Drift	Rain	Left	Right	Left	Right	1	2	Press	Suct	S
eis	Id	Coef														
52	1	1.00	1.00	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0
.00	0	0.00														
.00	2	1.00	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0
.00	0	0.00														
.00	3	1.00	1.00	0.00	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0
.00	0	0.00														
.00	4	1.00	1.00	0.00	1.00	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0
.00	0	0.00														
.00	5	1.00	1.00	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0
.00	0	0.00														
.00	6	1.00	1.00	0.00	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0
.00	0	0.00														
.00	7	1.00	1.00	0.00	0.75	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0
.00	0	0.00														
.00	8	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.00	0.00	1.00	0.00	0
.00	0	0.00														
.00	9	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.00	1.00	0.00	0
.00	0	0.00														
.00	10	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.00	0.00	0.00	1.00	0
.00	0	0.00														
.00	11	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.00	0.00	1.00	0
.00	0	0.00														
.00	12	1.00	0.00	0.00	0.00	0.00	0.00	1.00	0.00	0.00	0.00	0.00	0.00	0.00	1.00	0
.00	0	0.00														
.00	13	1.00	0.00	0.00	0.00	0.00	0.00	0.00	1.00	0.00	0.00	0.00	0.00	0.00	1.00	0
.00	0	0.00														
.00	14	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.00	0.00	0.00	0.00	0.00	1.00	0
.00	0	0.00														
.00	15	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.00	0.00	0.00	0.00	1.00	0
.00	0	0.00														
.00	16	1.00	1.00	0.75	0.00	0.00	0.00	0.00	0.00	0.75	0.00	0.00	0.00	0.00	0.75	0
.00	0	0.00														
.00	17	1.00	1.00	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.75	0.00	0.00	0.00	0.75	0
.00	0	0.00														
.00	18	1.00	1.00	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.75	0.00	0.00	0.75	0
.00	0	0.00														
.00	19	1.00	1.00	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.75	0.00	0.75	0
.00	0	0.00														
.00	20	1.00	1.00	0.00	0.75	0.00	0.00	0.00	0.00	0.75	0.00	0.00	0.00	0.00	0.75	0
.00	0	0.00														
.00	21	1.00	1.00	0.00	0.75	0.00	0.00	0.00	0.00	0.00	0.75	0.00	0.00	0.00	0.75	0
.00	0	0.00														
.00	22	1.00	1.00	0.00	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.75	0.00	0.00	0.75	0
.00	0	0.00														
.00	23	1.00	1.00	0.00	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.75	0.00	0.75	0
.00	0	0.00														

	24	1.00	1.00	0.00	0.75	0.75	0.00	0.00	0.00	0.75	0.00	0.00	0.00	0.00	0.75	0.00
.00	0	0.00														
	25	1.00	1.00	0.00	0.75	0.75	0.00	0.00	0.00	0.00	0.75	0.00	0.00	0.00	0.75	0.00
.00	0	0.00														
	26	1.00	1.00	0.00	0.75	0.75	0.00	0.00	0.00	0.00	0.00	0.75	0.00	0.00	0.75	0.00
.00	0	0.00														
	27	1.00	1.00	0.00	0.75	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.75	0.00	0.75	0.00
.00	0	0.00														
	28	0.60	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.00	0.00	1.00	0.00	0.00
.00	0	0.00														
	29	0.60	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.00	1.00	0.00	0.00
.00	0	0.00														
	30	0.60	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.00	0.00	0.00	1.00	0.00
.00	0	0.00														
	31	0.60	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.00	0.00	1.00	0.00
.00	0	0.00														
	32	0.60	0.00	0.00	0.00	0.00	0.00	1.00	0.00	0.00	0.00	0.00	0.00	0.00	1.00	0.00
.00	0	0.00														
	33	0.60	0.00	0.00	0.00	0.00	0.00	0.00	1.00	0.00	0.00	0.00	0.00	0.00	1.00	0.00
.00	0	0.00														
	34	0.60	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.00	0.00	0.00	0.00	0.00	1.00	0.00
.00	0	0.00														
	35	0.60	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.00	0.00	0.00	0.00	1.00	0.00
.00	0	0.00														
	36	1.03	1.03	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
.70	0	0.00														
	37	1.03	1.03	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-0.00
.70	0	0.00														
	38	1.02	1.02	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
.53	0	0.00														
	39	1.02	1.02	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-0.00
.53	0	0.00														
	40	1.02	1.02	0.00	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
.53	0	0.00														
	41	1.02	1.02	0.00	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-0.00
.53	0	0.00														
	42	1.02	1.02	0.00	0.75	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
.53	0	0.00														
	43	1.02	1.02	0.00	0.75	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-0.00
.53	0	0.00														
	44	0.57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
.70	0	0.00														
	45	0.57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-0.00
.70	0	0.00														
	46	1.00	1.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
.00	1	1.00														
	47	1.00	1.00	0.00	0.01	0.00	0.00	0.00	0.00	0.45	0.00	0.00	0.00	0.00	0.45	0.00
.00	1	0.75														
	48	1.00	1.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.45	0.00	0.00	0.00	0.45	0.00
.00	1	0.75														
	49	1.00	1.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
.00	2	1.00														
	50	1.00	1.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
.00	2	0.75														
	51	1.00	1.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.75	0.00
.00	2	0.75														
	52	1.01	1.01	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
.00	2	0.75														

* (40)AUXILIARY LOADS:

* No.	Aux	Aux	No._Add	Add_Load
* Aux	Id	Name	Comb	Id Coef
2	1	'MIN_SNOW	2	1 1.00

2	'UNB_SL	'	4	3	1.00
				4	0.40
				5	1.00
				6	0.37

*No.	Add	Surf	Basic	Load	Load	F		D		---Surface---	
*Add	Id	Id	Load	Type	Orn	W1	W2	D1	D2	Start	End
6	1	2	'U_SNOW'	'D '	'T'	-16.00	-16.00	0.0000	30.0260	0.000	70.000
	2	3	'U_SNOW'	'D '	'T'	-16.00	-16.00	0.0000	35.0304	0.000	70.000
	3	2	'U_SNOW'	'D '	'T'	-13.44	-13.44	0.0000	30.0260	0.000	70.000
	4	2	'U_SNOW'	'D '	'T'	-13.44	-13.44	9.0934	30.0260	0.000	70.000
	5	3	'U_SNOW'	'D '	'T'	-13.44	-13.44	0.0000	35.0304	0.000	70.000
	6	3	'U_SNOW'	'D '	'T'	-13.44	-13.44	0.0000	19.0065	0.000	70.000

* No.	--Location--		Jamb
*Trim	Type	Id	Trim
14	'EXT	1	'--'
	'EXT	2	'--'
	'EXT	3	'--'
	'EXT	4	'--'
	'INT	0	'--'
	'HALL	0	'--'
	'RECE	0	'--'
	'XTND	0	'--'
	'STEP	0	'--'
	'JAMB	0	'--'
	'PARA	0	'--'
	'FIRE	0	'--'
	'CLIM	0	'--'
	'LINE	0	'--'

* No.						Washer			
*Zone	Zone	Part		Dia	Limit	Dia	-----Spacing-----		
2	'INT '	'#29	'	0.209	2.900	0.500	12.000	6.000	0.000
	'EDGE'	'#29	'	0.209	2.900	0.500	12.000	6.000	0.000

```
* Aux
*   Id   Description
*   1    Minimum snow load
*   2    Unbalanced snow load
```

```
* Add
*   Id  Description
*   1   Minimum snow load surface 2
*   2   Minimum snow load surface 3
*   3   Unbalanced snow load surface 2
*   4   Unbalanced snow load surface 2
*   5   Unbalanced snow load surface 3
*   6   Unbalanced snow load surface 3
```

* Code file used was EW IBC.18N Version 4.0

STRUCTURAL CODE:
Design Basis : WS
Cold Formed Steel : NAUS16

BUILDING CODE:
Wind Code : IBC 18
Seismic Zone : B

MODULUS OF ELASTICITY
Cold Formed Steel : 29500 (ksi)

ROOF LAYOUT:

System		Roof_Extents		Roof	Panel
Id	Type	Start	End	Length	Part
-----	----	-----	-----	-----	-----
1	Long	0.0	70.0	70.0	PBR26

PANEL SHEAR:

System		---Offset---		-Shear(k)-		Panel_Shear(lb/ft)		
Id	Type	Start	End	Wind	Seis	Wind	Seis	Limit
-----	----	-----	-----	-----	-----	-----	-----	-----
1	Long	0.0	5.0	0.27	0.16	3.8	2.3	100.0
		5.0	10.0	0.86	0.29	12.2	4.1	100.0
		10.0	15.0	1.22	0.41	17.4	5.8	100.0
		15.0	20.0	1.58	0.53	22.6	7.6	100.0
		20.0	25.0	1.95	0.66	27.9	9.4	100.0
		25.0	30.0	2.33	0.78	33.3	11.1	100.0
		30.0	35.0	2.64	0.90	37.7	12.9	100.0
		35.0	40.0	2.26	0.78	32.3	11.1	100.0
		40.0	45.0	1.89	0.65	27.0	9.3	100.0
		45.0	50.0	1.52	0.53	21.8	7.6	100.0
		50.0	55.0	1.16	0.41	16.6	5.8	100.0
		55.0	60.0	0.81	0.28	11.5	4.1	100.0
		60.0	65.0	0.26	0.16	3.8	2.3	100.0

PANEL SHEAR:

Wall	Offset	Wall_Extents		Base Length	Panel Part	-Force(k)-		Panel_Shear(lb/ft)		
		Start	End			Wind	Seis	Wind	Seis	Limit
B_SW	0.0	0.0	70.0	Open						
Long	30.0	0.0	70.0	70.0	PBR29	5.34	1.91	76.3	27.3	100.0
F_SW	65.0	0.0	70.0	Open						
L_EW	0.0	0.0	65.0	65.0	CUSPANL	0.60	0.23	9.2	3.5	50.0
Tran	14.0	0.0	65.0	65.0	PBR29	1.20	0.35	18.4	5.4	100.0
Tran	28.0	0.0	65.0	65.0	PBR29	1.20	0.35	18.4	5.4	100.0
Tran	42.0	0.0	65.0	65.0	PBR29	1.20	0.35	18.4	5.4	100.0
Tran	56.0	0.0	65.0	65.0	PBR29	1.20	0.35	18.4	5.4	100.0
R_EW	70.0	0.0	65.0	65.0	CUSPANL	0.60	0.23	9.2	3.5	50.0

WALL LAYOUT:

Wall Id	Orn	Load Width
1	T	7.00

MEMBER LAYOUT:

Id	Locate		---Web(in)--		-Flange(in)-		Length (ft)	Weight (lb)	----Max_Load----		
	(ft)	Part	Depth	Thick	Width	Thick			Id	UC	Report
Col2	5.0	6X2C16	6.00	16ga	2.00	16ga	16.3	35.8	10	0.78	Deflect
Col3	10.0	6X2C16	6.00	16ga	2.00	16ga	16.5	36.2	10	0.77	Deflect
Col4	15.0	6X2C16	6.00	16ga	2.00	16ga	16.7	36.7	10	0.79	Deflect
Col5	20.0	6X2C16	6.00	16ga	2.00	16ga	17.0	37.1	10	0.82	Deflect
Col6	25.0	6X2C16	6.00	16ga	2.00	16ga	17.2	37.6	10	0.86	Deflect
Col7	30.0	6X2C16	6.00	16ga	2.00	16ga	17.3	37.9	1	0.10	Mom+Axl
Col8	35.0	6X2C16	6.00	16ga	2.00	16ga	17.2	37.6	10	0.86	Deflect
Col9	40.0	6X2C16	6.00	16ga	2.00	16ga	17.0	37.1	10	0.82	Deflect
Col10	45.0	6X2C16	6.00	16ga	2.00	16ga	16.7	36.7	10	0.79	Deflect
Col11	50.0	6X2C16	6.00	16ga	2.00	16ga	16.5	36.2	10	0.77	Deflect
Col12	55.0	6X2C16	6.00	16ga	2.00	16ga	16.3	35.8	10	0.74	Deflect
Col13	60.0	6X2C16	6.00	16ga	2.00	16ga	16.1	35.3	10	0.75	Deflect
Total=								440.0			

DESIGN ACTIONS/STRENGTH:

Id	Load Id	-Axial(k)-		-Shear(k)-		Moment(f-k)		-----Unity_Check-----			
		Calc	Limit	Calc	Limit	Calc	Limit	Axial	Shear	Moment	Shear+
Col2	1	0.83	7.45	0.00	3.32	0.00	2.65	0.11	0.00	0.11	0.00
Col2	2	0.13	7.45	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col2	3	0.60	7.45	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col2	4	0.60	7.45	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col2	5	0.66	7.45	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col2	6	0.48	7.45	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col2	7	0.48	7.45	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col2	8	-0.35	21.18	0.41	3.32	-1.68	2.65	0.02	0.12	0.62	0.00
Col2	9	-0.15	21.18	0.41	3.32	-1.68	2.65	0.01	0.12	0.63	0.00
Col2	10	-0.35	21.18	-0.48	3.32	1.95	2.65	0.02	0.14	0.72	0.00
Col2	11	-0.15	21.18	-0.48	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col2	12	-0.35	21.18	-0.48	3.32	1.95	2.65	0.02	0.14	0.72	0.00
Col2	13	-0.15	21.18	-0.48	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col2	14	-0.20	21.18	-0.48	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col2	15	-0.01	21.18	-0.48	3.32	1.95	2.65	0.00	0.14	0.74	0.00
Col2	16	0.42	7.45	-0.36	3.32	1.46	2.65	0.06	0.11	0.61	0.00
Col2	17	0.57	7.45	-0.36	3.32	1.46	2.65	0.08	0.11	0.63	0.00
Col2	18	0.31	7.45	-0.36	3.32	1.46	2.65	0.04	0.11	0.60	0.00
Col2	19	0.46	7.45	-0.36	3.32	1.46	2.65	0.06	0.11	0.61	0.00
Col2	20	0.25	7.45	-0.36	3.32	1.46	2.65	0.03	0.11	0.59	0.00
Col2	21	0.39	7.45	-0.36	3.32	1.46	2.65	0.05	0.11	0.61	0.00
Col2	22	0.14	7.45	-0.36	3.32	1.46	2.65	0.02	0.11	0.57	0.00
Col2	23	0.28	7.45	-0.36	3.32	1.46	2.65	0.04	0.11	0.59	0.00
Col2	24	0.25	7.45	-0.36	3.32	1.46	2.65	0.03	0.11	0.59	0.00
Col2	25	0.39	7.45	-0.36	3.32	1.46	2.65	0.05	0.11	0.61	0.00
Col2	26	0.14	7.45	-0.36	3.32	1.46	2.65	0.02	0.11	0.57	0.00
Col2	27	0.28	7.45	-0.36	3.32	1.46	2.65	0.04	0.11	0.59	0.00
Col2	28	-0.37	21.18	0.41	3.32	-1.68	2.65	0.02	0.12	0.62	0.00
Col2	29	-0.18	21.18	0.41	3.32	-1.68	2.65	0.01	0.12	0.63	0.00

Col2	30	-0.37	21.18	-0.48	3.32	1.95	2.65	0.02	0.14	0.72	0.00
Col2	31	-0.18	21.18	-0.48	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col2	32	-0.37	21.18	-0.48	3.32	1.95	2.65	0.02	0.14	0.72	0.00
Col2	33	-0.18	21.18	-0.48	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col2	34	-0.23	21.18	-0.48	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col2	35	-0.03	21.18	-0.48	3.32	1.95	2.65	0.00	0.14	0.74	0.00
Col2	36	0.14	7.45	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col2	37	0.14	7.45	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col2	38	0.66	7.45	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col2	39	0.66	7.45	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col2	40	0.49	7.45	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col2	41	0.49	7.45	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col2	42	0.49	7.45	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col2	43	0.49	7.45	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col2	44	0.08	7.45	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col2	45	0.08	7.45	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col2	46	0.69	7.45	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col2	47	0.32	7.45	-0.36	3.32	1.46	2.65	0.04	0.11	0.60	0.00
Col2	48	0.46	7.45	-0.36	3.32	1.46	2.65	0.06	0.11	0.62	0.00
Col2	49	0.13	7.45	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col2	50	0.13	7.45	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col2	51	0.09	7.45	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col2	52	0.09	7.45	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col2	53	0.61	7.45	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col2	54	0.49	7.45	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col2	55	0.49	7.45	-0.36	3.32	1.46	2.65	0.07	0.11	0.62	0.00
Col2	56	0.49	7.45	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col3	1	0.83	7.23	0.00	3.32	0.00	2.65	0.12	0.00	0.12	0.00
Col3	2	0.13	7.23	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col3	3	0.60	7.23	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col3	4	0.60	7.23	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col3	5	0.66	7.23	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col3	6	0.48	7.23	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col3	7	0.48	7.23	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col3	8	-0.34	21.18	0.42	3.32	-1.72	2.65	0.02	0.13	0.64	0.00
Col3	9	-0.15	21.18	0.42	3.32	-1.72	2.65	0.01	0.13	0.64	0.00
Col3	10	-0.34	21.18	-0.46	3.32	1.90	2.65	0.02	0.14	0.70	0.00
Col3	11	-0.15	21.18	-0.46	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col3	12	-0.34	21.18	-0.46	3.32	1.90	2.65	0.02	0.14	0.70	0.00
Col3	13	-0.15	21.18	-0.46	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col3	14	-0.20	21.18	-0.46	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col3	15	-0.01	21.18	-0.46	3.32	1.90	2.65	0.00	0.14	0.72	0.00
Col3	16	0.42	7.23	-0.34	3.32	1.42	2.65	0.06	0.10	0.60	0.00
Col3	17	0.57	7.23	-0.34	3.32	1.42	2.65	0.08	0.10	0.62	0.00
Col3	18	0.31	7.23	-0.34	3.32	1.42	2.65	0.04	0.10	0.58	0.00
Col3	19	0.46	7.23	-0.34	3.32	1.42	2.65	0.06	0.10	0.60	0.00
Col3	20	0.25	7.23	-0.34	3.32	1.42	2.65	0.03	0.10	0.57	0.00
Col3	21	0.39	7.23	-0.34	3.32	1.42	2.65	0.05	0.10	0.59	0.00
Col3	22	0.14	7.23	-0.34	3.32	1.42	2.65	0.02	0.10	0.56	0.00
Col3	23	0.28	7.23	-0.34	3.32	1.42	2.65	0.04	0.10	0.58	0.00
Col3	24	0.25	7.23	-0.34	3.32	1.42	2.65	0.03	0.10	0.57	0.00
Col3	25	0.39	7.23	-0.34	3.32	1.42	2.65	0.05	0.10	0.59	0.00
Col3	26	0.14	7.23	-0.34	3.32	1.42	2.65	0.02	0.10	0.56	0.00
Col3	27	0.28	7.23	-0.34	3.32	1.42	2.65	0.04	0.10	0.58	0.00
Col3	28	-0.37	21.18	0.42	3.32	-1.72	2.65	0.02	0.13	0.63	0.00
Col3	29	-0.18	21.18	0.42	3.32	-1.72	2.65	0.01	0.13	0.64	0.00
Col3	30	-0.37	21.18	-0.46	3.32	1.90	2.65	0.02	0.14	0.70	0.00
Col3	31	-0.18	21.18	-0.46	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col3	32	-0.37	21.18	-0.46	3.32	1.90	2.65	0.02	0.14	0.70	0.00
Col3	33	-0.18	21.18	-0.46	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col3	34	-0.23	21.18	-0.46	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col3	35	-0.03	21.18	-0.46	3.32	1.90	2.65	0.00	0.14	0.72	0.00
Col3	36	0.14	7.23	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col3	37	0.14	7.23	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col3	38	0.66	7.23	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00

Col3	39	0.66	7.23	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col3	40	0.49	7.23	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col3	41	0.49	7.23	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col3	42	0.49	7.23	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col3	43	0.49	7.23	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col3	44	0.09	7.23	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col3	45	0.09	7.23	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col3	46	0.69	7.23	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col3	47	0.32	7.23	-0.34	3.32	1.42	2.65	0.04	0.10	0.58	0.00
Col3	48	0.46	7.23	-0.34	3.32	1.42	2.65	0.06	0.10	0.60	0.00
Col3	49	0.13	7.23	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col3	50	0.13	7.23	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col3	51	0.09	7.23	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col3	52	0.09	7.23	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col3	53	0.73	7.23	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col3	54	0.58	7.23	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col3	55	0.58	7.23	-0.34	3.32	1.42	2.65	0.08	0.10	0.62	0.00
Col3	56	0.58	7.23	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col4	1	0.83	7.01	0.00	3.32	0.00	2.65	0.12	0.00	0.12	0.00
Col4	2	0.13	7.01	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col4	3	0.60	7.01	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col4	4	0.60	7.01	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col4	5	0.66	7.01	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col4	6	0.49	7.01	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col4	7	0.49	7.01	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col4	8	-0.34	21.18	0.42	3.32	-1.77	2.65	0.02	0.13	0.65	0.00
Col4	9	-0.15	21.18	0.42	3.32	-1.77	2.65	0.01	0.13	0.66	0.00
Col4	10	-0.34	21.18	-0.46	3.32	1.95	2.65	0.02	0.14	0.72	0.00
Col4	11	-0.15	21.18	-0.46	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col4	12	-0.34	21.18	-0.46	3.32	1.95	2.65	0.02	0.14	0.72	0.00
Col4	13	-0.15	21.18	-0.46	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col4	14	-0.20	21.18	-0.46	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col4	15	-0.01	21.18	-0.46	3.32	1.95	2.65	0.00	0.14	0.74	0.00
Col4	16	0.42	7.01	-0.35	3.32	1.46	2.65	0.06	0.11	0.61	0.00
Col4	17	0.57	7.01	-0.35	3.32	1.46	2.65	0.08	0.11	0.63	0.00
Col4	18	0.31	7.01	-0.35	3.32	1.46	2.65	0.04	0.11	0.60	0.00
Col4	19	0.46	7.01	-0.35	3.32	1.46	2.65	0.07	0.11	0.62	0.00
Col4	20	0.25	7.01	-0.35	3.32	1.46	2.65	0.04	0.11	0.59	0.00
Col4	21	0.39	7.01	-0.35	3.32	1.46	2.65	0.06	0.11	0.61	0.00
Col4	22	0.14	7.01	-0.35	3.32	1.46	2.65	0.02	0.11	0.57	0.00
Col4	23	0.29	7.01	-0.35	3.32	1.46	2.65	0.04	0.11	0.59	0.00
Col4	24	0.25	7.01	-0.35	3.32	1.46	2.65	0.04	0.11	0.59	0.00
Col4	25	0.39	7.01	-0.35	3.32	1.46	2.65	0.06	0.11	0.61	0.00
Col4	26	0.14	7.01	-0.35	3.32	1.46	2.65	0.02	0.11	0.57	0.00
Col4	27	0.29	7.01	-0.35	3.32	1.46	2.65	0.04	0.11	0.59	0.00
Col4	28	-0.37	21.18	0.42	3.32	-1.77	2.65	0.02	0.13	0.65	0.00
Col4	29	-0.18	21.18	0.42	3.32	-1.77	2.65	0.01	0.13	0.66	0.00
Col4	30	-0.37	21.18	-0.46	3.32	1.95	2.65	0.02	0.14	0.72	0.00
Col4	31	-0.18	21.18	-0.46	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col4	32	-0.37	21.18	-0.46	3.32	1.95	2.65	0.02	0.14	0.72	0.00
Col4	33	-0.18	21.18	-0.46	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col4	34	-0.23	21.18	-0.46	3.32	1.95	2.65	0.01	0.14	0.72	0.00
Col4	35	-0.03	21.18	-0.46	3.32	1.95	2.65	0.00	0.14	0.73	0.00
Col4	36	0.14	7.01	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col4	37	0.14	7.01	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col4	38	0.66	7.01	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col4	39	0.66	7.01	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col4	40	0.49	7.01	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col4	41	0.49	7.01	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col4	42	0.49	7.01	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col4	43	0.49	7.01	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col4	44	0.09	7.01	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col4	45	0.09	7.01	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col4	46	0.69	7.01	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col4	47	0.32	7.01	-0.35	3.32	1.46	2.65	0.05	0.11	0.60	0.00

Col14	48	0.46	7.01	-0.35	3.32	1.46	2.65	0.07	0.11	0.62	0.00
Col14	49	0.13	7.01	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col14	50	0.13	7.01	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col14	51	0.09	7.01	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col14	52	0.09	7.01	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col14	53	0.79	7.01	0.00	3.32	0.00	2.65	0.11	0.00	0.11	0.00
Col14	54	0.63	7.01	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col14	55	0.63	7.01	-0.35	3.32	1.46	2.65	0.09	0.11	0.64	0.00
Col14	56	0.63	7.01	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col15	1	0.83	6.79	0.00	3.32	0.00	2.65	0.12	0.00	0.12	0.00
Col15	2	0.13	6.79	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col15	3	0.60	6.79	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col15	4	0.60	6.79	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col15	5	0.66	6.79	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col15	6	0.49	6.79	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col15	7	0.49	6.79	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col15	8	-0.34	21.18	0.43	3.32	-1.81	2.65	0.02	0.13	0.67	0.00
Col15	9	-0.15	21.18	0.43	3.32	-1.81	2.65	0.01	0.13	0.68	0.00
Col15	10	-0.34	21.18	-0.47	3.32	2.00	2.65	0.02	0.14	0.74	0.00
Col15	11	-0.15	21.18	-0.47	3.32	2.00	2.65	0.01	0.14	0.75	0.00
Col15	12	-0.34	21.18	-0.47	3.32	2.00	2.65	0.02	0.14	0.74	0.00
Col15	13	-0.15	21.18	-0.47	3.32	2.00	2.65	0.01	0.14	0.75	0.00
Col15	14	-0.20	21.18	-0.47	3.32	2.00	2.65	0.01	0.14	0.74	0.00
Col15	15	0.00	21.18	-0.47	3.32	2.00	2.65	0.00	0.14	0.75	0.00
Col15	16	0.42	6.79	-0.35	3.32	1.50	2.65	0.06	0.11	0.63	0.00
Col15	17	0.57	6.79	-0.35	3.32	1.50	2.65	0.08	0.11	0.65	0.00
Col15	18	0.31	6.79	-0.35	3.32	1.50	2.65	0.05	0.11	0.61	0.00
Col15	19	0.46	6.79	-0.35	3.32	1.50	2.65	0.07	0.11	0.63	0.00
Col15	20	0.25	6.79	-0.35	3.32	1.50	2.65	0.04	0.11	0.60	0.00
Col15	21	0.39	6.79	-0.35	3.32	1.50	2.65	0.06	0.11	0.62	0.00
Col15	22	0.14	6.79	-0.35	3.32	1.50	2.65	0.02	0.11	0.59	0.00
Col15	23	0.29	6.79	-0.35	3.32	1.50	2.65	0.04	0.11	0.61	0.00
Col15	24	0.25	6.79	-0.35	3.32	1.50	2.65	0.04	0.11	0.60	0.00
Col15	25	0.39	6.79	-0.35	3.32	1.50	2.65	0.06	0.11	0.62	0.00
Col15	26	0.14	6.79	-0.35	3.32	1.50	2.65	0.02	0.11	0.59	0.00
Col15	27	0.29	6.79	-0.35	3.32	1.50	2.65	0.04	0.11	0.61	0.00
Col15	28	-0.37	21.18	0.43	3.32	-1.81	2.65	0.02	0.13	0.67	0.00
Col15	29	-0.18	21.18	0.43	3.32	-1.81	2.65	0.01	0.13	0.68	0.00
Col15	30	-0.37	21.18	-0.47	3.32	2.00	2.65	0.02	0.14	0.74	0.00
Col15	31	-0.18	21.18	-0.47	3.32	2.00	2.65	0.01	0.14	0.75	0.00
Col15	32	-0.37	21.18	-0.47	3.32	2.00	2.65	0.02	0.14	0.74	0.00
Col15	33	-0.18	21.18	-0.47	3.32	2.00	2.65	0.01	0.14	0.75	0.00
Col15	34	-0.23	21.18	-0.47	3.32	2.00	2.65	0.01	0.14	0.74	0.00
Col15	35	-0.03	21.18	-0.47	3.32	2.00	2.65	0.00	0.14	0.75	0.00
Col15	36	0.14	6.79	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col15	37	0.14	6.79	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col15	38	0.66	6.79	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col15	39	0.66	6.79	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col15	40	0.49	6.79	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col15	41	0.49	6.79	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col15	42	0.49	6.79	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col15	43	0.49	6.79	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col15	44	0.09	6.79	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col15	45	0.09	6.79	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col15	46	0.69	6.79	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col15	47	0.32	6.79	-0.35	3.32	1.50	2.65	0.05	0.11	0.61	0.00
Col15	48	0.46	6.79	-0.35	3.32	1.50	2.65	0.07	0.11	0.63	0.00
Col15	49	0.13	6.79	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col15	50	0.13	6.79	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col15	51	0.09	6.79	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col15	52	0.09	6.79	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col15	53	0.79	6.79	0.00	3.32	0.00	2.65	0.12	0.00	0.12	0.00
Col15	54	0.63	6.79	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col15	55	0.63	6.79	-0.35	3.32	1.50	2.65	0.09	0.11	0.66	0.00
Col15	56	0.63	6.79	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00

Col6	1	0.83	6.57	0.00	3.32	0.00	2.65	0.13	0.00	0.13	0.00
Col6	2	0.13	6.57	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col6	3	0.60	6.57	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col6	4	0.60	6.57	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col6	5	0.66	6.57	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col6	6	0.49	6.57	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col6	7	0.49	6.57	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col6	8	-0.34	21.18	0.43	3.32	-1.86	2.65	0.02	0.13	0.69	0.00
Col6	9	-0.15	21.18	0.43	3.32	-1.86	2.65	0.01	0.13	0.69	0.00
Col6	10	-0.34	21.18	-0.48	3.32	2.04	2.65	0.02	0.14	0.76	0.00
Col6	11	-0.15	21.18	-0.48	3.32	2.04	2.65	0.01	0.14	0.77	0.00
Col6	12	-0.34	21.18	-0.48	3.32	2.04	2.65	0.02	0.14	0.76	0.00
Col6	13	-0.15	21.18	-0.48	3.32	2.04	2.65	0.01	0.14	0.77	0.00
Col6	14	-0.20	21.18	-0.48	3.32	2.04	2.65	0.01	0.14	0.76	0.00
Col6	15	0.00	21.18	-0.48	3.32	2.04	2.65	0.00	0.14	0.77	0.00
Col6	16	0.42	6.57	-0.36	3.32	1.53	2.65	0.06	0.11	0.64	0.00
Col6	17	0.57	6.57	-0.36	3.32	1.53	2.65	0.09	0.11	0.67	0.00
Col6	18	0.31	6.57	-0.36	3.32	1.53	2.65	0.05	0.11	0.63	0.00
Col6	19	0.46	6.57	-0.36	3.32	1.53	2.65	0.07	0.11	0.65	0.00
Col6	20	0.25	6.57	-0.36	3.32	1.53	2.65	0.04	0.11	0.62	0.00
Col6	21	0.40	6.57	-0.36	3.32	1.53	2.65	0.06	0.11	0.64	0.00
Col6	22	0.14	6.57	-0.36	3.32	1.53	2.65	0.02	0.11	0.60	0.00
Col6	23	0.29	6.57	-0.36	3.32	1.53	2.65	0.04	0.11	0.62	0.00
Col6	24	0.25	6.57	-0.36	3.32	1.53	2.65	0.04	0.11	0.62	0.00
Col6	25	0.40	6.57	-0.36	3.32	1.53	2.65	0.06	0.11	0.64	0.00
Col6	26	0.14	6.57	-0.36	3.32	1.53	2.65	0.02	0.11	0.60	0.00
Col6	27	0.29	6.57	-0.36	3.32	1.53	2.65	0.04	0.11	0.62	0.00
Col6	28	-0.37	21.18	0.43	3.32	-1.86	2.65	0.02	0.13	0.68	0.00
Col6	29	-0.18	21.18	0.43	3.32	-1.86	2.65	0.01	0.13	0.69	0.00
Col6	30	-0.37	21.18	-0.48	3.32	2.04	2.65	0.02	0.14	0.75	0.00
Col6	31	-0.18	21.18	-0.48	3.32	2.04	2.65	0.01	0.14	0.76	0.00
Col6	32	-0.37	21.18	-0.48	3.32	2.04	2.65	0.02	0.14	0.75	0.00
Col6	33	-0.18	21.18	-0.48	3.32	2.04	2.65	0.01	0.14	0.76	0.00
Col6	34	-0.23	21.18	-0.48	3.32	2.04	2.65	0.01	0.14	0.76	0.00
Col6	35	-0.03	21.18	-0.48	3.32	2.04	2.65	0.00	0.14	0.77	0.00
Col6	36	0.14	6.57	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col6	37	0.14	6.57	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col6	38	0.66	6.57	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col6	39	0.66	6.57	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col6	40	0.49	6.57	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col6	41	0.49	6.57	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col6	42	0.49	6.57	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col6	43	0.49	6.57	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col6	44	0.09	6.57	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col6	45	0.09	6.57	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col6	46	0.69	6.57	0.00	3.32	0.00	2.65	0.11	0.00	0.11	0.00
Col6	47	0.32	6.57	-0.36	3.32	1.53	2.65	0.05	0.11	0.63	0.00
Col6	48	0.46	6.57	-0.36	3.32	1.53	2.65	0.07	0.11	0.65	0.00
Col6	49	0.13	6.57	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col6	50	0.13	6.57	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col6	51	0.09	6.57	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col6	52	0.09	6.57	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col6	53	0.79	6.57	0.00	3.32	0.00	2.65	0.12	0.00	0.12	0.00
Col6	54	0.63	6.57	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col6	55	0.63	6.57	-0.36	3.32	1.53	2.65	0.10	0.11	0.68	0.00
Col6	56	0.63	6.57	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col7	1	0.83	8.50	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col7	2	0.13	8.50	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col7	3	0.60	8.50	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col7	4	0.60	8.50	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col7	5	0.66	8.50	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col7	6	0.49	8.50	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col7	7	0.49	8.50	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col7	8	-0.24	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col7	9	-0.24	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00

Col7	10	-0.24	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col7	11	-0.24	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col7	12	-0.24	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col7	13	-0.24	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col7	14	-0.10	21.18	0.00	3.32	0.00	2.65	0.00	0.00	0.00	0.00
Col7	15	-0.10	21.18	0.00	3.32	0.00	2.65	0.00	0.00	0.00	0.00
Col7	16	0.50	8.50	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col7	17	0.50	8.50	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col7	18	0.39	8.50	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col7	19	0.39	8.50	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col7	20	0.32	8.50	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col7	21	0.32	8.50	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col7	22	0.22	8.50	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col7	23	0.22	8.50	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col7	24	0.32	8.50	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col7	25	0.32	8.50	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col7	26	0.22	8.50	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col7	27	0.22	8.50	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col7	28	-0.27	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col7	29	-0.27	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col7	30	-0.27	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col7	31	-0.27	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col7	32	-0.27	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col7	33	-0.27	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col7	34	-0.13	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col7	35	-0.13	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col7	36	0.14	8.50	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col7	37	0.14	8.50	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col7	38	0.66	8.50	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col7	39	0.66	8.50	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col7	40	0.49	8.50	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col7	41	0.49	8.50	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col7	42	0.49	8.50	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col7	43	0.49	8.50	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col7	44	0.09	8.50	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col7	45	0.09	8.50	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col7	46	0.68	8.50	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col7	47	0.38	8.50	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col7	48	0.38	8.50	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col7	49	0.13	8.50	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col7	50	0.13	8.50	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col7	51	0.09	8.50	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col7	52	0.09	8.50	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col7	53	0.77	8.50	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col7	54	0.61	8.50	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col7	55	0.61	8.50	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col7	56	0.61	8.50	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col8	1	0.83	6.57	0.00	3.32	0.00	2.65	0.13	0.00	0.13	0.00
Col8	2	0.13	6.57	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col8	3	0.60	6.57	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col8	4	0.60	6.57	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col8	5	0.66	6.57	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col8	6	0.49	6.57	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col8	7	0.49	6.57	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col8	8	-0.15	21.18	0.43	3.32	-1.86	2.65	0.01	0.13	0.69	0.00
Col8	9	-0.34	21.18	0.43	3.32	-1.86	2.65	0.02	0.13	0.69	0.00
Col8	10	-0.15	21.18	-0.48	3.32	2.04	2.65	0.01	0.14	0.77	0.00
Col8	11	-0.34	21.18	-0.48	3.32	2.04	2.65	0.02	0.14	0.76	0.00
Col8	12	-0.15	21.18	-0.48	3.32	2.04	2.65	0.01	0.14	0.77	0.00
Col8	13	-0.34	21.18	-0.48	3.32	2.04	2.65	0.02	0.14	0.76	0.00
Col8	14	0.00	21.18	-0.48	3.32	2.04	2.65	0.00	0.14	0.77	0.00
Col8	15	-0.20	21.18	-0.48	3.32	2.04	2.65	0.01	0.14	0.76	0.00
Col8	16	0.57	6.57	-0.36	3.32	1.53	2.65	0.09	0.11	0.67	0.00
Col8	17	0.42	6.57	-0.36	3.32	1.53	2.65	0.06	0.11	0.64	0.00
Col8	18	0.46	6.57	-0.36	3.32	1.53	2.65	0.07	0.11	0.65	0.00

Col8	19	0.31	6.57	-0.36	3.32	1.53	2.65	0.05	0.11	0.63	0.00
Col8	20	0.40	6.57	-0.36	3.32	1.53	2.65	0.06	0.11	0.64	0.00
Col8	21	0.25	6.57	-0.36	3.32	1.53	2.65	0.04	0.11	0.62	0.00
Col8	22	0.29	6.57	-0.36	3.32	1.53	2.65	0.04	0.11	0.62	0.00
Col8	23	0.14	6.57	-0.36	3.32	1.53	2.65	0.02	0.11	0.60	0.00
Col8	24	0.40	6.57	-0.36	3.32	1.53	2.65	0.06	0.11	0.64	0.00
Col8	25	0.25	6.57	-0.36	3.32	1.53	2.65	0.04	0.11	0.62	0.00
Col8	26	0.29	6.57	-0.36	3.32	1.53	2.65	0.04	0.11	0.62	0.00
Col8	27	0.14	6.57	-0.36	3.32	1.53	2.65	0.02	0.11	0.60	0.00
Col8	28	-0.18	21.18	0.43	3.32	-1.86	2.65	0.01	0.13	0.69	0.00
Col8	29	-0.37	21.18	0.43	3.32	-1.86	2.65	0.02	0.13	0.68	0.00
Col8	30	-0.18	21.18	-0.48	3.32	2.04	2.65	0.01	0.14	0.76	0.00
Col8	31	-0.37	21.18	-0.48	3.32	2.04	2.65	0.02	0.14	0.75	0.00
Col8	32	-0.18	21.18	-0.48	3.32	2.04	2.65	0.01	0.14	0.76	0.00
Col8	33	-0.37	21.18	-0.48	3.32	2.04	2.65	0.02	0.14	0.75	0.00
Col8	34	-0.03	21.18	-0.48	3.32	2.04	2.65	0.00	0.14	0.77	0.00
Col8	35	-0.23	21.18	-0.48	3.32	2.04	2.65	0.01	0.14	0.76	0.00
Col8	36	0.14	6.57	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col8	37	0.14	6.57	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col8	38	0.66	6.57	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col8	39	0.66	6.57	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col8	40	0.49	6.57	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col8	41	0.49	6.57	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col8	42	0.49	6.57	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col8	43	0.49	6.57	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col8	44	0.09	6.57	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col8	45	0.09	6.57	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col8	46	0.69	6.57	0.00	3.32	0.00	2.65	0.11	0.00	0.11	0.00
Col8	47	0.46	6.57	-0.36	3.32	1.53	2.65	0.07	0.11	0.65	0.00
Col8	48	0.32	6.57	-0.36	3.32	1.53	2.65	0.05	0.11	0.63	0.00
Col8	49	0.13	6.57	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col8	50	0.13	6.57	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col8	51	0.09	6.57	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col8	52	0.09	6.57	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col8	53	0.78	6.57	0.00	3.32	0.00	2.65	0.12	0.00	0.12	0.00
Col8	54	0.62	6.57	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col8	55	0.62	6.57	-0.36	3.32	1.53	2.65	0.09	0.11	0.67	0.00
Col8	56	0.62	6.57	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col9	1	0.83	6.79	0.00	3.32	0.00	2.65	0.12	0.00	0.12	0.00
Col9	2	0.13	6.79	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col9	3	0.60	6.79	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col9	4	0.60	6.79	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col9	5	0.66	6.79	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col9	6	0.49	6.79	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col9	7	0.49	6.79	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col9	8	-0.15	21.18	0.43	3.32	-1.81	2.65	0.01	0.13	0.68	0.00
Col9	9	-0.34	21.18	0.43	3.32	-1.81	2.65	0.02	0.13	0.67	0.00
Col9	10	-0.15	21.18	-0.47	3.32	2.00	2.65	0.01	0.14	0.75	0.00
Col9	11	-0.34	21.18	-0.47	3.32	2.00	2.65	0.02	0.14	0.74	0.00
Col9	12	-0.15	21.18	-0.47	3.32	2.00	2.65	0.01	0.14	0.75	0.00
Col9	13	-0.34	21.18	-0.47	3.32	2.00	2.65	0.02	0.14	0.74	0.00
Col9	14	0.00	21.18	-0.47	3.32	2.00	2.65	0.00	0.14	0.75	0.00
Col9	15	-0.20	21.18	-0.47	3.32	2.00	2.65	0.01	0.14	0.74	0.00
Col9	16	0.57	6.79	-0.35	3.32	1.50	2.65	0.08	0.11	0.65	0.00
Col9	17	0.42	6.79	-0.35	3.32	1.50	2.65	0.06	0.11	0.63	0.00
Col9	18	0.46	6.79	-0.35	3.32	1.50	2.65	0.07	0.11	0.63	0.00
Col9	19	0.31	6.79	-0.35	3.32	1.50	2.65	0.05	0.11	0.61	0.00
Col9	20	0.39	6.79	-0.35	3.32	1.50	2.65	0.06	0.11	0.62	0.00
Col9	21	0.25	6.79	-0.35	3.32	1.50	2.65	0.04	0.11	0.60	0.00
Col9	22	0.29	6.79	-0.35	3.32	1.50	2.65	0.04	0.11	0.61	0.00
Col9	23	0.14	6.79	-0.35	3.32	1.50	2.65	0.02	0.11	0.59	0.00
Col9	24	0.39	6.79	-0.35	3.32	1.50	2.65	0.06	0.11	0.62	0.00
Col9	25	0.25	6.79	-0.35	3.32	1.50	2.65	0.04	0.11	0.60	0.00
Col9	26	0.29	6.79	-0.35	3.32	1.50	2.65	0.04	0.11	0.61	0.00
Col9	27	0.14	6.79	-0.35	3.32	1.50	2.65	0.02	0.11	0.59	0.00

Col19	28	-0.18	21.18	0.43	3.32	-1.81	2.65	0.01	0.13	0.68	0.00
Col19	29	-0.37	21.18	0.43	3.32	-1.81	2.65	0.02	0.13	0.67	0.00
Col19	30	-0.18	21.18	-0.47	3.32	2.00	2.65	0.01	0.14	0.75	0.00
Col19	31	-0.37	21.18	-0.47	3.32	2.00	2.65	0.02	0.14	0.74	0.00
Col19	32	-0.18	21.18	-0.47	3.32	2.00	2.65	0.01	0.14	0.75	0.00
Col19	33	-0.37	21.18	-0.47	3.32	2.00	2.65	0.02	0.14	0.74	0.00
Col19	34	-0.03	21.18	-0.47	3.32	2.00	2.65	0.00	0.14	0.75	0.00
Col19	35	-0.23	21.18	-0.47	3.32	2.00	2.65	0.01	0.14	0.74	0.00
Col19	36	0.14	6.79	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col19	37	0.14	6.79	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col19	38	0.66	6.79	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col19	39	0.66	6.79	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col19	40	0.49	6.79	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col19	41	0.49	6.79	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col19	42	0.49	6.79	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col19	43	0.49	6.79	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col19	44	0.09	6.79	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col19	45	0.09	6.79	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col19	46	0.69	6.79	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col19	47	0.46	6.79	-0.35	3.32	1.50	2.65	0.07	0.11	0.63	0.00
Col19	48	0.32	6.79	-0.35	3.32	1.50	2.65	0.05	0.11	0.61	0.00
Col19	49	0.13	6.79	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col19	50	0.13	6.79	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col19	51	0.09	6.79	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col19	52	0.09	6.79	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col19	53	0.78	6.79	0.00	3.32	0.00	2.65	0.11	0.00	0.11	0.00
Col19	54	0.62	6.79	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col19	55	0.62	6.79	-0.35	3.32	1.50	2.65	0.09	0.11	0.66	0.00
Col19	56	0.62	6.79	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col110	1	0.83	7.01	0.00	3.32	0.00	2.65	0.12	0.00	0.12	0.00
Col110	2	0.13	7.01	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col110	3	0.60	7.01	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col110	4	0.60	7.01	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col110	5	0.66	7.01	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col110	6	0.49	7.01	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col110	7	0.49	7.01	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col110	8	-0.15	21.18	0.42	3.32	-1.77	2.65	0.01	0.13	0.66	0.00
Col110	9	-0.34	21.18	0.42	3.32	-1.77	2.65	0.02	0.13	0.65	0.00
Col110	10	-0.15	21.18	-0.46	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col110	11	-0.34	21.18	-0.46	3.32	1.95	2.65	0.02	0.14	0.72	0.00
Col110	12	-0.15	21.18	-0.46	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col110	13	-0.34	21.18	-0.46	3.32	1.95	2.65	0.02	0.14	0.72	0.00
Col110	14	-0.01	21.18	-0.46	3.32	1.95	2.65	0.00	0.14	0.74	0.00
Col110	15	-0.20	21.18	-0.46	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col110	16	0.57	7.01	-0.35	3.32	1.46	2.65	0.08	0.11	0.63	0.00
Col110	17	0.42	7.01	-0.35	3.32	1.46	2.65	0.06	0.11	0.61	0.00
Col110	18	0.46	7.01	-0.35	3.32	1.46	2.65	0.07	0.11	0.62	0.00
Col110	19	0.31	7.01	-0.35	3.32	1.46	2.65	0.04	0.11	0.60	0.00
Col110	20	0.39	7.01	-0.35	3.32	1.46	2.65	0.06	0.11	0.61	0.00
Col110	21	0.25	7.01	-0.35	3.32	1.46	2.65	0.04	0.11	0.59	0.00
Col110	22	0.29	7.01	-0.35	3.32	1.46	2.65	0.04	0.11	0.59	0.00
Col110	23	0.14	7.01	-0.35	3.32	1.46	2.65	0.02	0.11	0.57	0.00
Col110	24	0.39	7.01	-0.35	3.32	1.46	2.65	0.06	0.11	0.61	0.00
Col110	25	0.25	7.01	-0.35	3.32	1.46	2.65	0.04	0.11	0.59	0.00
Col110	26	0.29	7.01	-0.35	3.32	1.46	2.65	0.04	0.11	0.59	0.00
Col110	27	0.14	7.01	-0.35	3.32	1.46	2.65	0.02	0.11	0.57	0.00
Col110	28	-0.18	21.18	0.42	3.32	-1.77	2.65	0.01	0.13	0.66	0.00
Col110	29	-0.37	21.18	0.42	3.32	-1.77	2.65	0.02	0.13	0.65	0.00
Col110	30	-0.18	21.18	-0.46	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col110	31	-0.37	21.18	-0.46	3.32	1.95	2.65	0.02	0.14	0.72	0.00
Col110	32	-0.18	21.18	-0.46	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col110	33	-0.37	21.18	-0.46	3.32	1.95	2.65	0.02	0.14	0.72	0.00
Col110	34	-0.03	21.18	-0.46	3.32	1.95	2.65	0.00	0.14	0.73	0.00
Col110	35	-0.23	21.18	-0.46	3.32	1.95	2.65	0.01	0.14	0.72	0.00
Col110	36	0.14	7.01	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00

Col110	37	0.14	7.01	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col110	38	0.66	7.01	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col110	39	0.66	7.01	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col110	40	0.49	7.01	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col110	41	0.49	7.01	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col110	42	0.49	7.01	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col110	43	0.49	7.01	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col110	44	0.09	7.01	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col110	45	0.09	7.01	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col110	46	0.69	7.01	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col110	47	0.46	7.01	-0.35	3.32	1.46	2.65	0.07	0.11	0.62	0.00
Col110	48	0.32	7.01	-0.35	3.32	1.46	2.65	0.05	0.11	0.60	0.00
Col110	49	0.13	7.01	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col110	50	0.13	7.01	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col110	51	0.09	7.01	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col110	52	0.09	7.01	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col110	53	0.77	7.01	0.00	3.32	0.00	2.65	0.11	0.00	0.11	0.00
Col110	54	0.61	7.01	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col110	55	0.61	7.01	-0.35	3.32	1.46	2.65	0.09	0.11	0.64	0.00
Col110	56	0.62	7.01	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col111	1	0.83	7.23	0.00	3.32	0.00	2.65	0.12	0.00	0.12	0.00
Col111	2	0.13	7.23	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col111	3	0.60	7.23	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col111	4	0.60	7.23	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col111	5	0.66	7.23	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col111	6	0.48	7.23	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col111	7	0.48	7.23	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col111	8	-0.15	21.18	0.42	3.32	-1.72	2.65	0.01	0.13	0.64	0.00
Col111	9	-0.34	21.18	0.42	3.32	-1.72	2.65	0.02	0.13	0.64	0.00
Col111	10	-0.15	21.18	-0.46	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col111	11	-0.34	21.18	-0.46	3.32	1.90	2.65	0.02	0.14	0.70	0.00
Col111	12	-0.15	21.18	-0.46	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col111	13	-0.34	21.18	-0.46	3.32	1.90	2.65	0.02	0.14	0.70	0.00
Col111	14	-0.01	21.18	-0.46	3.32	1.90	2.65	0.00	0.14	0.72	0.00
Col111	15	-0.20	21.18	-0.46	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col111	16	0.57	7.23	-0.34	3.32	1.42	2.65	0.08	0.10	0.62	0.00
Col111	17	0.42	7.23	-0.34	3.32	1.42	2.65	0.06	0.10	0.60	0.00
Col111	18	0.46	7.23	-0.34	3.32	1.42	2.65	0.06	0.10	0.60	0.00
Col111	19	0.31	7.23	-0.34	3.32	1.42	2.65	0.04	0.10	0.58	0.00
Col111	20	0.39	7.23	-0.34	3.32	1.42	2.65	0.05	0.10	0.59	0.00
Col111	21	0.25	7.23	-0.34	3.32	1.42	2.65	0.03	0.10	0.57	0.00
Col111	22	0.28	7.23	-0.34	3.32	1.42	2.65	0.04	0.10	0.58	0.00
Col111	23	0.14	7.23	-0.34	3.32	1.42	2.65	0.02	0.10	0.56	0.00
Col111	24	0.39	7.23	-0.34	3.32	1.42	2.65	0.05	0.10	0.59	0.00
Col111	25	0.25	7.23	-0.34	3.32	1.42	2.65	0.03	0.10	0.57	0.00
Col111	26	0.28	7.23	-0.34	3.32	1.42	2.65	0.04	0.10	0.58	0.00
Col111	27	0.14	7.23	-0.34	3.32	1.42	2.65	0.02	0.10	0.56	0.00
Col111	28	-0.18	21.18	0.42	3.32	-1.72	2.65	0.01	0.13	0.64	0.00
Col111	29	-0.37	21.18	0.42	3.32	-1.72	2.65	0.02	0.13	0.63	0.00
Col111	30	-0.18	21.18	-0.46	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col111	31	-0.37	21.18	-0.46	3.32	1.90	2.65	0.02	0.14	0.70	0.00
Col111	32	-0.18	21.18	-0.46	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col111	33	-0.37	21.18	-0.46	3.32	1.90	2.65	0.02	0.14	0.70	0.00
Col111	34	-0.03	21.18	-0.46	3.32	1.90	2.65	0.00	0.14	0.72	0.00
Col111	35	-0.23	21.18	-0.46	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col111	36	0.14	7.23	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col111	37	0.14	7.23	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col111	38	0.66	7.23	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col111	39	0.66	7.23	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col111	40	0.49	7.23	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col111	41	0.49	7.23	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col111	42	0.49	7.23	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col111	43	0.49	7.23	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col111	44	0.09	7.23	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col111	45	0.09	7.23	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00

Col11	46	0.69	7.23	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col11	47	0.46	7.23	-0.34	3.32	1.42	2.65	0.06	0.10	0.60	0.00
Col11	48	0.32	7.23	-0.34	3.32	1.42	2.65	0.04	0.10	0.58	0.00
Col11	49	0.13	7.23	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col11	50	0.13	7.23	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col11	51	0.09	7.23	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col11	52	0.09	7.23	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col11	53	0.66	7.23	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col11	54	0.53	7.23	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col11	55	0.53	7.23	-0.34	3.32	1.42	2.65	0.07	0.10	0.61	0.00
Col11	56	0.53	7.23	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col12	1	0.83	7.45	0.00	3.32	0.00	2.65	0.11	0.00	0.11	0.00
Col12	2	0.13	7.45	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col12	3	0.60	7.45	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col12	4	0.60	7.45	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col12	5	0.66	7.45	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col12	6	0.48	7.45	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col12	7	0.48	7.45	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col12	8	-0.15	21.18	0.41	3.32	-1.68	2.65	0.01	0.12	0.63	0.00
Col12	9	-0.35	21.18	0.41	3.32	-1.68	2.65	0.02	0.12	0.62	0.00
Col12	10	-0.15	21.18	-0.45	3.32	1.85	2.65	0.01	0.14	0.69	0.00
Col12	11	-0.35	21.18	-0.45	3.32	1.85	2.65	0.02	0.14	0.68	0.00
Col12	12	-0.15	21.18	-0.45	3.32	1.85	2.65	0.01	0.14	0.69	0.00
Col12	13	-0.35	21.18	-0.45	3.32	1.85	2.65	0.02	0.14	0.68	0.00
Col12	14	-0.01	21.18	-0.45	3.32	1.85	2.65	0.00	0.14	0.70	0.00
Col12	15	-0.20	21.18	-0.45	3.32	1.85	2.65	0.01	0.14	0.69	0.00
Col12	16	0.57	7.45	-0.34	3.32	1.39	2.65	0.08	0.10	0.60	0.00
Col12	17	0.42	7.45	-0.34	3.32	1.39	2.65	0.06	0.10	0.58	0.00
Col12	18	0.46	7.45	-0.34	3.32	1.39	2.65	0.06	0.10	0.59	0.00
Col12	19	0.31	7.45	-0.34	3.32	1.39	2.65	0.04	0.10	0.57	0.00
Col12	20	0.39	7.45	-0.34	3.32	1.39	2.65	0.05	0.10	0.58	0.00
Col12	21	0.25	7.45	-0.34	3.32	1.39	2.65	0.03	0.10	0.56	0.00
Col12	22	0.28	7.45	-0.34	3.32	1.39	2.65	0.04	0.10	0.56	0.00
Col12	23	0.14	7.45	-0.34	3.32	1.39	2.65	0.02	0.10	0.54	0.00
Col12	24	0.39	7.45	-0.34	3.32	1.39	2.65	0.05	0.10	0.58	0.00
Col12	25	0.25	7.45	-0.34	3.32	1.39	2.65	0.03	0.10	0.56	0.00
Col12	26	0.28	7.45	-0.34	3.32	1.39	2.65	0.04	0.10	0.56	0.00
Col12	27	0.14	7.45	-0.34	3.32	1.39	2.65	0.02	0.10	0.54	0.00
Col12	28	-0.18	21.18	0.41	3.32	-1.68	2.65	0.01	0.12	0.63	0.00
Col12	29	-0.37	21.18	0.41	3.32	-1.68	2.65	0.02	0.12	0.62	0.00
Col12	30	-0.18	21.18	-0.45	3.32	1.85	2.65	0.01	0.14	0.69	0.00
Col12	31	-0.37	21.18	-0.45	3.32	1.85	2.65	0.02	0.14	0.68	0.00
Col12	32	-0.18	21.18	-0.45	3.32	1.85	2.65	0.01	0.14	0.69	0.00
Col12	33	-0.37	21.18	-0.45	3.32	1.85	2.65	0.02	0.14	0.68	0.00
Col12	34	-0.03	21.18	-0.45	3.32	1.85	2.65	0.00	0.14	0.70	0.00
Col12	35	-0.23	21.18	-0.45	3.32	1.85	2.65	0.01	0.14	0.69	0.00
Col12	36	0.14	7.45	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col12	37	0.14	7.45	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col12	38	0.66	7.45	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col12	39	0.66	7.45	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col12	40	0.49	7.45	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col12	41	0.49	7.45	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col12	42	0.49	7.45	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col12	43	0.49	7.45	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col12	44	0.08	7.45	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col12	45	0.08	7.45	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col12	46	0.69	7.45	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col12	47	0.46	7.45	-0.34	3.32	1.39	2.65	0.06	0.10	0.59	0.00
Col12	48	0.32	7.45	-0.34	3.32	1.39	2.65	0.04	0.10	0.57	0.00
Col12	49	0.13	7.45	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col12	50	0.13	7.45	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col12	51	0.09	7.45	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col12	52	0.09	7.45	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col12	53	0.60	7.45	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col12	54	0.49	7.45	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00

Col12	55	0.49	7.45	-0.34	3.32	1.39	2.65	0.07	0.10	0.59	0.00
Col12	56	0.49	7.45	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col13	1	0.83	7.66	0.00	3.32	0.00	2.65	0.11	0.00	0.11	0.00
Col13	2	0.13	7.66	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col13	3	0.60	7.66	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col13	4	0.60	7.66	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col13	5	0.66	7.66	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col13	6	0.48	7.66	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col13	7	0.48	7.66	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col13	8	-0.15	21.18	0.41	3.32	-1.64	2.65	0.01	0.12	0.61	0.00
Col13	9	-0.35	21.18	0.41	3.32	-1.64	2.65	0.02	0.12	0.60	0.00
Col13	10	-0.15	21.18	-0.47	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col13	11	-0.35	21.18	-0.47	3.32	1.90	2.65	0.02	0.14	0.70	0.00
Col13	12	-0.15	21.18	-0.47	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col13	13	-0.35	21.18	-0.47	3.32	1.90	2.65	0.02	0.14	0.70	0.00
Col13	14	-0.01	21.18	-0.47	3.32	1.90	2.65	0.00	0.14	0.72	0.00
Col13	15	-0.20	21.18	-0.47	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col13	16	0.57	7.66	-0.35	3.32	1.43	2.65	0.07	0.11	0.61	0.00
Col13	17	0.42	7.66	-0.35	3.32	1.43	2.65	0.05	0.11	0.59	0.00
Col13	18	0.46	7.66	-0.35	3.32	1.43	2.65	0.06	0.11	0.60	0.00
Col13	19	0.31	7.66	-0.35	3.32	1.43	2.65	0.04	0.11	0.58	0.00
Col13	20	0.39	7.66	-0.35	3.32	1.43	2.65	0.05	0.11	0.59	0.00
Col13	21	0.25	7.66	-0.35	3.32	1.43	2.65	0.03	0.11	0.57	0.00
Col13	22	0.28	7.66	-0.35	3.32	1.43	2.65	0.04	0.11	0.58	0.00
Col13	23	0.14	7.66	-0.35	3.32	1.43	2.65	0.02	0.11	0.56	0.00
Col13	24	0.39	7.66	-0.35	3.32	1.43	2.65	0.05	0.11	0.59	0.00
Col13	25	0.25	7.66	-0.35	3.32	1.43	2.65	0.03	0.11	0.57	0.00
Col13	26	0.28	7.66	-0.35	3.32	1.43	2.65	0.04	0.11	0.58	0.00
Col13	27	0.14	7.66	-0.35	3.32	1.43	2.65	0.02	0.11	0.56	0.00
Col13	28	-0.18	21.18	0.41	3.32	-1.64	2.65	0.01	0.12	0.61	0.00
Col13	29	-0.37	21.18	0.41	3.32	-1.64	2.65	0.02	0.12	0.60	0.00
Col13	30	-0.18	21.18	-0.47	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col13	31	-0.37	21.18	-0.47	3.32	1.90	2.65	0.02	0.14	0.70	0.00
Col13	32	-0.18	21.18	-0.47	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col13	33	-0.37	21.18	-0.47	3.32	1.90	2.65	0.02	0.14	0.70	0.00
Col13	34	-0.03	21.18	-0.47	3.32	1.90	2.65	0.00	0.14	0.72	0.00
Col13	35	-0.23	21.18	-0.47	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col13	36	0.13	7.66	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col13	37	0.13	7.66	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col13	38	0.66	7.66	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col13	39	0.66	7.66	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col13	40	0.49	7.66	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col13	41	0.49	7.66	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col13	42	0.49	7.66	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col13	43	0.49	7.66	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col13	44	0.08	7.66	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col13	45	0.08	7.66	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col13	46	0.69	7.66	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col13	47	0.46	7.66	-0.35	3.32	1.43	2.65	0.06	0.11	0.60	0.00
Col13	48	0.32	7.66	-0.35	3.32	1.43	2.65	0.04	0.11	0.58	0.00
Col13	49	0.13	7.66	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col13	50	0.13	7.66	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col13	51	0.09	7.66	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col13	52	0.09	7.66	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col13	53	0.60	7.66	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col13	54	0.49	7.66	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col13	55	0.49	7.66	-0.35	3.32	1.43	2.65	0.06	0.11	0.60	0.00
Col13	56	0.49	7.66	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00

COLUMN REACTIONS:

Id	Load		In_Plane		Out_Plane
	Id	Vert (k)	Horz (k)	Horz (k)	
Col2	1	0.83	0.00	0.00	

Col2	2	0.13	0.00	0.00
Col2	3	0.60	0.00	0.00
Col2	4	0.60	0.00	0.00
Col2	5	0.66	0.00	0.00
Col2	6	0.48	0.00	0.00
Col2	7	0.48	0.00	0.00
Col2	8	-0.35	0.00	-0.41
Col2	9	-0.15	0.00	-0.41
Col2	10	-0.35	0.00	0.48
Col2	11	-0.15	0.00	0.48
Col2	12	-0.35	0.00	0.48
Col2	13	-0.15	0.00	0.48
Col2	14	-0.20	0.00	0.48
Col2	15	-0.01	0.00	0.48
Col2	16	0.42	0.00	0.36
Col2	17	0.57	0.00	0.36
Col2	18	0.31	0.00	0.36
Col2	19	0.46	0.00	0.36
Col2	20	0.25	0.00	0.36
Col2	21	0.39	0.00	0.36
Col2	22	0.14	0.00	0.36
Col2	23	0.28	0.00	0.36
Col2	24	0.25	0.00	0.36
Col2	25	0.39	0.00	0.36
Col2	26	0.14	0.00	0.36
Col2	27	0.28	0.00	0.36
Col2	28	-0.37	0.00	-0.41
Col2	29	-0.18	0.00	-0.41
Col2	30	-0.37	0.00	0.48
Col2	31	-0.18	0.00	0.48
Col2	32	-0.37	0.00	0.48
Col2	33	-0.18	0.00	0.48
Col2	34	-0.23	0.00	0.48
Col2	35	-0.03	0.00	0.48
Col2	36	0.14	0.00	0.00
Col2	37	0.14	0.00	0.00
Col2	38	0.66	0.00	0.00
Col2	39	0.66	0.00	0.00
Col2	40	0.49	0.00	0.00
Col2	41	0.49	0.00	0.00
Col2	42	0.49	0.00	0.00
Col2	43	0.49	0.00	0.00
Col2	44	0.08	0.00	0.00
Col2	45	0.08	0.00	0.00
Col2	46	0.69	0.00	0.00
Col2	47	0.32	0.00	0.36
Col2	48	0.46	0.00	0.36
Col2	49	0.13	0.00	0.00
Col2	50	0.13	0.00	0.00
Col2	51	0.09	0.00	0.00
Col2	52	0.09	0.00	0.00
Col2	53	0.61	0.00	0.00
Col2	54	0.49	0.00	0.00
Col2	55	0.49	0.00	0.36
Col2	56	0.49	0.00	0.00
Col3	1	0.83	0.00	0.00
Col3	2	0.13	0.00	0.00
Col3	3	0.60	0.00	0.00
Col3	4	0.60	0.00	0.00
Col3	5	0.66	0.00	0.00
Col3	6	0.48	0.00	0.00
Col3	7	0.48	0.00	0.00
Col3	8	-0.34	0.00	-0.42
Col3	9	-0.15	0.00	-0.42
Col3	10	-0.34	0.00	0.46

Col3	11	-0.15	0.00	0.46
Col3	12	-0.34	0.00	0.46
Col3	13	-0.15	0.00	0.46
Col3	14	-0.20	0.00	0.46
Col3	15	-0.01	0.00	0.46
Col3	16	0.42	0.00	0.34
Col3	17	0.57	0.00	0.34
Col3	18	0.31	0.00	0.34
Col3	19	0.46	0.00	0.34
Col3	20	0.25	0.00	0.34
Col3	21	0.39	0.00	0.34
Col3	22	0.14	0.00	0.34
Col3	23	0.28	0.00	0.34
Col3	24	0.25	0.00	0.34
Col3	25	0.39	0.00	0.34
Col3	26	0.14	0.00	0.34
Col3	27	0.28	0.00	0.34
Col3	28	-0.37	0.00	-0.42
Col3	29	-0.18	0.00	-0.42
Col3	30	-0.37	0.00	0.46
Col3	31	-0.18	0.00	0.46
Col3	32	-0.37	0.00	0.46
Col3	33	-0.18	0.00	0.46
Col3	34	-0.23	0.00	0.46
Col3	35	-0.03	0.00	0.46
Col3	36	0.14	0.00	0.00
Col3	37	0.14	0.00	0.00
Col3	38	0.66	0.00	0.00
Col3	39	0.66	0.00	0.00
Col3	40	0.49	0.00	0.00
Col3	41	0.49	0.00	0.00
Col3	42	0.49	0.00	0.00
Col3	43	0.49	0.00	0.00
Col3	44	0.09	0.00	0.00
Col3	45	0.09	0.00	0.00
Col3	46	0.69	0.00	0.00
Col3	47	0.32	0.00	0.34
Col3	48	0.46	0.00	0.34
Col3	49	0.13	0.00	0.00
Col3	50	0.13	0.00	0.00
Col3	51	0.09	0.00	0.00
Col3	52	0.09	0.00	0.00
Col3	53	0.73	0.00	0.00
Col3	54	0.58	0.00	0.00
Col3	55	0.58	0.00	0.34
Col3	56	0.58	0.00	0.00
Col4	1	0.83	0.00	0.00
Col4	2	0.13	0.00	0.00
Col4	3	0.60	0.00	0.00
Col4	4	0.60	0.00	0.00
Col4	5	0.66	0.00	0.00
Col4	6	0.49	0.00	0.00
Col4	7	0.49	0.00	0.00
Col4	8	-0.34	0.00	-0.42
Col4	9	-0.15	0.00	-0.42
Col4	10	-0.34	0.00	0.46
Col4	11	-0.15	0.00	0.46
Col4	12	-0.34	0.00	0.46
Col4	13	-0.15	0.00	0.46
Col4	14	-0.20	0.00	0.46
Col4	15	-0.01	0.00	0.46
Col4	16	0.42	0.00	0.35
Col4	17	0.57	0.00	0.35
Col4	18	0.31	0.00	0.35
Col4	19	0.46	0.00	0.35

Col14	20	0.25	0.00	0.35
Col14	21	0.39	0.00	0.35
Col14	22	0.14	0.00	0.35
Col14	23	0.29	0.00	0.35
Col14	24	0.25	0.00	0.35
Col14	25	0.39	0.00	0.35
Col14	26	0.14	0.00	0.35
Col14	27	0.29	0.00	0.35
Col14	28	-0.37	0.00	-0.42
Col14	29	-0.18	0.00	-0.42
Col14	30	-0.37	0.00	0.46
Col14	31	-0.18	0.00	0.46
Col14	32	-0.37	0.00	0.46
Col14	33	-0.18	0.00	0.46
Col14	34	-0.23	0.00	0.46
Col14	35	-0.03	0.00	0.46
Col14	36	0.14	0.00	0.00
Col14	37	0.14	0.00	0.00
Col14	38	0.66	0.00	0.00
Col14	39	0.66	0.00	0.00
Col14	40	0.49	0.00	0.00
Col14	41	0.49	0.00	0.00
Col14	42	0.49	0.00	0.00
Col14	43	0.49	0.00	0.00
Col14	44	0.09	0.00	0.00
Col14	45	0.09	0.00	0.00
Col14	46	0.69	0.00	0.00
Col14	47	0.32	0.00	0.35
Col14	48	0.46	0.00	0.35
Col14	49	0.13	0.00	0.00
Col14	50	0.13	0.00	0.00
Col14	51	0.09	0.00	0.00
Col14	52	0.09	0.00	0.00
Col14	53	0.79	0.00	0.00
Col14	54	0.63	0.00	0.00
Col14	55	0.63	0.00	0.35
Col14	56	0.63	0.00	0.00
Col15	1	0.83	0.00	0.00
Col15	2	0.13	0.00	0.00
Col15	3	0.60	0.00	0.00
Col15	4	0.60	0.00	0.00
Col15	5	0.66	0.00	0.00
Col15	6	0.49	0.00	0.00
Col15	7	0.49	0.00	0.00
Col15	8	-0.34	0.00	-0.43
Col15	9	-0.15	0.00	-0.43
Col15	10	-0.34	0.00	0.47
Col15	11	-0.15	0.00	0.47
Col15	12	-0.34	0.00	0.47
Col15	13	-0.15	0.00	0.47
Col15	14	-0.20	0.00	0.47
Col15	15	0.00	0.00	0.47
Col15	16	0.42	0.00	0.35
Col15	17	0.57	0.00	0.35
Col15	18	0.31	0.00	0.35
Col15	19	0.46	0.00	0.35
Col15	20	0.25	0.00	0.35
Col15	21	0.39	0.00	0.35
Col15	22	0.14	0.00	0.35
Col15	23	0.29	0.00	0.35
Col15	24	0.25	0.00	0.35
Col15	25	0.39	0.00	0.35
Col15	26	0.14	0.00	0.35
Col15	27	0.29	0.00	0.35
Col15	28	-0.37	0.00	-0.43

Col5	29	-0.18	0.00	-0.43
Col5	30	-0.37	0.00	0.47
Col5	31	-0.18	0.00	0.47
Col5	32	-0.37	0.00	0.47
Col5	33	-0.18	0.00	0.47
Col5	34	-0.23	0.00	0.47
Col5	35	-0.03	0.00	0.47
Col5	36	0.14	0.00	0.00
Col5	37	0.14	0.00	0.00
Col5	38	0.66	0.00	0.00
Col5	39	0.66	0.00	0.00
Col5	40	0.49	0.00	0.00
Col5	41	0.49	0.00	0.00
Col5	42	0.49	0.00	0.00
Col5	43	0.49	0.00	0.00
Col5	44	0.09	0.00	0.00
Col5	45	0.09	0.00	0.00
Col5	46	0.69	0.00	0.00
Col5	47	0.32	0.00	0.35
Col5	48	0.46	0.00	0.35
Col5	49	0.13	0.00	0.00
Col5	50	0.13	0.00	0.00
Col5	51	0.09	0.00	0.00
Col5	52	0.09	0.00	0.00
Col5	53	0.79	0.00	0.00
Col5	54	0.63	0.00	0.00
Col5	55	0.63	0.00	0.35
Col5	56	0.63	0.00	0.00
Col6	1	0.83	0.00	0.00
Col6	2	0.13	0.00	0.00
Col6	3	0.60	0.00	0.00
Col6	4	0.60	0.00	0.00
Col6	5	0.66	0.00	0.00
Col6	6	0.49	0.00	0.00
Col6	7	0.49	0.00	0.00
Col6	8	-0.34	0.00	-0.43
Col6	9	-0.15	0.00	-0.43
Col6	10	-0.34	0.00	0.48
Col6	11	-0.15	0.00	0.48
Col6	12	-0.34	0.00	0.48
Col6	13	-0.15	0.00	0.48
Col6	14	-0.20	0.00	0.48
Col6	15	0.00	0.00	0.48
Col6	16	0.42	0.00	0.36
Col6	17	0.57	0.00	0.36
Col6	18	0.31	0.00	0.36
Col6	19	0.46	0.00	0.36
Col6	20	0.25	0.00	0.36
Col6	21	0.40	0.00	0.36
Col6	22	0.14	0.00	0.36
Col6	23	0.29	0.00	0.36
Col6	24	0.25	0.00	0.36
Col6	25	0.40	0.00	0.36
Col6	26	0.14	0.00	0.36
Col6	27	0.29	0.00	0.36
Col6	28	-0.37	0.00	-0.43
Col6	29	-0.18	0.00	-0.43
Col6	30	-0.37	0.00	0.48
Col6	31	-0.18	0.00	0.48
Col6	32	-0.37	0.00	0.48
Col6	33	-0.18	0.00	0.48
Col6	34	-0.23	0.00	0.48
Col6	35	-0.03	0.00	0.48
Col6	36	0.14	0.00	0.00
Col6	37	0.14	0.00	0.00

Col6	38	0.66	0.00	0.00
Col6	39	0.66	0.00	0.00
Col6	40	0.49	0.00	0.00
Col6	41	0.49	0.00	0.00
Col6	42	0.49	0.00	0.00
Col6	43	0.49	0.00	0.00
Col6	44	0.09	0.00	0.00
Col6	45	0.09	0.00	0.00
Col6	46	0.69	0.00	0.00
Col6	47	0.32	0.00	0.36
Col6	48	0.46	0.00	0.36
Col6	49	0.13	0.00	0.00
Col6	50	0.13	0.00	0.00
Col6	51	0.09	0.00	0.00
Col6	52	0.09	0.00	0.00
Col6	53	0.79	0.00	0.00
Col6	54	0.63	0.00	0.00
Col6	55	0.63	0.00	0.36
Col6	56	0.63	0.00	0.00
Col7	1	0.83	0.00	0.00
Col7	2	0.13	0.00	0.00
Col7	3	0.60	0.00	0.00
Col7	4	0.60	0.00	0.00
Col7	5	0.66	0.00	0.00
Col7	6	0.49	0.00	0.00
Col7	7	0.49	0.00	0.00
Col7	8	-0.24	0.00	0.00
Col7	9	-0.24	0.00	0.00
Col7	10	-0.24	0.00	0.00
Col7	11	-0.24	0.00	0.00
Col7	12	-0.24	0.00	0.00
Col7	13	-0.24	0.00	0.00
Col7	14	-0.10	0.00	0.00
Col7	15	-0.10	0.00	0.00
Col7	16	0.50	0.00	0.00
Col7	17	0.50	0.00	0.00
Col7	18	0.39	0.00	0.00
Col7	19	0.39	0.00	0.00
Col7	20	0.32	0.00	0.00
Col7	21	0.32	0.00	0.00
Col7	22	0.22	0.00	0.00
Col7	23	0.22	0.00	0.00
Col7	24	0.32	0.00	0.00
Col7	25	0.32	0.00	0.00
Col7	26	0.22	0.00	0.00
Col7	27	0.22	0.00	0.00
Col7	28	-0.27	0.00	0.00
Col7	29	-0.27	0.00	0.00
Col7	30	-0.27	0.00	0.00
Col7	31	-0.27	0.00	0.00
Col7	32	-0.27	0.00	0.00
Col7	33	-0.27	0.00	0.00
Col7	34	-0.13	0.00	0.00
Col7	35	-0.13	0.00	0.00
Col7	36	0.14	0.00	0.00
Col7	37	0.14	0.00	0.00
Col7	38	0.66	0.00	0.00
Col7	39	0.66	0.00	0.00
Col7	40	0.49	0.00	0.00
Col7	41	0.49	0.00	0.00
Col7	42	0.49	0.00	0.00
Col7	43	0.49	0.00	0.00
Col7	44	0.09	0.00	0.00
Col7	45	0.09	0.00	0.00
Col7	46	0.68	0.00	0.00

Col7	47	0.38	0.00	0.00
Col7	48	0.38	0.00	0.00
Col7	49	0.13	0.00	0.00
Col7	50	0.13	0.00	0.00
Col7	51	0.09	0.00	0.00
Col7	52	0.09	0.00	0.00
Col7	53	0.77	0.00	0.00
Col7	54	0.61	0.00	0.00
Col7	55	0.61	0.00	0.00
Col7	56	0.61	0.00	0.00
Col8	1	0.83	0.00	0.00
Col8	2	0.13	0.00	0.00
Col8	3	0.60	0.00	0.00
Col8	4	0.60	0.00	0.00
Col8	5	0.66	0.00	0.00
Col8	6	0.49	0.00	0.00
Col8	7	0.49	0.00	0.00
Col8	8	-0.15	0.00	-0.43
Col8	9	-0.34	0.00	-0.43
Col8	10	-0.15	0.00	0.48
Col8	11	-0.34	0.00	0.48
Col8	12	-0.15	0.00	0.48
Col8	13	-0.34	0.00	0.48
Col8	14	0.00	0.00	0.48
Col8	15	-0.20	0.00	0.48
Col8	16	0.57	0.00	0.36
Col8	17	0.42	0.00	0.36
Col8	18	0.46	0.00	0.36
Col8	19	0.31	0.00	0.36
Col8	20	0.40	0.00	0.36
Col8	21	0.25	0.00	0.36
Col8	22	0.29	0.00	0.36
Col8	23	0.14	0.00	0.36
Col8	24	0.40	0.00	0.36
Col8	25	0.25	0.00	0.36
Col8	26	0.29	0.00	0.36
Col8	27	0.14	0.00	0.36
Col8	28	-0.18	0.00	-0.43
Col8	29	-0.37	0.00	-0.43
Col8	30	-0.18	0.00	0.48
Col8	31	-0.37	0.00	0.48
Col8	32	-0.18	0.00	0.48
Col8	33	-0.37	0.00	0.48
Col8	34	-0.03	0.00	0.48
Col8	35	-0.23	0.00	0.48
Col8	36	0.14	0.00	0.00
Col8	37	0.14	0.00	0.00
Col8	38	0.66	0.00	0.00
Col8	39	0.66	0.00	0.00
Col8	40	0.49	0.00	0.00
Col8	41	0.49	0.00	0.00
Col8	42	0.49	0.00	0.00
Col8	43	0.49	0.00	0.00
Col8	44	0.09	0.00	0.00
Col8	45	0.09	0.00	0.00
Col8	46	0.69	0.00	0.00
Col8	47	0.46	0.00	0.36
Col8	48	0.32	0.00	0.36
Col8	49	0.13	0.00	0.00
Col8	50	0.13	0.00	0.00
Col8	51	0.09	0.00	0.00
Col8	52	0.09	0.00	0.00
Col8	53	0.78	0.00	0.00
Col8	54	0.62	0.00	0.00
Col8	55	0.62	0.00	0.36

Col18	56	0.62	0.00	0.00
Col19	1	0.83	0.00	0.00
Col19	2	0.13	0.00	0.00
Col19	3	0.60	0.00	0.00
Col19	4	0.60	0.00	0.00
Col19	5	0.66	0.00	0.00
Col19	6	0.49	0.00	0.00
Col19	7	0.49	0.00	0.00
Col19	8	-0.15	0.00	-0.43
Col19	9	-0.34	0.00	-0.43
Col19	10	-0.15	0.00	0.47
Col19	11	-0.34	0.00	0.47
Col19	12	-0.15	0.00	0.47
Col19	13	-0.34	0.00	0.47
Col19	14	0.00	0.00	0.47
Col19	15	-0.20	0.00	0.47
Col19	16	0.57	0.00	0.35
Col19	17	0.42	0.00	0.35
Col19	18	0.46	0.00	0.35
Col19	19	0.31	0.00	0.35
Col19	20	0.39	0.00	0.35
Col19	21	0.25	0.00	0.35
Col19	22	0.29	0.00	0.35
Col19	23	0.14	0.00	0.35
Col19	24	0.39	0.00	0.35
Col19	25	0.25	0.00	0.35
Col19	26	0.29	0.00	0.35
Col19	27	0.14	0.00	0.35
Col19	28	-0.18	0.00	-0.43
Col19	29	-0.37	0.00	-0.43
Col19	30	-0.18	0.00	0.47
Col19	31	-0.37	0.00	0.47
Col19	32	-0.18	0.00	0.47
Col19	33	-0.37	0.00	0.47
Col19	34	-0.03	0.00	0.47
Col19	35	-0.23	0.00	0.47
Col19	36	0.14	0.00	0.00
Col19	37	0.14	0.00	0.00
Col19	38	0.66	0.00	0.00
Col19	39	0.66	0.00	0.00
Col19	40	0.49	0.00	0.00
Col19	41	0.49	0.00	0.00
Col19	42	0.49	0.00	0.00
Col19	43	0.49	0.00	0.00
Col19	44	0.09	0.00	0.00
Col19	45	0.09	0.00	0.00
Col19	46	0.69	0.00	0.00
Col19	47	0.46	0.00	0.35
Col19	48	0.32	0.00	0.35
Col19	49	0.13	0.00	0.00
Col19	50	0.13	0.00	0.00
Col19	51	0.09	0.00	0.00
Col19	52	0.09	0.00	0.00
Col19	53	0.78	0.00	0.00
Col19	54	0.62	0.00	0.00
Col19	55	0.62	0.00	0.35
Col19	56	0.62	0.00	0.00
Col110	1	0.83	0.00	0.00
Col110	2	0.13	0.00	0.00
Col110	3	0.60	0.00	0.00
Col110	4	0.60	0.00	0.00
Col110	5	0.66	0.00	0.00
Col110	6	0.49	0.00	0.00
Col110	7	0.49	0.00	0.00
Col110	8	-0.15	0.00	-0.42

Col10	9	-0.34	0.00	-0.42
Col10	10	-0.15	0.00	0.46
Col10	11	-0.34	0.00	0.46
Col10	12	-0.15	0.00	0.46
Col10	13	-0.34	0.00	0.46
Col10	14	-0.01	0.00	0.46
Col10	15	-0.20	0.00	0.46
Col10	16	0.57	0.00	0.35
Col10	17	0.42	0.00	0.35
Col10	18	0.46	0.00	0.35
Col10	19	0.31	0.00	0.35
Col10	20	0.39	0.00	0.35
Col10	21	0.25	0.00	0.35
Col10	22	0.29	0.00	0.35
Col10	23	0.14	0.00	0.35
Col10	24	0.39	0.00	0.35
Col10	25	0.25	0.00	0.35
Col10	26	0.29	0.00	0.35
Col10	27	0.14	0.00	0.35
Col10	28	-0.18	0.00	-0.42
Col10	29	-0.37	0.00	-0.42
Col10	30	-0.18	0.00	0.46
Col10	31	-0.37	0.00	0.46
Col10	32	-0.18	0.00	0.46
Col10	33	-0.37	0.00	0.46
Col10	34	-0.03	0.00	0.46
Col10	35	-0.23	0.00	0.46
Col10	36	0.14	0.00	0.00
Col10	37	0.14	0.00	0.00
Col10	38	0.66	0.00	0.00
Col10	39	0.66	0.00	0.00
Col10	40	0.49	0.00	0.00
Col10	41	0.49	0.00	0.00
Col10	42	0.49	0.00	0.00
Col10	43	0.49	0.00	0.00
Col10	44	0.09	0.00	0.00
Col10	45	0.09	0.00	0.00
Col10	46	0.69	0.00	0.00
Col10	47	0.46	0.00	0.35
Col10	48	0.32	0.00	0.35
Col10	49	0.13	0.00	0.00
Col10	50	0.13	0.00	0.00
Col10	51	0.09	0.00	0.00
Col10	52	0.09	0.00	0.00
Col10	53	0.77	0.00	0.00
Col10	54	0.61	0.00	0.00
Col10	55	0.61	0.00	0.35
Col10	56	0.62	0.00	0.00
Col11	1	0.83	0.00	0.00
Col11	2	0.13	0.00	0.00
Col11	3	0.60	0.00	0.00
Col11	4	0.60	0.00	0.00
Col11	5	0.66	0.00	0.00
Col11	6	0.48	0.00	0.00
Col11	7	0.48	0.00	0.00
Col11	8	-0.15	0.00	-0.42
Col11	9	-0.34	0.00	-0.42
Col11	10	-0.15	0.00	0.46
Col11	11	-0.34	0.00	0.46
Col11	12	-0.15	0.00	0.46
Col11	13	-0.34	0.00	0.46
Col11	14	-0.01	0.00	0.46
Col11	15	-0.20	0.00	0.46
Col11	16	0.57	0.00	0.34
Col11	17	0.42	0.00	0.34

Col11	18	0.46	0.00	0.34
Col11	19	0.31	0.00	0.34
Col11	20	0.39	0.00	0.34
Col11	21	0.25	0.00	0.34
Col11	22	0.28	0.00	0.34
Col11	23	0.14	0.00	0.34
Col11	24	0.39	0.00	0.34
Col11	25	0.25	0.00	0.34
Col11	26	0.28	0.00	0.34
Col11	27	0.14	0.00	0.34
Col11	28	-0.18	0.00	-0.42
Col11	29	-0.37	0.00	-0.42
Col11	30	-0.18	0.00	0.46
Col11	31	-0.37	0.00	0.46
Col11	32	-0.18	0.00	0.46
Col11	33	-0.37	0.00	0.46
Col11	34	-0.03	0.00	0.46
Col11	35	-0.23	0.00	0.46
Col11	36	0.14	0.00	0.00
Col11	37	0.14	0.00	0.00
Col11	38	0.66	0.00	0.00
Col11	39	0.66	0.00	0.00
Col11	40	0.49	0.00	0.00
Col11	41	0.49	0.00	0.00
Col11	42	0.49	0.00	0.00
Col11	43	0.49	0.00	0.00
Col11	44	0.09	0.00	0.00
Col11	45	0.09	0.00	0.00
Col11	46	0.69	0.00	0.00
Col11	47	0.46	0.00	0.34
Col11	48	0.32	0.00	0.34
Col11	49	0.13	0.00	0.00
Col11	50	0.13	0.00	0.00
Col11	51	0.09	0.00	0.00
Col11	52	0.09	0.00	0.00
Col11	53	0.66	0.00	0.00
Col11	54	0.53	0.00	0.00
Col11	55	0.53	0.00	0.34
Col11	56	0.53	0.00	0.00
Col12	1	0.83	0.00	0.00
Col12	2	0.13	0.00	0.00
Col12	3	0.60	0.00	0.00
Col12	4	0.60	0.00	0.00
Col12	5	0.66	0.00	0.00
Col12	6	0.48	0.00	0.00
Col12	7	0.48	0.00	0.00
Col12	8	-0.15	0.00	-0.41
Col12	9	-0.35	0.00	-0.41
Col12	10	-0.15	0.00	0.45
Col12	11	-0.35	0.00	0.45
Col12	12	-0.15	0.00	0.45
Col12	13	-0.35	0.00	0.45
Col12	14	-0.01	0.00	0.45
Col12	15	-0.20	0.00	0.45
Col12	16	0.57	0.00	0.34
Col12	17	0.42	0.00	0.34
Col12	18	0.46	0.00	0.34
Col12	19	0.31	0.00	0.34
Col12	20	0.39	0.00	0.34
Col12	21	0.25	0.00	0.34
Col12	22	0.28	0.00	0.34
Col12	23	0.14	0.00	0.34
Col12	24	0.39	0.00	0.34
Col12	25	0.25	0.00	0.34
Col12	26	0.28	0.00	0.34

Col12	27	0.14	0.00	0.34
Col12	28	-0.18	0.00	-0.41
Col12	29	-0.37	0.00	-0.41
Col12	30	-0.18	0.00	0.45
Col12	31	-0.37	0.00	0.45
Col12	32	-0.18	0.00	0.45
Col12	33	-0.37	0.00	0.45
Col12	34	-0.03	0.00	0.45
Col12	35	-0.23	0.00	0.45
Col12	36	0.14	0.00	0.00
Col12	37	0.14	0.00	0.00
Col12	38	0.66	0.00	0.00
Col12	39	0.66	0.00	0.00
Col12	40	0.49	0.00	0.00
Col12	41	0.49	0.00	0.00
Col12	42	0.49	0.00	0.00
Col12	43	0.49	0.00	0.00
Col12	44	0.08	0.00	0.00
Col12	45	0.08	0.00	0.00
Col12	46	0.69	0.00	0.00
Col12	47	0.46	0.00	0.34
Col12	48	0.32	0.00	0.34
Col12	49	0.13	0.00	0.00
Col12	50	0.13	0.00	0.00
Col12	51	0.09	0.00	0.00
Col12	52	0.09	0.00	0.00
Col12	53	0.60	0.00	0.00
Col12	54	0.49	0.00	0.00
Col12	55	0.49	0.00	0.34
Col12	56	0.49	0.00	0.00
Col13	1	0.83	0.00	0.00
Col13	2	0.13	0.00	0.00
Col13	3	0.60	0.00	0.00
Col13	4	0.60	0.00	0.00
Col13	5	0.66	0.00	0.00
Col13	6	0.48	0.00	0.00
Col13	7	0.48	0.00	0.00
Col13	8	-0.15	0.00	-0.41
Col13	9	-0.35	0.00	-0.41
Col13	10	-0.15	0.00	0.47
Col13	11	-0.35	0.00	0.47
Col13	12	-0.15	0.00	0.47
Col13	13	-0.35	0.00	0.47
Col13	14	-0.01	0.00	0.47
Col13	15	-0.20	0.00	0.47
Col13	16	0.57	0.00	0.35
Col13	17	0.42	0.00	0.35
Col13	18	0.46	0.00	0.35
Col13	19	0.31	0.00	0.35
Col13	20	0.39	0.00	0.35
Col13	21	0.25	0.00	0.35
Col13	22	0.28	0.00	0.35
Col13	23	0.14	0.00	0.35
Col13	24	0.39	0.00	0.35
Col13	25	0.25	0.00	0.35
Col13	26	0.28	0.00	0.35
Col13	27	0.14	0.00	0.35
Col13	28	-0.18	0.00	-0.41
Col13	29	-0.37	0.00	-0.41
Col13	30	-0.18	0.00	0.47
Col13	31	-0.37	0.00	0.47
Col13	32	-0.18	0.00	0.47
Col13	33	-0.37	0.00	0.47
Col13	34	-0.03	0.00	0.47
Col13	35	-0.23	0.00	0.47

Col13	36	0.13	0.00	0.00
Col13	37	0.13	0.00	0.00
Col13	38	0.66	0.00	0.00
Col13	39	0.66	0.00	0.00
Col13	40	0.49	0.00	0.00
Col13	41	0.49	0.00	0.00
Col13	42	0.49	0.00	0.00
Col13	43	0.49	0.00	0.00
Col13	44	0.08	0.00	0.00
Col13	45	0.08	0.00	0.00
Col13	46	0.69	0.00	0.00
Col13	47	0.46	0.00	0.35
Col13	48	0.32	0.00	0.35
Col13	49	0.13	0.00	0.00
Col13	50	0.13	0.00	0.00
Col13	51	0.09	0.00	0.00
Col13	52	0.09	0.00	0.00
Col13	53	0.60	0.00	0.00
Col13	54	0.49	0.00	0.00
Col13	55	0.49	0.00	0.35
Col13	56	0.49	0.00	0.00

COLUMN DEFLECTIONS:

Load		Deflection(in)	
Id	Id	Calc	Limit
-----	----	-----	-----
Col2	1	0.00	1.09
Col2	2	0.00	1.09
Col2	3	0.00	1.09
Col2	4	0.00	1.09
Col2	5	0.00	1.09
Col2	6	0.00	1.09
Col2	7	0.00	1.09
Col2	8	-0.73	1.09
Col2	9	-0.73	1.09
Col2	10	0.85	1.09
Col2	11	0.85	1.09
Col2	12	0.85	1.09
Col2	13	0.85	1.09
Col2	14	0.85	1.09
Col2	15	0.85	1.09
Col2	16	0.64	1.09
Col2	17	0.64	1.09
Col2	18	0.64	1.09
Col2	19	0.64	1.09
Col2	20	0.64	1.09
Col2	21	0.64	1.09
Col2	22	0.64	1.09
Col2	23	0.64	1.09
Col2	24	0.64	1.09
Col2	25	0.64	1.09
Col2	26	0.64	1.09
Col2	27	0.64	1.09
Col2	28	-0.73	1.09
Col2	29	-0.73	1.09
Col2	30	0.85	1.09
Col2	31	0.85	1.09
Col2	32	0.85	1.09
Col2	33	0.85	1.09
Col2	34	0.85	1.09
Col2	35	0.85	1.09
Col2	36	0.00	1.09
Col2	37	0.00	1.09
Col2	38	0.00	1.09

Col2	39	0.00	1.09
Col2	40	0.00	1.09
Col2	41	0.00	1.09
Col2	42	0.00	1.09
Col2	43	0.00	1.09
Col2	44	0.00	1.09
Col2	45	0.00	1.09
Col2	46	0.00	1.09
Col2	47	0.38	1.09
Col2	48	0.38	1.09
Col2	49	0.00	1.09
Col2	50	0.00	1.09
Col2	51	0.64	1.09
Col2	52	0.00	1.09
Col3	1	0.00	1.10
Col3	2	0.00	1.10
Col3	3	0.00	1.10
Col3	4	0.00	1.10
Col3	5	0.00	1.10
Col3	6	0.00	1.10
Col3	7	0.00	1.10
Col3	8	-0.77	1.10
Col3	9	-0.77	1.10
Col3	10	0.84	1.10
Col3	11	0.84	1.10
Col3	12	0.84	1.10
Col3	13	0.84	1.10
Col3	14	0.84	1.10
Col3	15	0.84	1.10
Col3	16	0.63	1.10
Col3	17	0.63	1.10
Col3	18	0.63	1.10
Col3	19	0.63	1.10
Col3	20	0.63	1.10
Col3	21	0.63	1.10
Col3	22	0.63	1.10
Col3	23	0.63	1.10
Col3	24	0.63	1.10
Col3	25	0.63	1.10
Col3	26	0.63	1.10
Col3	27	0.63	1.10
Col3	28	-0.77	1.10
Col3	29	-0.77	1.10
Col3	30	0.84	1.10
Col3	31	0.84	1.10
Col3	32	0.84	1.10
Col3	33	0.84	1.10
Col3	34	0.84	1.10
Col3	35	0.84	1.10
Col3	36	0.00	1.10
Col3	37	0.00	1.10
Col3	38	0.00	1.10
Col3	39	0.00	1.10
Col3	40	0.00	1.10
Col3	41	0.00	1.10
Col3	42	0.00	1.10
Col3	43	0.00	1.10
Col3	44	0.00	1.10
Col3	45	0.00	1.10
Col3	46	0.00	1.10
Col3	47	0.38	1.10
Col3	48	0.38	1.10
Col3	49	0.00	1.10
Col3	50	0.00	1.10
Col3	51	0.63	1.10

Col13	52	0.00	1.10
Col14	1	0.00	1.12
Col14	2	0.00	1.12
Col14	3	0.00	1.12
Col14	4	0.00	1.12
Col14	5	0.00	1.12
Col14	6	0.00	1.12
Col14	7	0.00	1.12
Col14	8	-0.81	1.12
Col14	9	-0.81	1.12
Col14	10	0.89	1.12
Col14	11	0.89	1.12
Col14	12	0.89	1.12
Col14	13	0.89	1.12
Col14	14	0.89	1.12
Col14	15	0.89	1.12
Col14	16	0.67	1.12
Col14	17	0.67	1.12
Col14	18	0.67	1.12
Col14	19	0.67	1.12
Col14	20	0.67	1.12
Col14	21	0.67	1.12
Col14	22	0.67	1.12
Col14	23	0.67	1.12
Col14	24	0.67	1.12
Col14	25	0.67	1.12
Col14	26	0.67	1.12
Col14	27	0.67	1.12
Col14	28	-0.81	1.12
Col14	29	-0.81	1.12
Col14	30	0.89	1.12
Col14	31	0.89	1.12
Col14	32	0.89	1.12
Col14	33	0.89	1.12
Col14	34	0.89	1.12
Col14	35	0.89	1.12
Col14	36	0.00	1.12
Col14	37	0.00	1.12
Col14	38	0.00	1.12
Col14	39	0.00	1.12
Col14	40	0.00	1.12
Col14	41	0.00	1.12
Col14	42	0.00	1.12
Col14	43	0.00	1.12
Col14	44	0.00	1.12
Col14	45	0.00	1.12
Col14	46	0.00	1.12
Col14	47	0.40	1.12
Col14	48	0.40	1.12
Col14	49	0.00	1.12
Col14	50	0.00	1.12
Col14	51	0.67	1.12
Col14	52	0.00	1.12
Col15	1	0.00	1.13
Col15	2	0.00	1.13
Col15	3	0.00	1.13
Col15	4	0.00	1.13
Col15	5	0.00	1.13
Col15	6	0.00	1.13
Col15	7	0.00	1.13
Col15	8	-0.85	1.13
Col15	9	-0.85	1.13
Col15	10	0.93	1.13
Col15	11	0.93	1.13
Col15	12	0.93	1.13

Col5	13	0.93	1.13
Col5	14	0.93	1.13
Col5	15	0.93	1.13
Col5	16	0.70	1.13
Col5	17	0.70	1.13
Col5	18	0.70	1.13
Col5	19	0.70	1.13
Col5	20	0.70	1.13
Col5	21	0.70	1.13
Col5	22	0.70	1.13
Col5	23	0.70	1.13
Col5	24	0.70	1.13
Col5	25	0.70	1.13
Col5	26	0.70	1.13
Col5	27	0.70	1.13
Col5	28	-0.85	1.13
Col5	29	-0.85	1.13
Col5	30	0.93	1.13
Col5	31	0.93	1.13
Col5	32	0.93	1.13
Col5	33	0.93	1.13
Col5	34	0.93	1.13
Col5	35	0.93	1.13
Col5	36	0.00	1.13
Col5	37	0.00	1.13
Col5	38	0.00	1.13
Col5	39	0.00	1.13
Col5	40	0.00	1.13
Col5	41	0.00	1.13
Col5	42	0.00	1.13
Col5	43	0.00	1.13
Col5	44	0.00	1.13
Col5	45	0.00	1.13
Col5	46	0.00	1.13
Col5	47	0.42	1.13
Col5	48	0.42	1.13
Col5	49	0.00	1.13
Col5	50	0.00	1.13
Col5	51	0.70	1.13
Col5	52	0.00	1.13
Col6	1	0.00	1.14
Col6	2	0.00	1.14
Col6	3	0.00	1.14
Col6	4	0.00	1.14
Col6	5	0.00	1.14
Col6	6	0.00	1.14
Col6	7	0.00	1.14
Col6	8	-0.89	1.14
Col6	9	-0.89	1.14
Col6	10	0.98	1.14
Col6	11	0.98	1.14
Col6	12	0.98	1.14
Col6	13	0.98	1.14
Col6	14	0.98	1.14
Col6	15	0.98	1.14
Col6	16	0.73	1.14
Col6	17	0.73	1.14
Col6	18	0.73	1.14
Col6	19	0.73	1.14
Col6	20	0.73	1.14
Col6	21	0.73	1.14
Col6	22	0.73	1.14
Col6	23	0.73	1.14
Col6	24	0.73	1.14
Col6	25	0.73	1.14

Col6	26	0.73	1.14
Col6	27	0.73	1.14
Col6	28	-0.89	1.14
Col6	29	-0.89	1.14
Col6	30	0.98	1.14
Col6	31	0.98	1.14
Col6	32	0.98	1.14
Col6	33	0.98	1.14
Col6	34	0.98	1.14
Col6	35	0.98	1.14
Col6	36	0.00	1.14
Col6	37	0.00	1.14
Col6	38	0.00	1.14
Col6	39	0.00	1.14
Col6	40	0.00	1.14
Col6	41	0.00	1.14
Col6	42	0.00	1.14
Col6	43	0.00	1.14
Col6	44	0.00	1.14
Col6	45	0.00	1.14
Col6	46	0.00	1.14
Col6	47	0.44	1.14
Col6	48	0.44	1.14
Col6	49	0.00	1.14
Col6	50	0.00	1.14
Col6	51	0.73	1.14
Col6	52	0.00	1.14
Col7	1	0.00	1.15
Col7	2	0.00	1.15
Col7	3	0.00	1.15
Col7	4	0.00	1.15
Col7	5	0.00	1.15
Col7	6	0.00	1.15
Col7	7	0.00	1.15
Col7	8	0.00	1.15
Col7	9	0.00	1.15
Col7	10	0.00	1.15
Col7	11	0.00	1.15
Col7	12	0.00	1.15
Col7	13	0.00	1.15
Col7	14	0.00	1.15
Col7	15	0.00	1.15
Col7	16	0.00	1.15
Col7	17	0.00	1.15
Col7	18	0.00	1.15
Col7	19	0.00	1.15
Col7	20	0.00	1.15
Col7	21	0.00	1.15
Col7	22	0.00	1.15
Col7	23	0.00	1.15
Col7	24	0.00	1.15
Col7	25	0.00	1.15
Col7	26	0.00	1.15
Col7	27	0.00	1.15
Col7	28	0.00	1.15
Col7	29	0.00	1.15
Col7	30	0.00	1.15
Col7	31	0.00	1.15
Col7	32	0.00	1.15
Col7	33	0.00	1.15
Col7	34	0.00	1.15
Col7	35	0.00	1.15
Col7	36	0.00	1.15
Col7	37	0.00	1.15
Col7	38	0.00	1.15

Col7	39	0.00	1.15
Col7	40	0.00	1.15
Col7	41	0.00	1.15
Col7	42	0.00	1.15
Col7	43	0.00	1.15
Col7	44	0.00	1.15
Col7	45	0.00	1.15
Col7	46	0.00	1.15
Col7	47	0.00	1.15
Col7	48	0.00	1.15
Col7	49	0.00	1.15
Col7	50	0.00	1.15
Col7	51	0.00	1.15
Col7	52	0.00	1.15
Col8	1	0.00	1.14
Col8	2	0.00	1.14
Col8	3	0.00	1.14
Col8	4	0.00	1.14
Col8	5	0.00	1.14
Col8	6	0.00	1.14
Col8	7	0.00	1.14
Col8	8	-0.89	1.14
Col8	9	-0.89	1.14
Col8	10	0.98	1.14
Col8	11	0.98	1.14
Col8	12	0.98	1.14
Col8	13	0.98	1.14
Col8	14	0.98	1.14
Col8	15	0.98	1.14
Col8	16	0.73	1.14
Col8	17	0.73	1.14
Col8	18	0.73	1.14
Col8	19	0.73	1.14
Col8	20	0.73	1.14
Col8	21	0.73	1.14
Col8	22	0.73	1.14
Col8	23	0.73	1.14
Col8	24	0.73	1.14
Col8	25	0.73	1.14
Col8	26	0.73	1.14
Col8	27	0.73	1.14
Col8	28	-0.89	1.14
Col8	29	-0.89	1.14
Col8	30	0.98	1.14
Col8	31	0.98	1.14
Col8	32	0.98	1.14
Col8	33	0.98	1.14
Col8	34	0.98	1.14
Col8	35	0.98	1.14
Col8	36	0.00	1.14
Col8	37	0.00	1.14
Col8	38	0.00	1.14
Col8	39	0.00	1.14
Col8	40	0.00	1.14
Col8	41	0.00	1.14
Col8	42	0.00	1.14
Col8	43	0.00	1.14
Col8	44	0.00	1.14
Col8	45	0.00	1.14
Col8	46	0.00	1.14
Col8	47	0.44	1.14
Col8	48	0.44	1.14
Col8	49	0.00	1.14
Col8	50	0.00	1.14
Col8	51	0.73	1.14

Col8	52	0.00	1.14
Col9	1	0.00	1.13
Col9	2	0.00	1.13
Col9	3	0.00	1.13
Col9	4	0.00	1.13
Col9	5	0.00	1.13
Col9	6	0.00	1.13
Col9	7	0.00	1.13
Col9	8	-0.85	1.13
Col9	9	-0.85	1.13
Col9	10	0.93	1.13
Col9	11	0.93	1.13
Col9	12	0.93	1.13
Col9	13	0.93	1.13
Col9	14	0.93	1.13
Col9	15	0.93	1.13
Col9	16	0.70	1.13
Col9	17	0.70	1.13
Col9	18	0.70	1.13
Col9	19	0.70	1.13
Col9	20	0.70	1.13
Col9	21	0.70	1.13
Col9	22	0.70	1.13
Col9	23	0.70	1.13
Col9	24	0.70	1.13
Col9	25	0.70	1.13
Col9	26	0.70	1.13
Col9	27	0.70	1.13
Col9	28	-0.85	1.13
Col9	29	-0.85	1.13
Col9	30	0.93	1.13
Col9	31	0.93	1.13
Col9	32	0.93	1.13
Col9	33	0.93	1.13
Col9	34	0.93	1.13
Col9	35	0.93	1.13
Col9	36	0.00	1.13
Col9	37	0.00	1.13
Col9	38	0.00	1.13
Col9	39	0.00	1.13
Col9	40	0.00	1.13
Col9	41	0.00	1.13
Col9	42	0.00	1.13
Col9	43	0.00	1.13
Col9	44	0.00	1.13
Col9	45	0.00	1.13
Col9	46	0.00	1.13
Col9	47	0.42	1.13
Col9	48	0.42	1.13
Col9	49	0.00	1.13
Col9	50	0.00	1.13
Col9	51	0.70	1.13
Col9	52	0.00	1.13
Col10	1	0.00	1.12
Col10	2	0.00	1.12
Col10	3	0.00	1.12
Col10	4	0.00	1.12
Col10	5	0.00	1.12
Col10	6	0.00	1.12
Col10	7	0.00	1.12
Col10	8	-0.81	1.12
Col10	9	-0.81	1.12
Col10	10	0.89	1.12
Col10	11	0.89	1.12
Col10	12	0.89	1.12

Col10	13	0.89	1.12
Col10	14	0.89	1.12
Col10	15	0.89	1.12
Col10	16	0.67	1.12
Col10	17	0.67	1.12
Col10	18	0.67	1.12
Col10	19	0.67	1.12
Col10	20	0.67	1.12
Col10	21	0.67	1.12
Col10	22	0.67	1.12
Col10	23	0.67	1.12
Col10	24	0.67	1.12
Col10	25	0.67	1.12
Col10	26	0.67	1.12
Col10	27	0.67	1.12
Col10	28	-0.81	1.12
Col10	29	-0.81	1.12
Col10	30	0.89	1.12
Col10	31	0.89	1.12
Col10	32	0.89	1.12
Col10	33	0.89	1.12
Col10	34	0.89	1.12
Col10	35	0.89	1.12
Col10	36	0.00	1.12
Col10	37	0.00	1.12
Col10	38	0.00	1.12
Col10	39	0.00	1.12
Col10	40	0.00	1.12
Col10	41	0.00	1.12
Col10	42	0.00	1.12
Col10	43	0.00	1.12
Col10	44	0.00	1.12
Col10	45	0.00	1.12
Col10	46	0.00	1.12
Col10	47	0.40	1.12
Col10	48	0.40	1.12
Col10	49	0.00	1.12
Col10	50	0.00	1.12
Col10	51	0.67	1.12
Col10	52	0.00	1.12
Col11	1	0.00	1.10
Col11	2	0.00	1.10
Col11	3	0.00	1.10
Col11	4	0.00	1.10
Col11	5	0.00	1.10
Col11	6	0.00	1.10
Col11	7	0.00	1.10
Col11	8	-0.77	1.10
Col11	9	-0.77	1.10
Col11	10	0.84	1.10
Col11	11	0.84	1.10
Col11	12	0.84	1.10
Col11	13	0.84	1.10
Col11	14	0.84	1.10
Col11	15	0.84	1.10
Col11	16	0.63	1.10
Col11	17	0.63	1.10
Col11	18	0.63	1.10
Col11	19	0.63	1.10
Col11	20	0.63	1.10
Col11	21	0.63	1.10
Col11	22	0.63	1.10
Col11	23	0.63	1.10
Col11	24	0.63	1.10
Col11	25	0.63	1.10

Col11	26	0.63	1.10
Col11	27	0.63	1.10
Col11	28	-0.77	1.10
Col11	29	-0.77	1.10
Col11	30	0.84	1.10
Col11	31	0.84	1.10
Col11	32	0.84	1.10
Col11	33	0.84	1.10
Col11	34	0.84	1.10
Col11	35	0.84	1.10
Col11	36	0.00	1.10
Col11	37	0.00	1.10
Col11	38	0.00	1.10
Col11	39	0.00	1.10
Col11	40	0.00	1.10
Col11	41	0.00	1.10
Col11	42	0.00	1.10
Col11	43	0.00	1.10
Col11	44	0.00	1.10
Col11	45	0.00	1.10
Col11	46	0.00	1.10
Col11	47	0.38	1.10
Col11	48	0.38	1.10
Col11	49	0.00	1.10
Col11	50	0.00	1.10
Col11	51	0.63	1.10
Col11	52	0.00	1.10
Col12	1	0.00	1.09
Col12	2	0.00	1.09
Col12	3	0.00	1.09
Col12	4	0.00	1.09
Col12	5	0.00	1.09
Col12	6	0.00	1.09
Col12	7	0.00	1.09
Col12	8	-0.73	1.09
Col12	9	-0.73	1.09
Col12	10	0.80	1.09
Col12	11	0.80	1.09
Col12	12	0.80	1.09
Col12	13	0.80	1.09
Col12	14	0.80	1.09
Col12	15	0.80	1.09
Col12	16	0.60	1.09
Col12	17	0.60	1.09
Col12	18	0.60	1.09
Col12	19	0.60	1.09
Col12	20	0.60	1.09
Col12	21	0.60	1.09
Col12	22	0.60	1.09
Col12	23	0.60	1.09
Col12	24	0.60	1.09
Col12	25	0.60	1.09
Col12	26	0.60	1.09
Col12	27	0.60	1.09
Col12	28	-0.73	1.09
Col12	29	-0.73	1.09
Col12	30	0.80	1.09
Col12	31	0.80	1.09
Col12	32	0.80	1.09
Col12	33	0.80	1.09
Col12	34	0.80	1.09
Col12	35	0.80	1.09
Col12	36	0.00	1.09
Col12	37	0.00	1.09
Col12	38	0.00	1.09

Col12	39	0.00	1.09
Col12	40	0.00	1.09
Col12	41	0.00	1.09
Col12	42	0.00	1.09
Col12	43	0.00	1.09
Col12	44	0.00	1.09
Col12	45	0.00	1.09
Col12	46	0.00	1.09
Col12	47	0.36	1.09
Col12	48	0.36	1.09
Col12	49	0.00	1.09
Col12	50	0.00	1.09
Col12	51	0.60	1.09
Col12	52	0.00	1.09
Col13	1	0.00	1.07
Col13	2	0.00	1.07
Col13	3	0.00	1.07
Col13	4	0.00	1.07
Col13	5	0.00	1.07
Col13	6	0.00	1.07
Col13	7	0.00	1.07
Col13	8	-0.69	1.07
Col13	9	-0.69	1.07
Col13	10	0.80	1.07
Col13	11	0.80	1.07
Col13	12	0.80	1.07
Col13	13	0.80	1.07
Col13	14	0.80	1.07
Col13	15	0.80	1.07
Col13	16	0.60	1.07
Col13	17	0.60	1.07
Col13	18	0.60	1.07
Col13	19	0.60	1.07
Col13	20	0.60	1.07
Col13	21	0.60	1.07
Col13	22	0.60	1.07
Col13	23	0.60	1.07
Col13	24	0.60	1.07
Col13	25	0.60	1.07
Col13	26	0.60	1.07
Col13	27	0.60	1.07
Col13	28	-0.69	1.07
Col13	29	-0.69	1.07
Col13	30	0.80	1.07
Col13	31	0.80	1.07
Col13	32	0.80	1.07
Col13	33	0.80	1.07
Col13	34	0.80	1.07
Col13	35	0.80	1.07
Col13	36	0.00	1.07
Col13	37	0.00	1.07
Col13	38	0.00	1.07
Col13	39	0.00	1.07
Col13	40	0.00	1.07
Col13	41	0.00	1.07
Col13	42	0.00	1.07
Col13	43	0.00	1.07
Col13	44	0.00	1.07
Col13	45	0.00	1.07
Col13	46	0.00	1.07
Col13	47	0.36	1.07
Col13	48	0.36	1.07
Col13	49	0.00	1.07
Col13	50	0.00	1.07
Col13	51	0.60	1.07

Col13 52 0.00 1.07

COLUMN KL/R RATIO, MOMENT REDUCTION:

Id	Major (ft)	--Minor (ft)--		----KL/R----		Available Reduction Factor	
		Bend	Axial	Major	Minor	Out	In
Col12	16.3	4.3	4.3	85	70	0.00	0.00
Col13	16.5	4.5	4.5	86	73	0.00	0.00
Col14	16.7	4.7	4.7	87	77	0.00	0.00
Col15	17.0	5.0	5.0	88	80	0.00	0.00
Col16	17.2	5.2	5.2	89	83	0.00	0.00
Col17	0.1	5.3	5.3	1	85	0.00	0.00
Col18	17.2	5.2	5.2	89	83	0.00	0.00
Col19	17.0	5.0	5.0	88	80	0.00	0.00
Col110	16.7	4.7	4.7	87	77	0.00	0.00
Col111	16.5	4.5	4.5	86	73	0.00	0.00
Col112	16.3	4.3	4.3	85	70	0.00	0.00
Col113	16.1	4.1	4.1	84	66	0.00	0.00

GIRT LAYOUT:

Bay Id	Girt Id	Locate	Part	Design Length	Available Reduction Factor	
					Out	In
1	1	4.000	6X2C16	4.500	0.00	0.70
	2	8.000	6X2C16	4.500	0.00	0.70
	3	12.000	6X2C16	4.500	0.00	0.70
2	1	4.000	6X2C16	4.500	0.00	0.70
	2	8.000	6X2C16	4.500	0.00	0.70
	3	12.000	6X2C16	4.500	0.00	0.70
3	1	4.000	6X2C16	4.500	0.00	0.70
	2	8.000	6X2C16	4.500	0.00	0.70
	3	12.000	6X2C16	4.500	0.00	0.70
4	1	4.000	6X2C16	4.500	0.00	0.70
	2	8.000	6X2C16	4.500	0.00	0.70
	3	12.000	6X2C16	4.500	0.00	0.70
5	1	4.000	6X2C16	4.500	0.00	0.70
	2	8.000	6X2C16	4.500	0.00	0.70
	3	12.000	6X2C16	4.500	0.00	0.70
6	1	4.000	6X2C16	4.500	0.00	0.70
	2	8.000	6X2C16	4.500	0.00	0.70
	3	12.000	6X2C16	4.500	0.00	0.70
7	1	4.000	6X2C16	4.500	0.00	0.70
	2	8.000	6X2C16	4.500	0.00	0.70
	3	12.000	6X2C16	4.500	0.00	0.70
8	1	4.000	6X2C16	4.500	0.00	0.70
	2	8.000	6X2C16	4.500	0.00	0.70
	3	12.000	6X2C16	4.500	0.00	0.70
9	1	4.000	6X2C16	4.500	0.00	0.70
	2	8.000	6X2C16	4.500	0.00	0.70
	3	12.000	6X2C16	4.500	0.00	0.70
10	1	4.000	6X2C16	4.500	0.00	0.70
	2	8.000	6X2C16	4.500	0.00	0.70
	3	12.000	6X2C16	4.500	0.00	0.70
11	1	4.000	6X2C16	4.500	0.00	0.70
	2	8.000	6X2C16	4.500	0.00	0.70
	3	12.000	6X2C16	4.500	0.00	0.70
12	1	4.000	6X2C16	4.500	0.00	0.70
	2	8.000	6X2C16	4.500	0.00	0.70
	3	12.000	6X2C16	4.500	0.00	0.70
13	1	4.000	6X2C16	4.625	0.00	0.70
	2	8.000	6X2C16	4.625	0.00	0.70
	3	12.000	6X2C16	4.625	0.00	0.70

GIRT ACTIONS:

Bay Id	Girt Id	Load	-Shear(k)-		Moment(f-k)		Max UC	Deflect(in)	
			Calc	Limit	Calc	Limit		Calc	Limit
1	1	WP	-0.09	3.32	-0.10	2.65	0.04	0.00	0.60
		WS	0.11	3.32	0.12	2.65	0.05	0.00	0.60
2	1	WP	-0.09	3.32	-0.10	2.65	0.04	0.00	0.60
		WS	0.10	3.32	0.11	2.65	0.04	0.00	0.60
	3	WP	-0.10	3.32	-0.11	2.65	0.04	0.00	0.60
		WS	0.11	3.32	0.12	2.65	0.05	0.00	0.60
3	1	WP	-0.09	3.32	-0.10	2.65	0.04	0.00	0.60
		WS	0.10	3.32	0.11	2.65	0.04	0.00	0.60
	3	WP	-0.10	3.32	-0.11	2.65	0.04	0.00	0.60
		WS	0.11	3.32	0.12	2.65	0.05	0.00	0.60
4	1	WP	-0.09	3.32	-0.10	2.65	0.04	0.00	0.60

		WS	0.10	3.32	0.11	2.65	0.04	0.00	0.60
	3	WP	-0.10	3.32	-0.11	2.65	0.04	0.00	0.60
		WS	0.11	3.32	0.12	2.65	0.05	0.00	0.60
5	1	WP	-0.09	3.32	-0.10	2.65	0.04	0.00	0.60
		WS	0.10	3.32	0.11	2.65	0.04	0.00	0.60
	3	WP	-0.10	3.32	-0.12	2.65	0.04	0.00	0.60
		WS	0.11	3.32	0.13	2.65	0.05	0.00	0.60
6	1	WP	-0.09	3.32	-0.10	2.65	0.04	0.00	0.60
		WS	0.10	3.32	0.11	2.65	0.04	0.00	0.60
	3	WP	-0.10	3.32	-0.12	2.65	0.04	0.00	0.60
		WS	0.12	3.32	0.13	2.65	0.05	0.00	0.60
7	1	WP	-0.09	3.32	-0.10	2.65	0.04	0.00	0.60
		WS	0.10	3.32	0.11	2.65	0.04	0.00	0.60
	3	WP	-0.10	3.32	-0.12	2.65	0.04	0.00	0.60
		WS	0.12	3.32	0.13	2.65	0.05	0.00	0.60
8	1	WP	-0.09	3.32	-0.10	2.65	0.04	0.00	0.60
		WS	0.10	3.32	0.11	2.65	0.04	0.00	0.60
	3	WP	-0.10	3.32	-0.12	2.65	0.04	0.00	0.60
		WS	0.11	3.32	0.13	2.65	0.05	0.00	0.60
9	1	WP	-0.09	3.32	-0.10	2.65	0.04	0.00	0.60
		WS	0.10	3.32	0.11	2.65	0.04	0.00	0.60
	3	WP	-0.10	3.32	-0.11	2.65	0.04	0.00	0.60
		WS	0.11	3.32	0.12	2.65	0.05	0.00	0.60
10	1	WP	-0.09	3.32	-0.10	2.65	0.04	0.00	0.60
		WS	0.10	3.32	0.11	2.65	0.04	0.00	0.60
	3	WP	-0.10	3.32	-0.11	2.65	0.04	0.00	0.60
		WS	0.11	3.32	0.12	2.65	0.05	0.00	0.60
11	1	WP	-0.09	3.32	-0.10	2.65	0.04	0.00	0.60
		WS	0.10	3.32	0.11	2.65	0.04	0.00	0.60
	3	WP	-0.10	3.32	-0.11	2.65	0.04	0.00	0.60
		WS	0.10	3.32	0.12	2.65	0.04	0.00	0.60
12	1	WP	-0.09	3.32	-0.10	2.65	0.04	0.00	0.60
		WS	0.10	3.32	0.11	2.65	0.04	0.00	0.60
	3	WP	-0.09	3.32	-0.10	2.65	0.04	0.00	0.60
		WS	0.10	3.32	0.12	2.65	0.04	0.00	0.60
13	1	WP	-0.09	3.32	-0.11	2.65	0.04	0.00	0.62
		WS	0.11	3.32	0.13	2.65	0.05	0.00	0.62

WP - Wind_Pressure

WS - Wind_Suction

PANEL DATA:

Table with 5 columns: Bay, Part, Type, Gage, Yield. Row 1: 7, CUSPANL, CP, 20.00, 50.0

MOMENTS & DEFLECTION:

Table with 13 columns: Span Id, Locate (ft) Start, End, Load, Moment (ft-lb/ft) Calc, Limit (Start, Midspan, End), Max UC, Deflect (in) Calc, Limit. Includes data for spans 1-4 and a legend for WP (Wind Pressure) and WS (Wind Suction).

PANEL:

Table with 4 columns: Part, Thick (in), Yield (ksi), Tensile Strength (ksi). Row 1: CUSPANL, 0.038, 50.00, 65.00.

GIRT SCREWS:

Table with 4 columns: Part, Dia (in), Washer (in), Limit (k). Row 1: #29, 0.21, 0.50, 2.90.

PANEL ZONE LAYOUT:

Table with 9 columns: Zone Id, Description, Wall (ft) Offset1, Wall (ft) Offset2, Bay Id, Girt (ft, ft, in) Locate, Girt (ft, ft, in) Width, Girt (ft, ft, in) Min Thick, Panel Span (ft). Rows 1-3: Interior, Lt Edge, Rt Edge.

GIRT SCREW CHECK:

Table with 8 columns: Zone Id, Screw Space, Wind Suction (psf), Load (k), Limit (k) Girt Pullout, Limit (k) Panel Pullover, Screw Tension, Max UC. Rows 1-3: Interior, Lt Edge, Rt Edge.

11 12	Front SW - Column & Rafter Design	8/25/22 2:32pm
-------	-----------------------------------	----------------

WALL LAYOUT:

Wall Id	Orn	Load Width
2	L	2.50

MEMBER LAYOUT:

Id	Locate		---Web(in)---		-Flange(in)-		Length (ft)	Weight (lb)	----Max_Load----		
	(ft)	Part	Depth	Thick	Width	Thick			Id	UC	Report
Col15	0.0	6X2C16	6.00	16ga	2.00	16ga	15.9	34.8	17	0.09	Mom+Axl
Col16	14.0	6X2C16	6.00	16ga	2.00	16ga	15.9	34.8	1	0.08	Mom+Axl
Col17	28.0	6X2C16	6.00	16ga	2.00	16ga	15.9	34.8	1	0.08	Mom+Axl
Col18	42.0	6X2C16	6.00	16ga	2.00	16ga	15.9	34.8	1	0.08	Mom+Axl
Col19	56.0	6X2C16	6.00	16ga	2.00	16ga	15.9	34.8	1	0.08	Mom+Axl
Col20	70.0	6X2C16	6.00	16ga	2.00	16ga	15.9	34.8	17	0.09	Mom+Axl
Raf1		PB6EC	6.13	16ga	2.06	16ga	28.0	58.8			
Raf2		PB6EC	6.13	16ga	2.06	16ga	28.0	58.8			
Raf3		PB6EC	6.13	16ga	2.06	16ga	14.0	29.4			
Total=								355.6			

DESIGN ACTIONS/STRENGTH:

Id	Load Id	-Axial(k)-		-Shear(k)-		Moment(f-k)		-----Unity_Check-----			
		Calc	Limit	Calc	Limit	Calc	Limit	Axial	Shear	Axial+	Shear+
								Moment		Moment	
Col15	1	0.44	7.84	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col15	2	0.09	7.84	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col15	3	0.33	7.84	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col15	4	0.33	7.84	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col15	5	0.36	7.84	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col15	6	0.27	7.84	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col15	7	0.27	7.84	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col15	8	-0.15	21.18	0.04	3.32	-0.16	2.65	0.01	0.01	0.05	0.00
Col15	9	-0.05	21.18	0.04	3.32	-0.16	2.65	0.00	0.01	0.06	0.00
Col15	10	-0.15	21.18	-0.05	3.32	0.19	2.65	0.01	0.01	0.06	0.00
Col15	11	-0.05	21.18	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00
Col15	12	-0.15	21.18	-0.05	3.32	0.19	2.65	0.01	0.01	0.06	0.00
Col15	13	-0.05	21.18	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00
Col15	14	-0.07	21.18	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00
Col15	15	0.02	7.84	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00
Col15	16	0.24	7.84	-0.04	3.32	0.14	2.65	0.03	0.01	0.08	0.00
Col15	17	0.31	7.84	-0.04	3.32	0.14	2.65	0.04	0.01	0.09	0.00
Col15	18	0.18	7.84	-0.04	3.32	0.14	2.65	0.02	0.01	0.08	0.00
Col15	19	0.26	7.84	-0.04	3.32	0.14	2.65	0.03	0.01	0.09	0.00
Col15	20	0.15	7.84	-0.04	3.32	0.14	2.65	0.02	0.01	0.07	0.00
Col15	21	0.22	7.84	-0.04	3.32	0.14	2.65	0.03	0.01	0.08	0.00
Col15	22	0.10	7.84	-0.04	3.32	0.14	2.65	0.01	0.01	0.07	0.00
Col15	23	0.17	7.84	-0.04	3.32	0.14	2.65	0.02	0.01	0.07	0.00
Col15	24	0.15	7.84	-0.04	3.32	0.14	2.65	0.02	0.01	0.07	0.00
Col15	25	0.22	7.84	-0.04	3.32	0.14	2.65	0.03	0.01	0.08	0.00
Col15	26	0.10	7.84	-0.04	3.32	0.14	2.65	0.01	0.01	0.07	0.00
Col15	27	0.17	7.84	-0.04	3.32	0.14	2.65	0.02	0.01	0.07	0.00
Col15	28	-0.16	21.18	0.04	3.32	-0.16	2.65	0.01	0.01	0.05	0.00
Col15	29	-0.06	21.18	0.04	3.32	-0.16	2.65	0.00	0.01	0.06	0.00
Col15	30	-0.16	21.18	-0.05	3.32	0.19	2.65	0.01	0.01	0.06	0.00
Col15	31	-0.06	21.18	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00

Col15	32	-0.16	21.18	-0.05	3.32	0.19	2.65	0.01	0.01	0.06	0.00
Col15	33	-0.06	21.18	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00
Col15	34	-0.09	21.18	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00
Col15	35	0.01	7.84	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00
Col15	36	0.09	7.84	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col15	37	0.09	7.84	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col15	38	0.36	7.84	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col15	39	0.36	7.84	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col15	40	0.27	7.84	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col15	41	0.27	7.84	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col15	42	0.27	7.84	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col15	43	0.27	7.84	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col15	44	0.07	7.84	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col15	45	0.07	7.84	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col15	46	0.37	7.84	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col15	47	0.19	7.84	-0.04	3.32	0.14	2.65	0.02	0.01	0.08	0.00
Col15	48	0.26	7.84	-0.04	3.32	0.14	2.65	0.03	0.01	0.09	0.00
Col15	49	0.09	7.84	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col15	50	0.09	7.84	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col15	51	0.07	7.84	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col15	52	0.07	7.84	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col15	53	0.33	7.84	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col15	54	0.27	7.84	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col15	55	0.27	7.84	-0.04	3.32	0.14	2.65	0.03	0.01	0.09	0.00
Col15	56	0.27	7.84	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col16	1	0.85	10.49	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col16	2	0.15	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col16	3	0.62	10.49	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col16	4	0.62	10.49	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col16	5	0.68	10.49	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col16	6	0.50	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col16	7	0.50	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col16	8	-0.33	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col16	9	-0.13	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col16	10	-0.33	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col16	11	-0.13	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col16	12	-0.33	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col16	13	-0.13	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col16	14	-0.18	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col16	15	0.01	10.49	0.00	3.32	0.00	2.65	0.00	0.00	0.00	0.00
Col16	16	0.44	10.49	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col16	17	0.59	10.49	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col16	18	0.33	10.49	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col16	19	0.48	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col16	20	0.27	10.49	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col16	21	0.41	10.49	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col16	22	0.16	10.49	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col16	23	0.30	10.49	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col16	24	0.27	10.49	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col16	25	0.41	10.49	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col16	26	0.16	10.49	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col16	27	0.30	10.49	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col16	28	-0.35	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col16	29	-0.16	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col16	30	-0.35	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col16	31	-0.16	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col16	32	-0.35	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col16	33	-0.16	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col16	34	-0.21	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col16	35	-0.01	21.18	0.00	3.32	0.00	2.65	0.00	0.00	0.00	0.00
Col16	36	0.15	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col16	37	0.15	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col16	38	0.68	10.49	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col16	39	0.68	10.49	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col16	40	0.51	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00

Col16	41	0.51	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col16	42	0.51	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col16	43	0.51	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col16	44	0.10	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col16	45	0.10	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col16	46	0.71	10.49	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col16	47	0.34	10.49	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col16	48	0.48	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col16	49	0.15	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col16	50	0.15	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col16	51	0.11	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col16	52	0.11	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col16	53	0.62	10.49	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col16	54	0.50	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col16	55	0.50	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col16	56	0.51	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col17	1	0.85	10.49	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col17	2	0.15	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col17	3	0.62	10.49	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col17	4	0.62	10.49	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col17	5	0.68	10.49	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col17	6	0.50	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col17	7	0.50	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col17	8	-0.33	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col17	9	-0.13	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col17	10	-0.33	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col17	11	-0.13	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col17	12	-0.33	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col17	13	-0.13	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col17	14	-0.18	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col17	15	0.01	10.49	0.00	3.32	0.00	2.65	0.00	0.00	0.00	0.00
Col17	16	0.44	10.49	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col17	17	0.59	10.49	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col17	18	0.33	10.49	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col17	19	0.48	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col17	20	0.27	10.49	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col17	21	0.41	10.49	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col17	22	0.16	10.49	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col17	23	0.30	10.49	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col17	24	0.27	10.49	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col17	25	0.41	10.49	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col17	26	0.16	10.49	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col17	27	0.30	10.49	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col17	28	-0.35	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col17	29	-0.16	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col17	30	-0.35	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col17	31	-0.16	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col17	32	-0.35	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col17	33	-0.16	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col17	34	-0.21	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col17	35	-0.01	21.18	0.00	3.32	0.00	2.65	0.00	0.00	0.00	0.00
Col17	36	0.15	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col17	37	0.15	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col17	38	0.68	10.49	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col17	39	0.68	10.49	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col17	40	0.51	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col17	41	0.51	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col17	42	0.51	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col17	43	0.51	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col17	44	0.10	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col17	45	0.10	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col17	46	0.71	10.49	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col17	47	0.34	10.49	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col17	48	0.48	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col17	49	0.15	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00

Col17	50	0.15	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col17	51	0.11	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col17	52	0.11	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col17	53	0.62	10.49	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col17	54	0.50	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col17	55	0.50	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col17	56	0.51	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col18	1	0.85	10.49	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col18	2	0.15	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col18	3	0.62	10.49	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col18	4	0.62	10.49	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col18	5	0.68	10.49	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col18	6	0.50	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col18	7	0.50	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col18	8	-0.33	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col18	9	-0.13	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col18	10	-0.33	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col18	11	-0.13	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col18	12	-0.33	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col18	13	-0.13	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col18	14	-0.18	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col18	15	0.01	10.49	0.00	3.32	0.00	2.65	0.00	0.00	0.00	0.00
Col18	16	0.44	10.49	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col18	17	0.59	10.49	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col18	18	0.33	10.49	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col18	19	0.48	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col18	20	0.27	10.49	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col18	21	0.41	10.49	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col18	22	0.16	10.49	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col18	23	0.30	10.49	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col18	24	0.27	10.49	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col18	25	0.41	10.49	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col18	26	0.16	10.49	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col18	27	0.30	10.49	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col18	28	-0.35	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col18	29	-0.16	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col18	30	-0.35	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col18	31	-0.16	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col18	32	-0.35	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col18	33	-0.16	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col18	34	-0.21	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col18	35	-0.01	21.18	0.00	3.32	0.00	2.65	0.00	0.00	0.00	0.00
Col18	36	0.15	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col18	37	0.15	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col18	38	0.68	10.49	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col18	39	0.68	10.49	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col18	40	0.51	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col18	41	0.51	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col18	42	0.51	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col18	43	0.51	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col18	44	0.10	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col18	45	0.10	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col18	46	0.71	10.49	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col18	47	0.34	10.49	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col18	48	0.48	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col18	49	0.15	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col18	50	0.15	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col18	51	0.11	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col18	52	0.11	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col18	53	0.62	10.49	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col18	54	0.50	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col18	55	0.50	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col18	56	0.51	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col19	1	0.85	10.49	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col19	2	0.15	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00

Col19	3	0.62	10.49	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col19	4	0.62	10.49	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col19	5	0.68	10.49	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col19	6	0.50	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col19	7	0.50	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col19	8	-0.33	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col19	9	-0.13	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col19	10	-0.33	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col19	11	-0.13	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col19	12	-0.33	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col19	13	-0.13	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col19	14	-0.18	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col19	15	0.01	10.49	0.00	3.32	0.00	2.65	0.00	0.00	0.00	0.00
Col19	16	0.44	10.49	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col19	17	0.59	10.49	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col19	18	0.33	10.49	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col19	19	0.48	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col19	20	0.27	10.49	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col19	21	0.41	10.49	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col19	22	0.16	10.49	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col19	23	0.30	10.49	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col19	24	0.27	10.49	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col19	25	0.41	10.49	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col19	26	0.16	10.49	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col19	27	0.30	10.49	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col19	28	-0.35	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col19	29	-0.16	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col19	30	-0.35	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col19	31	-0.16	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col19	32	-0.35	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col19	33	-0.16	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col19	34	-0.21	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col19	35	-0.01	21.18	0.00	3.32	0.00	2.65	0.00	0.00	0.00	0.00
Col19	36	0.15	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col19	37	0.15	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col19	38	0.68	10.49	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col19	39	0.68	10.49	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col19	40	0.51	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col19	41	0.51	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col19	42	0.51	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col19	43	0.51	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col19	44	0.10	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col19	45	0.10	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col19	46	0.71	10.49	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col19	47	0.34	10.49	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col19	48	0.48	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col19	49	0.15	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col19	50	0.15	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col19	51	0.11	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col19	52	0.11	10.49	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col19	53	0.62	10.49	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col19	54	0.50	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col19	55	0.50	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col19	56	0.51	10.49	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col20	1	0.44	7.84	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col20	2	0.09	7.84	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col20	3	0.33	7.84	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col20	4	0.33	7.84	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col20	5	0.36	7.84	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col20	6	0.27	7.84	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col20	7	0.27	7.84	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col20	8	-0.15	21.18	0.04	3.32	-0.16	2.65	0.01	0.01	0.05	0.00
Col20	9	-0.05	21.18	0.04	3.32	-0.16	2.65	0.00	0.01	0.06	0.00
Col20	10	-0.15	21.18	-0.05	3.32	0.19	2.65	0.01	0.01	0.06	0.00
Col20	11	-0.05	21.18	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00

Col20	12	-0.15	21.18	-0.05	3.32	0.19	2.65	0.01	0.01	0.06	0.00
Col20	13	-0.05	21.18	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00
Col20	14	-0.07	21.18	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00
Col20	15	0.02	7.84	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00
Col20	16	0.24	7.84	-0.04	3.32	0.14	2.65	0.03	0.01	0.08	0.00
Col20	17	0.31	7.84	-0.04	3.32	0.14	2.65	0.04	0.01	0.09	0.00
Col20	18	0.18	7.84	-0.04	3.32	0.14	2.65	0.02	0.01	0.08	0.00
Col20	19	0.26	7.84	-0.04	3.32	0.14	2.65	0.03	0.01	0.09	0.00
Col20	20	0.15	7.84	-0.04	3.32	0.14	2.65	0.02	0.01	0.07	0.00
Col20	21	0.22	7.84	-0.04	3.32	0.14	2.65	0.03	0.01	0.08	0.00
Col20	22	0.10	7.84	-0.04	3.32	0.14	2.65	0.01	0.01	0.07	0.00
Col20	23	0.17	7.84	-0.04	3.32	0.14	2.65	0.02	0.01	0.07	0.00
Col20	24	0.15	7.84	-0.04	3.32	0.14	2.65	0.02	0.01	0.07	0.00
Col20	25	0.22	7.84	-0.04	3.32	0.14	2.65	0.03	0.01	0.08	0.00
Col20	26	0.10	7.84	-0.04	3.32	0.14	2.65	0.01	0.01	0.07	0.00
Col20	27	0.17	7.84	-0.04	3.32	0.14	2.65	0.02	0.01	0.07	0.00
Col20	28	-0.16	21.18	0.04	3.32	-0.16	2.65	0.01	0.01	0.05	0.00
Col20	29	-0.06	21.18	0.04	3.32	-0.16	2.65	0.00	0.01	0.06	0.00
Col20	30	-0.16	21.18	-0.05	3.32	0.19	2.65	0.01	0.01	0.06	0.00
Col20	31	-0.06	21.18	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00
Col20	32	-0.16	21.18	-0.05	3.32	0.19	2.65	0.01	0.01	0.06	0.00
Col20	33	-0.06	21.18	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00
Col20	34	-0.09	21.18	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00
Col20	35	0.01	7.84	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00
Col20	36	0.09	7.84	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col20	37	0.09	7.84	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col20	38	0.36	7.84	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col20	39	0.36	7.84	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col20	40	0.27	7.84	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col20	41	0.27	7.84	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col20	42	0.27	7.84	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col20	43	0.27	7.84	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col20	44	0.07	7.84	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col20	45	0.07	7.84	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col20	46	0.37	7.84	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col20	47	0.19	7.84	-0.04	3.32	0.14	2.65	0.02	0.01	0.08	0.00
Col20	48	0.26	7.84	-0.04	3.32	0.14	2.65	0.03	0.01	0.09	0.00
Col20	49	0.09	7.84	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col20	50	0.09	7.84	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col20	51	0.07	7.84	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col20	52	0.07	7.84	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col20	53	0.33	7.84	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col20	54	0.27	7.84	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col20	55	0.27	7.84	-0.04	3.32	0.14	2.65	0.03	0.01	0.09	0.00
Col20	56	0.27	7.84	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00

Raf1	1	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf1	2	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf1	3	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf1	4	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf1	5	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf1	6	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf1	7	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf1	8	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf1	9	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf1	10	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf1	11	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf1	12	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf1	13	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf1	14	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf1	15	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf1	16	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf1	17	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf1	18	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf1	19	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00

[illegible]

[illegible]

Raf3	38	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf3	39	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf3	40	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf3	41	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf3	42	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf3	43	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf3	44	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf3	45	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf3	46	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf3	47	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf3	48	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf3	49	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf3	50	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf3	51	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf3	52	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf3	53	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf3	54	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf3	55	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf3	56	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00

COLUMN REACTIONS:

Id	Load		In_Plane		Out_Plane
	Id	Vert(k)	Horz(k)	Horz(k)	
-----	-----	-----	-----	-----	
Col15	1	0.44	0.00	0.00	
Col15	2	0.09	0.00	0.00	
Col15	3	0.33	0.00	0.00	
Col15	4	0.33	0.00	0.00	
Col15	5	0.36	0.00	0.00	
Col15	6	0.27	0.00	0.00	
Col15	7	0.27	0.00	0.00	
Col15	8	-0.15	0.00	-0.04	
Col15	9	-0.05	0.00	-0.04	
Col15	10	-0.15	0.00	0.05	
Col15	11	-0.05	0.00	0.05	
Col15	12	-0.15	0.00	0.05	
Col15	13	-0.05	0.00	0.05	
Col15	14	-0.07	0.00	0.05	
Col15	15	0.02	0.00	0.05	
Col15	16	0.24	0.00	0.04	
Col15	17	0.31	0.00	0.04	
Col15	18	0.18	0.00	0.04	
Col15	19	0.26	0.00	0.04	
Col15	20	0.15	0.00	0.04	
Col15	21	0.22	0.00	0.04	
Col15	22	0.10	0.00	0.04	
Col15	23	0.17	0.00	0.04	
Col15	24	0.15	0.00	0.04	
Col15	25	0.22	0.00	0.04	
Col15	26	0.10	0.00	0.04	
Col15	27	0.17	0.00	0.04	
Col15	28	-0.16	0.00	-0.04	
Col15	29	-0.06	0.00	-0.04	
Col15	30	-0.16	0.00	0.05	
Col15	31	-0.06	0.00	0.05	
Col15	32	-0.16	0.00	0.05	
Col15	33	-0.06	0.00	0.05	
Col15	34	-0.09	0.00	0.05	
Col15	35	0.01	0.00	0.05	
Col15	36	0.09	0.00	0.00	
Col15	37	0.09	0.00	0.00	
Col15	38	0.36	0.00	0.00	
Col15	39	0.36	0.00	0.00	
Col15	40	0.27	0.00	0.00	

Col15	41	0.27	0.00	0.00
Col15	42	0.27	0.00	0.00
Col15	43	0.27	0.00	0.00
Col15	44	0.07	0.00	0.00
Col15	45	0.07	0.00	0.00
Col15	46	0.37	0.00	0.00
Col15	47	0.19	0.00	0.04
Col15	48	0.26	0.00	0.04
Col15	49	0.09	0.00	0.00
Col15	50	0.09	0.00	0.00
Col15	51	0.07	0.00	0.00
Col15	52	0.07	0.00	0.00
Col15	53	0.33	0.00	0.00
Col15	54	0.27	0.00	0.00
Col15	55	0.27	0.00	0.04
Col15	56	0.27	0.00	0.00
Col16	1	0.85	0.00	0.00
Col16	2	0.15	0.00	0.00
Col16	3	0.62	0.00	0.00
Col16	4	0.62	0.00	0.00
Col16	5	0.68	0.00	0.00
Col16	6	0.50	0.00	0.00
Col16	7	0.50	0.00	0.00
Col16	8	-0.33	0.00	0.00
Col16	9	-0.13	0.00	0.00
Col16	10	-0.33	0.00	0.00
Col16	11	-0.13	0.00	0.00
Col16	12	-0.33	0.00	0.00
Col16	13	-0.13	0.00	0.00
Col16	14	-0.18	0.00	0.00
Col16	15	0.01	0.00	0.00
Col16	16	0.44	0.00	0.00
Col16	17	0.59	0.00	0.00
Col16	18	0.33	0.00	0.00
Col16	19	0.48	0.00	0.00
Col16	20	0.27	0.00	0.00
Col16	21	0.41	0.00	0.00
Col16	22	0.16	0.00	0.00
Col16	23	0.30	0.00	0.00
Col16	24	0.27	0.00	0.00
Col16	25	0.41	0.00	0.00
Col16	26	0.16	0.00	0.00
Col16	27	0.30	0.00	0.00
Col16	28	-0.35	0.00	0.00
Col16	29	-0.16	0.00	0.00
Col16	30	-0.35	0.00	0.00
Col16	31	-0.16	0.00	0.00
Col16	32	-0.35	0.00	0.00
Col16	33	-0.16	0.00	0.00
Col16	34	-0.21	0.00	0.00
Col16	35	-0.01	0.00	0.00
Col16	36	0.15	0.00	0.00
Col16	37	0.15	0.00	0.00
Col16	38	0.68	0.00	0.00
Col16	39	0.68	0.00	0.00
Col16	40	0.51	0.00	0.00
Col16	41	0.51	0.00	0.00
Col16	42	0.51	0.00	0.00
Col16	43	0.51	0.00	0.00
Col16	44	0.10	0.00	0.00
Col16	45	0.10	0.00	0.00
Col16	46	0.71	0.00	0.00
Col16	47	0.34	0.00	0.00
Col16	48	0.48	0.00	0.00
Col16	49	0.15	0.00	0.00

Col16	50	0.15	0.00	0.00
Col16	51	0.11	0.00	0.00
Col16	52	0.11	0.00	0.00
Col16	53	0.62	0.00	0.00
Col16	54	0.50	0.00	0.00
Col16	55	0.50	0.00	0.00
Col16	56	0.51	0.00	0.00
Col17	1	0.85	0.00	0.00
Col17	2	0.15	0.00	0.00
Col17	3	0.62	0.00	0.00
Col17	4	0.62	0.00	0.00
Col17	5	0.68	0.00	0.00
Col17	6	0.50	0.00	0.00
Col17	7	0.50	0.00	0.00
Col17	8	-0.33	0.00	0.00
Col17	9	-0.13	0.00	0.00
Col17	10	-0.33	0.00	0.00
Col17	11	-0.13	0.00	0.00
Col17	12	-0.33	0.00	0.00
Col17	13	-0.13	0.00	0.00
Col17	14	-0.18	0.00	0.00
Col17	15	0.01	0.00	0.00
Col17	16	0.44	0.00	0.00
Col17	17	0.59	0.00	0.00
Col17	18	0.33	0.00	0.00
Col17	19	0.48	0.00	0.00
Col17	20	0.27	0.00	0.00
Col17	21	0.41	0.00	0.00
Col17	22	0.16	0.00	0.00
Col17	23	0.30	0.00	0.00
Col17	24	0.27	0.00	0.00
Col17	25	0.41	0.00	0.00
Col17	26	0.16	0.00	0.00
Col17	27	0.30	0.00	0.00
Col17	28	-0.35	0.00	0.00
Col17	29	-0.16	0.00	0.00
Col17	30	-0.35	0.00	0.00
Col17	31	-0.16	0.00	0.00
Col17	32	-0.35	0.00	0.00
Col17	33	-0.16	0.00	0.00
Col17	34	-0.21	0.00	0.00
Col17	35	-0.01	0.00	0.00
Col17	36	0.15	0.00	0.00
Col17	37	0.15	0.00	0.00
Col17	38	0.68	0.00	0.00
Col17	39	0.68	0.00	0.00
Col17	40	0.51	0.00	0.00
Col17	41	0.51	0.00	0.00
Col17	42	0.51	0.00	0.00
Col17	43	0.51	0.00	0.00
Col17	44	0.10	0.00	0.00
Col17	45	0.10	0.00	0.00
Col17	46	0.71	0.00	0.00
Col17	47	0.34	0.00	0.00
Col17	48	0.48	0.00	0.00
Col17	49	0.15	0.00	0.00
Col17	50	0.15	0.00	0.00
Col17	51	0.11	0.00	0.00
Col17	52	0.11	0.00	0.00
Col17	53	0.62	0.00	0.00
Col17	54	0.50	0.00	0.00
Col17	55	0.50	0.00	0.00
Col17	56	0.51	0.00	0.00
Col18	1	0.85	0.00	0.00
Col18	2	0.15	0.00	0.00

Col18	3	0.62	0.00	0.00
Col18	4	0.62	0.00	0.00
Col18	5	0.68	0.00	0.00
Col18	6	0.50	0.00	0.00
Col18	7	0.50	0.00	0.00
Col18	8	-0.33	0.00	0.00
Col18	9	-0.13	0.00	0.00
Col18	10	-0.33	0.00	0.00
Col18	11	-0.13	0.00	0.00
Col18	12	-0.33	0.00	0.00
Col18	13	-0.13	0.00	0.00
Col18	14	-0.18	0.00	0.00
Col18	15	0.01	0.00	0.00
Col18	16	0.44	0.00	0.00
Col18	17	0.59	0.00	0.00
Col18	18	0.33	0.00	0.00
Col18	19	0.48	0.00	0.00
Col18	20	0.27	0.00	0.00
Col18	21	0.41	0.00	0.00
Col18	22	0.16	0.00	0.00
Col18	23	0.30	0.00	0.00
Col18	24	0.27	0.00	0.00
Col18	25	0.41	0.00	0.00
Col18	26	0.16	0.00	0.00
Col18	27	0.30	0.00	0.00
Col18	28	-0.35	0.00	0.00
Col18	29	-0.16	0.00	0.00
Col18	30	-0.35	0.00	0.00
Col18	31	-0.16	0.00	0.00
Col18	32	-0.35	0.00	0.00
Col18	33	-0.16	0.00	0.00
Col18	34	-0.21	0.00	0.00
Col18	35	-0.01	0.00	0.00
Col18	36	0.15	0.00	0.00
Col18	37	0.15	0.00	0.00
Col18	38	0.68	0.00	0.00
Col18	39	0.68	0.00	0.00
Col18	40	0.51	0.00	0.00
Col18	41	0.51	0.00	0.00
Col18	42	0.51	0.00	0.00
Col18	43	0.51	0.00	0.00
Col18	44	0.10	0.00	0.00
Col18	45	0.10	0.00	0.00
Col18	46	0.71	0.00	0.00
Col18	47	0.34	0.00	0.00
Col18	48	0.48	0.00	0.00
Col18	49	0.15	0.00	0.00
Col18	50	0.15	0.00	0.00
Col18	51	0.11	0.00	0.00
Col18	52	0.11	0.00	0.00
Col18	53	0.62	0.00	0.00
Col18	54	0.50	0.00	0.00
Col18	55	0.50	0.00	0.00
Col18	56	0.51	0.00	0.00
Col19	1	0.85	0.00	0.00
Col19	2	0.15	0.00	0.00
Col19	3	0.62	0.00	0.00
Col19	4	0.62	0.00	0.00
Col19	5	0.68	0.00	0.00
Col19	6	0.50	0.00	0.00
Col19	7	0.50	0.00	0.00
Col19	8	-0.33	0.00	0.00
Col19	9	-0.13	0.00	0.00
Col19	10	-0.33	0.00	0.00
Col19	11	-0.13	0.00	0.00

Col119	12	-0.33	0.00	0.00
Col119	13	-0.13	0.00	0.00
Col119	14	-0.18	0.00	0.00
Col119	15	0.01	0.00	0.00
Col119	16	0.44	0.00	0.00
Col119	17	0.59	0.00	0.00
Col119	18	0.33	0.00	0.00
Col119	19	0.48	0.00	0.00
Col119	20	0.27	0.00	0.00
Col119	21	0.41	0.00	0.00
Col119	22	0.16	0.00	0.00
Col119	23	0.30	0.00	0.00
Col119	24	0.27	0.00	0.00
Col119	25	0.41	0.00	0.00
Col119	26	0.16	0.00	0.00
Col119	27	0.30	0.00	0.00
Col119	28	-0.35	0.00	0.00
Col119	29	-0.16	0.00	0.00
Col119	30	-0.35	0.00	0.00
Col119	31	-0.16	0.00	0.00
Col119	32	-0.35	0.00	0.00
Col119	33	-0.16	0.00	0.00
Col119	34	-0.21	0.00	0.00
Col119	35	-0.01	0.00	0.00
Col119	36	0.15	0.00	0.00
Col119	37	0.15	0.00	0.00
Col119	38	0.68	0.00	0.00
Col119	39	0.68	0.00	0.00
Col119	40	0.51	0.00	0.00
Col119	41	0.51	0.00	0.00
Col119	42	0.51	0.00	0.00
Col119	43	0.51	0.00	0.00
Col119	44	0.10	0.00	0.00
Col119	45	0.10	0.00	0.00
Col119	46	0.71	0.00	0.00
Col119	47	0.34	0.00	0.00
Col119	48	0.48	0.00	0.00
Col119	49	0.15	0.00	0.00
Col119	50	0.15	0.00	0.00
Col119	51	0.11	0.00	0.00
Col119	52	0.11	0.00	0.00
Col119	53	0.62	0.00	0.00
Col119	54	0.50	0.00	0.00
Col119	55	0.50	0.00	0.00
Col119	56	0.51	0.00	0.00
Col120	1	0.44	0.00	0.00
Col120	2	0.09	0.00	0.00
Col120	3	0.33	0.00	0.00
Col120	4	0.33	0.00	0.00
Col120	5	0.36	0.00	0.00
Col120	6	0.27	0.00	0.00
Col120	7	0.27	0.00	0.00
Col120	8	-0.15	0.00	-0.04
Col120	9	-0.05	0.00	-0.04
Col120	10	-0.15	0.00	0.05
Col120	11	-0.05	0.00	0.05
Col120	12	-0.15	0.00	0.05
Col120	13	-0.05	0.00	0.05
Col120	14	-0.07	0.00	0.05
Col120	15	0.02	0.00	0.05
Col120	16	0.24	0.00	0.04
Col120	17	0.31	0.00	0.04
Col120	18	0.18	0.00	0.04
Col120	19	0.26	0.00	0.04
Col120	20	0.15	0.00	0.04

Col20	21	0.22	0.00	0.04
Col20	22	0.10	0.00	0.04
Col20	23	0.17	0.00	0.04
Col20	24	0.15	0.00	0.04
Col20	25	0.22	0.00	0.04
Col20	26	0.10	0.00	0.04
Col20	27	0.17	0.00	0.04
Col20	28	-0.16	0.00	-0.04
Col20	29	-0.06	0.00	-0.04
Col20	30	-0.16	0.00	0.05
Col20	31	-0.06	0.00	0.05
Col20	32	-0.16	0.00	0.05
Col20	33	-0.06	0.00	0.05
Col20	34	-0.09	0.00	0.05
Col20	35	0.01	0.00	0.05
Col20	36	0.09	0.00	0.00
Col20	37	0.09	0.00	0.00
Col20	38	0.36	0.00	0.00
Col20	39	0.36	0.00	0.00
Col20	40	0.27	0.00	0.00
Col20	41	0.27	0.00	0.00
Col20	42	0.27	0.00	0.00
Col20	43	0.27	0.00	0.00
Col20	44	0.07	0.00	0.00
Col20	45	0.07	0.00	0.00
Col20	46	0.37	0.00	0.00
Col20	47	0.19	0.00	0.04
Col20	48	0.26	0.00	0.04
Col20	49	0.09	0.00	0.00
Col20	50	0.09	0.00	0.00
Col20	51	0.07	0.00	0.00
Col20	52	0.07	0.00	0.00
Col20	53	0.33	0.00	0.00
Col20	54	0.27	0.00	0.00
Col20	55	0.27	0.00	0.04
Col20	56	0.27	0.00	0.00

COLUMN DEFLECTIONS:

Id	Load	Deflection(in)	
	Id	Calc	Limit
Col15	1	0.00	1.06
Col15	2	0.00	1.06
Col15	3	0.00	1.06
Col15	4	0.00	1.06
Col15	5	0.00	1.06
Col15	6	0.00	1.06
Col15	7	0.00	1.06
Col15	8	-0.07	1.06
Col15	9	-0.07	1.06
Col15	10	0.08	1.06
Col15	11	0.08	1.06
Col15	12	0.08	1.06
Col15	13	0.08	1.06
Col15	14	0.08	1.06
Col15	15	0.08	1.06
Col15	16	0.06	1.06
Col15	17	0.06	1.06
Col15	18	0.06	1.06
Col15	19	0.06	1.06
Col15	20	0.06	1.06
Col15	21	0.06	1.06
Col15	22	0.06	1.06
Col15	23	0.06	1.06

Col15	24	0.06	1.06
Col15	25	0.06	1.06
Col15	26	0.06	1.06
Col15	27	0.06	1.06
Col15	28	-0.07	1.06
Col15	29	-0.07	1.06
Col15	30	0.08	1.06
Col15	31	0.08	1.06
Col15	32	0.08	1.06
Col15	33	0.08	1.06
Col15	34	0.08	1.06
Col15	35	0.08	1.06
Col15	36	0.00	1.06
Col15	37	0.00	1.06
Col15	38	0.00	1.06
Col15	39	0.00	1.06
Col15	40	0.00	1.06
Col15	41	0.00	1.06
Col15	42	0.00	1.06
Col15	43	0.00	1.06
Col15	44	0.00	1.06
Col15	45	0.00	1.06
Col15	46	0.00	1.06
Col15	47	0.03	1.06
Col15	48	0.03	1.06
Col15	49	0.00	1.06
Col15	50	0.00	1.06
Col15	51	0.06	1.06
Col15	52	0.00	1.06
Col16	1	0.00	1.06
Col16	2	0.00	1.06
Col16	3	0.00	1.06
Col16	4	0.00	1.06
Col16	5	0.00	1.06
Col16	6	0.00	1.06
Col16	7	0.00	1.06
Col16	8	0.00	1.06
Col16	9	0.00	1.06
Col16	10	0.00	1.06
Col16	11	0.00	1.06
Col16	12	0.00	1.06
Col16	13	0.00	1.06
Col16	14	0.00	1.06
Col16	15	0.00	1.06
Col16	16	0.00	1.06
Col16	17	0.00	1.06
Col16	18	0.00	1.06
Col16	19	0.00	1.06
Col16	20	0.00	1.06
Col16	21	0.00	1.06
Col16	22	0.00	1.06
Col16	23	0.00	1.06
Col16	24	0.00	1.06
Col16	25	0.00	1.06
Col16	26	0.00	1.06
Col16	27	0.00	1.06
Col16	28	0.00	1.06
Col16	29	0.00	1.06
Col16	30	0.00	1.06
Col16	31	0.00	1.06
Col16	32	0.00	1.06
Col16	33	0.00	1.06
Col16	34	0.00	1.06
Col16	35	0.00	1.06
Col16	36	0.00	1.06

Col16	37	0.00	1.06
Col16	38	0.00	1.06
Col16	39	0.00	1.06
Col16	40	0.00	1.06
Col16	41	0.00	1.06
Col16	42	0.00	1.06
Col16	43	0.00	1.06
Col16	44	0.00	1.06
Col16	45	0.00	1.06
Col16	46	0.00	1.06
Col16	47	0.00	1.06
Col16	48	0.00	1.06
Col16	49	0.00	1.06
Col16	50	0.00	1.06
Col16	51	0.00	1.06
Col16	52	0.00	1.06
Col17	1	0.00	1.06
Col17	2	0.00	1.06
Col17	3	0.00	1.06
Col17	4	0.00	1.06
Col17	5	0.00	1.06
Col17	6	0.00	1.06
Col17	7	0.00	1.06
Col17	8	0.00	1.06
Col17	9	0.00	1.06
Col17	10	0.00	1.06
Col17	11	0.00	1.06
Col17	12	0.00	1.06
Col17	13	0.00	1.06
Col17	14	0.00	1.06
Col17	15	0.00	1.06
Col17	16	0.00	1.06
Col17	17	0.00	1.06
Col17	18	0.00	1.06
Col17	19	0.00	1.06
Col17	20	0.00	1.06
Col17	21	0.00	1.06
Col17	22	0.00	1.06
Col17	23	0.00	1.06
Col17	24	0.00	1.06
Col17	25	0.00	1.06
Col17	26	0.00	1.06
Col17	27	0.00	1.06
Col17	28	0.00	1.06
Col17	29	0.00	1.06
Col17	30	0.00	1.06
Col17	31	0.00	1.06
Col17	32	0.00	1.06
Col17	33	0.00	1.06
Col17	34	0.00	1.06
Col17	35	0.00	1.06
Col17	36	0.00	1.06
Col17	37	0.00	1.06
Col17	38	0.00	1.06
Col17	39	0.00	1.06
Col17	40	0.00	1.06
Col17	41	0.00	1.06
Col17	42	0.00	1.06
Col17	43	0.00	1.06
Col17	44	0.00	1.06
Col17	45	0.00	1.06
Col17	46	0.00	1.06
Col17	47	0.00	1.06
Col17	48	0.00	1.06
Col17	49	0.00	1.06

Col17	50	0.00	1.06
Col17	51	0.00	1.06
Col17	52	0.00	1.06
Col18	1	0.00	1.06
Col18	2	0.00	1.06
Col18	3	0.00	1.06
Col18	4	0.00	1.06
Col18	5	0.00	1.06
Col18	6	0.00	1.06
Col18	7	0.00	1.06
Col18	8	0.00	1.06
Col18	9	0.00	1.06
Col18	10	0.00	1.06
Col18	11	0.00	1.06
Col18	12	0.00	1.06
Col18	13	0.00	1.06
Col18	14	0.00	1.06
Col18	15	0.00	1.06
Col18	16	0.00	1.06
Col18	17	0.00	1.06
Col18	18	0.00	1.06
Col18	19	0.00	1.06
Col18	20	0.00	1.06
Col18	21	0.00	1.06
Col18	22	0.00	1.06
Col18	23	0.00	1.06
Col18	24	0.00	1.06
Col18	25	0.00	1.06
Col18	26	0.00	1.06
Col18	27	0.00	1.06
Col18	28	0.00	1.06
Col18	29	0.00	1.06
Col18	30	0.00	1.06
Col18	31	0.00	1.06
Col18	32	0.00	1.06
Col18	33	0.00	1.06
Col18	34	0.00	1.06
Col18	35	0.00	1.06
Col18	36	0.00	1.06
Col18	37	0.00	1.06
Col18	38	0.00	1.06
Col18	39	0.00	1.06
Col18	40	0.00	1.06
Col18	41	0.00	1.06
Col18	42	0.00	1.06
Col18	43	0.00	1.06
Col18	44	0.00	1.06
Col18	45	0.00	1.06
Col18	46	0.00	1.06
Col18	47	0.00	1.06
Col18	48	0.00	1.06
Col18	49	0.00	1.06
Col18	50	0.00	1.06
Col18	51	0.00	1.06
Col18	52	0.00	1.06
Col19	1	0.00	1.06
Col19	2	0.00	1.06
Col19	3	0.00	1.06
Col19	4	0.00	1.06
Col19	5	0.00	1.06
Col19	6	0.00	1.06
Col19	7	0.00	1.06
Col19	8	0.00	1.06
Col19	9	0.00	1.06
Col19	10	0.00	1.06

Col19	11	0.00	1.06
Col19	12	0.00	1.06
Col19	13	0.00	1.06
Col19	14	0.00	1.06
Col19	15	0.00	1.06
Col19	16	0.00	1.06
Col19	17	0.00	1.06
Col19	18	0.00	1.06
Col19	19	0.00	1.06
Col19	20	0.00	1.06
Col19	21	0.00	1.06
Col19	22	0.00	1.06
Col19	23	0.00	1.06
Col19	24	0.00	1.06
Col19	25	0.00	1.06
Col19	26	0.00	1.06
Col19	27	0.00	1.06
Col19	28	0.00	1.06
Col19	29	0.00	1.06
Col19	30	0.00	1.06
Col19	31	0.00	1.06
Col19	32	0.00	1.06
Col19	33	0.00	1.06
Col19	34	0.00	1.06
Col19	35	0.00	1.06
Col19	36	0.00	1.06
Col19	37	0.00	1.06
Col19	38	0.00	1.06
Col19	39	0.00	1.06
Col19	40	0.00	1.06
Col19	41	0.00	1.06
Col19	42	0.00	1.06
Col19	43	0.00	1.06
Col19	44	0.00	1.06
Col19	45	0.00	1.06
Col19	46	0.00	1.06
Col19	47	0.00	1.06
Col19	48	0.00	1.06
Col19	49	0.00	1.06
Col19	50	0.00	1.06
Col19	51	0.00	1.06
Col19	52	0.00	1.06
Col20	1	0.00	1.06
Col20	2	0.00	1.06
Col20	3	0.00	1.06
Col20	4	0.00	1.06
Col20	5	0.00	1.06
Col20	6	0.00	1.06
Col20	7	0.00	1.06
Col20	8	-0.07	1.06
Col20	9	-0.07	1.06
Col20	10	0.08	1.06
Col20	11	0.08	1.06
Col20	12	0.08	1.06
Col20	13	0.08	1.06
Col20	14	0.08	1.06
Col20	15	0.08	1.06
Col20	16	0.06	1.06
Col20	17	0.06	1.06
Col20	18	0.06	1.06
Col20	19	0.06	1.06
Col20	20	0.06	1.06
Col20	21	0.06	1.06
Col20	22	0.06	1.06
Col20	23	0.06	1.06

Col20	24	0.06	1.06
Col20	25	0.06	1.06
Col20	26	0.06	1.06
Col20	27	0.06	1.06
Col20	28	-0.07	1.06
Col20	29	-0.07	1.06
Col20	30	0.08	1.06
Col20	31	0.08	1.06
Col20	32	0.08	1.06
Col20	33	0.08	1.06
Col20	34	0.08	1.06
Col20	35	0.08	1.06
Col20	36	0.00	1.06
Col20	37	0.00	1.06
Col20	38	0.00	1.06
Col20	39	0.00	1.06
Col20	40	0.00	1.06
Col20	41	0.00	1.06
Col20	42	0.00	1.06
Col20	43	0.00	1.06
Col20	44	0.00	1.06
Col20	45	0.00	1.06
Col20	46	0.00	1.06
Col20	47	0.03	1.06
Col20	48	0.03	1.06
Col20	49	0.00	1.06
Col20	50	0.00	1.06
Col20	51	0.06	1.06
Col20	52	0.00	1.06

RAFTER DEFLECTIONS:

Id	Load	Deflection(in)	
	Id	Calc	Limit
-----	----	-----	-----
Raf1	1	0.00	0.93
Raf1	2	0.00	0.93
Raf1	3	0.00	0.93
Raf1	4	0.00	0.93
Raf1	5	0.00	0.93
Raf1	6	0.00	0.93
Raf1	7	0.00	0.93
Raf1	8	0.00	0.93
Raf1	9	0.00	0.93
Raf1	10	0.00	0.93
Raf1	11	0.00	0.93
Raf1	12	0.00	0.93
Raf1	13	0.00	0.93
Raf1	14	0.00	0.93
Raf1	15	0.00	0.93
Raf1	16	0.00	0.93
Raf1	17	0.00	0.93
Raf1	18	0.00	0.93
Raf1	19	0.00	0.93
Raf1	20	0.00	0.93
Raf1	21	0.00	0.93
Raf1	22	0.00	0.93
Raf1	23	0.00	0.93
Raf1	24	0.00	0.93
Raf1	25	0.00	0.93
Raf1	26	0.00	0.93
Raf1	27	0.00	0.93
Raf1	28	0.00	0.93
Raf1	29	0.00	0.93
Raf1	30	0.00	0.93

Raf1	31	0.00	0.93
Raf1	32	0.00	0.93
Raf1	33	0.00	0.93
Raf1	34	0.00	0.93
Raf1	35	0.00	0.93
Raf1	36	0.00	0.93
Raf1	37	0.00	0.93
Raf1	38	0.00	0.93
Raf1	39	0.00	0.93
Raf1	40	0.00	0.93
Raf1	41	0.00	0.93
Raf1	42	0.00	0.93
Raf1	43	0.00	0.93
Raf1	44	0.00	0.93
Raf1	45	0.00	0.93
Raf1	46	0.00	0.93
Raf1	47	0.00	0.93
Raf1	48	0.00	0.93
Raf1	49	0.00	0.93
Raf1	50	0.00	0.93
Raf1	51	0.00	0.93
Raf1	52	0.00	0.93
Raf2	1	0.00	0.93
Raf2	2	0.00	0.93
Raf2	3	0.00	0.93
Raf2	4	0.00	0.93
Raf2	5	0.00	0.93
Raf2	6	0.00	0.93
Raf2	7	0.00	0.93
Raf2	8	0.00	0.93
Raf2	9	0.00	0.93
Raf2	10	0.00	0.93
Raf2	11	0.00	0.93
Raf2	12	0.00	0.93
Raf2	13	0.00	0.93
Raf2	14	0.00	0.93
Raf2	15	0.00	0.93
Raf2	16	0.00	0.93
Raf2	17	0.00	0.93
Raf2	18	0.00	0.93
Raf2	19	0.00	0.93
Raf2	20	0.00	0.93
Raf2	21	0.00	0.93
Raf2	22	0.00	0.93
Raf2	23	0.00	0.93
Raf2	24	0.00	0.93
Raf2	25	0.00	0.93
Raf2	26	0.00	0.93
Raf2	27	0.00	0.93
Raf2	28	0.00	0.93
Raf2	29	0.00	0.93
Raf2	30	0.00	0.93
Raf2	31	0.00	0.93
Raf2	32	0.00	0.93
Raf2	33	0.00	0.93
Raf2	34	0.00	0.93
Raf2	35	0.00	0.93
Raf2	36	0.00	0.93
Raf2	37	0.00	0.93
Raf2	38	0.00	0.93
Raf2	39	0.00	0.93
Raf2	40	0.00	0.93
Raf2	41	0.00	0.93
Raf2	42	0.00	0.93
Raf2	43	0.00	0.93

Raf2	44	0.00	0.93
Raf2	45	0.00	0.93
Raf2	46	0.00	0.93
Raf2	47	0.00	0.93
Raf2	48	0.00	0.93
Raf2	49	0.00	0.93
Raf2	50	0.00	0.93
Raf2	51	0.00	0.93
Raf2	52	0.00	0.93
Raf3	1	0.00	0.93
Raf3	2	0.00	0.93
Raf3	3	0.00	0.93
Raf3	4	0.00	0.93
Raf3	5	0.00	0.93
Raf3	6	0.00	0.93
Raf3	7	0.00	0.93
Raf3	8	0.00	0.93
Raf3	9	0.00	0.93
Raf3	10	0.00	0.93
Raf3	11	0.00	0.93
Raf3	12	0.00	0.93
Raf3	13	0.00	0.93
Raf3	14	0.00	0.93
Raf3	15	0.00	0.93
Raf3	16	0.00	0.93
Raf3	17	0.00	0.93
Raf3	18	0.00	0.93
Raf3	19	0.00	0.93
Raf3	20	0.00	0.93
Raf3	21	0.00	0.93
Raf3	22	0.00	0.93
Raf3	23	0.00	0.93
Raf3	24	0.00	0.93
Raf3	25	0.00	0.93
Raf3	26	0.00	0.93
Raf3	27	0.00	0.93
Raf3	28	0.00	0.93
Raf3	29	0.00	0.93
Raf3	30	0.00	0.93
Raf3	31	0.00	0.93
Raf3	32	0.00	0.93
Raf3	33	0.00	0.93
Raf3	34	0.00	0.93
Raf3	35	0.00	0.93
Raf3	36	0.00	0.93
Raf3	37	0.00	0.93
Raf3	38	0.00	0.93
Raf3	39	0.00	0.93
Raf3	40	0.00	0.93
Raf3	41	0.00	0.93
Raf3	42	0.00	0.93
Raf3	43	0.00	0.93
Raf3	44	0.00	0.93
Raf3	45	0.00	0.93
Raf3	46	0.00	0.93
Raf3	47	0.00	0.93
Raf3	48	0.00	0.93
Raf3	49	0.00	0.93
Raf3	50	0.00	0.93
Raf3	51	0.00	0.93
Raf3	52	0.00	0.93

COLUMN KL/R RATIO, MOMENT REDUCTION:

Available
Reduction

Id	Major	--Minor (ft)--		----KL/R----		Factor	
	(ft)	Bend	Axial	Major	Minor	Out	In
Col15	15.9	4.0	4.0	82	64	0.00	0.00
Col16	0.1	4.0	4.0	1	64	0.00	0.00
Col17	0.1	4.0	4.0	1	64	0.00	0.00
Col18	0.1	4.0	4.0	1	64	0.00	0.00
Col19	0.1	4.0	4.0	1	64	0.00	0.00
Col20	15.9	4.0	4.0	82	64	0.00	0.00

JAMB/HEADER LAYOUT:

Bay	Id	Part	Length	Weight
----	-----	-----	-----	-----
1	JambL	PBMJ6	15.88	55.3
	JambR	PBMJ6	15.88	55.3
	Header	6X25C16	12.00	28.1
2	JambL	PBMJ6	15.88	55.3
	JambR	PBMJ6	15.88	55.3
	Header	6X25C16	12.00	28.1
3	JambL	PBMJ6	15.88	55.3
	JambR	PBMJ6	15.88	55.3
	Header	6X25C16	12.00	28.1
4	JambL	PBMJ6	15.88	55.3
	JambR	PBMJ6	15.88	55.3
	Header	6X25C16	12.00	28.1
5	JambL	PBMJ6	15.88	55.3
	JambR	PBMJ6	15.88	55.3
	Header	6X25C16	12.00	28.1

STRENGTH/DEFLECTION:

Bay	Id	Load	-Shear(k)-		Moment(f-k)		Max	Deflect(in)	
----	-----	-----	Calc	Limit	Calc	Limit	UC	Calc	Limit
----	-----	-----	-----	-----	-----	-----	-----	-----	-----
1	JambL	WP	-0.52	5.26	-2.06	3.90	0.53	-0.27	2.12
		WS	0.61	5.26	2.42	3.90	0.62	0.32	2.12
	JambR	WP	-0.52	5.26	-2.06	3.90	0.53	-0.27	2.12
		WS	0.57	5.26	2.27	3.90	0.58	0.30	2.12
	Header	WP	-0.06	3.86	-0.17	0.98	0.17	-0.02	1.60
		WS	0.06	3.86	0.19	1.93	0.10	0.02	1.60
2	JambL	WP	-0.52	5.26	-2.06	3.90	0.53	-0.27	2.12
		WS	0.57	5.26	2.27	3.90	0.58	0.30	2.12
	JambR	WP	-0.52	5.26	-2.06	3.90	0.53	-0.27	2.12
		WS	0.57	5.26	2.27	3.90	0.58	0.30	2.12
	Header	WP	-0.06	3.86	-0.17	0.98	0.17	-0.02	1.60
		WS	0.06	3.86	0.19	1.93	0.10	0.02	1.60
3	JambL	WP	-0.52	5.26	-2.06	3.90	0.53	-0.27	2.12
		WS	0.57	5.26	2.27	3.90	0.58	0.30	2.12
	JambR	WP	-0.52	5.26	-2.06	3.90	0.53	-0.27	2.12
		WS	0.57	5.26	2.27	3.90	0.58	0.30	2.12
	Header	WP	-0.06	3.86	-0.17	0.98	0.17	-0.02	1.60
		WS	0.06	3.86	0.19	1.93	0.10	0.02	1.60
4	JambL	WP	-0.52	5.26	-2.06	3.90	0.53	-0.27	2.12
		WS	0.57	5.26	2.27	3.90	0.58	0.30	2.12
	JambR	WP	-0.52	5.26	-2.06	3.90	0.53	-0.27	2.12
		WS	0.57	5.26	2.27	3.90	0.58	0.30	2.12
	Header	WP	-0.06	3.86	-0.17	0.98	0.17	-0.02	1.60
		WS	0.06	3.86	0.19	1.93	0.10	0.02	1.60
5	JambL	WP	-0.52	5.26	-2.06	3.90	0.53	-0.27	2.12
		WS	0.57	5.26	2.27	3.90	0.58	0.30	2.12
	JambR	WP	-0.52	5.26	-2.06	3.90	0.53	-0.27	2.12
		WS	0.61	5.26	2.42	3.90	0.62	0.32	2.12
	Header	WP	-0.06	3.86	-0.17	0.98	0.17	-0.02	1.60
		WS	0.06	3.86	0.19	1.93	0.10	0.02	1.60

WP - Wind_Pressure
WS - Wind_Suction

PANEL DATA:

Bay	Part	Type	Gage	Yield
---	-----	---	-----	-----
1	CUSPANL	CP	20.00	50.0

MOMENTS & DEFLECTION:

			-----Moment (ft-lb/ft)-----									
Span Id	Locate(ft)		Load	Start		Midspan		End		Max UC	Deflect (in)	
	Start	End		Calc	Limit	Calc	Limit	Calc	Limit		Calc	Limit
----	-----	-----	----	-----	-----	-----	-----	-----	-----	-----	-----	-----
1	14.00	15.88	WP	0.0	49.1	-5.5	49.1	0.0	38.1	0.11	-0.02	0.38
			WS	0.0	38.1	7.3	38.1	0.0	38.1	0.19	0.02	0.38
			WP - Wind Pressure									
			WS - Wind Suction									

PANEL:

Part	Thick (in)	Yield (ksi)	Tensile Strength (ksi)
CUSPANL	0.038	50.00	65.00

GIRT SCREWS:

Part	Dia (in)	Washer (in)	Limit (k)
#29	0.21	0.50	2.90

PANEL ZONE LAYOUT:

		--Girt (ft,ft,in)--						Panel
Zone		----Wall (ft)----		Bay	Load		Min	Span
Id	Description	Offset1	Offset2	Id	Locate	Width	Thick	(ft)
1	Interior	6.43	63.57	1	4.00	4.00	0.000	4.00
2	Lt Edge	0.00	6.43	1	4.00	4.00	0.000	4.00
3	Rt Edge	63.57	70.00	5	4.00	4.00	0.000	4.00

GIRT SCREW CHECK:

		Wind	-----Limit(k)-----				
Zone	Screw	Suction	Load	Girt	Panel	Screw	Max
Id	Space	(psf)	(k)	Pullout	Pullover	Tension	UC
1	1.00	16.62	0.07				
2	1.00	16.62	0.07				
3	1.00	16.62	0.07				

WALL LAYOUT:

Wall Id	Orn	Load Width
3	T	7.00

MEMBER LAYOUT:

Id	Locate		---Web(in)--		-Flange(in)-		Length (ft)	Weight (lb)	----Max_Load----		
	(ft)	Part	Depth	Thick	Width	Thick			Id	UC	Report
Col22	5.0	6X2C16	6.00	16ga	2.00	16ga	16.1	35.3	10	0.75	Deflect
Col23	10.0	6X2C16	6.00	16ga	2.00	16ga	16.3	35.8	10	0.74	Deflect
Col24	15.0	6X2C16	6.00	16ga	2.00	16ga	16.5	36.2	10	0.77	Deflect
Col25	20.0	6X2C16	6.00	16ga	2.00	16ga	16.8	36.7	10	0.79	Deflect
Col26	25.0	6X2C16	6.00	16ga	2.00	16ga	17.0	37.1	10	0.82	Deflect
Col27	30.0	6X2C16	6.00	16ga	2.00	16ga	17.2	37.6	10	0.86	Deflect
Col28	35.0	6X2C16	6.00	16ga	2.00	16ga	17.3	37.9	1	0.10	Mom+Axl
Col29	40.0	6X2C16	6.00	16ga	2.00	16ga	17.2	37.6	10	0.86	Deflect
Col30	45.0	6X2C16	6.00	16ga	2.00	16ga	17.0	37.1	10	0.82	Deflect
Col31	50.0	6X2C16	6.00	16ga	2.00	16ga	16.7	36.7	10	0.79	Deflect
Col32	55.0	6X2C16	6.00	16ga	2.00	16ga	16.5	36.2	10	0.77	Deflect
Col33	60.0	6X2C16	6.00	16ga	2.00	16ga	16.3	35.8	10	0.78	Deflect
Total=								440.0			

DESIGN ACTIONS/STRENGTH:

Id	Load Id	-Axial(k)-		-Shear(k)-		Moment(f-k)		-----Unity_Check-----			
		Calc	Limit	Calc	Limit	Calc	Limit	Axial	Shear	Axial+ Moment	Shear+ Moment
Col22	1	0.83	7.66	0.00	3.32	0.00	2.65	0.11	0.00	0.11	0.00
Col22	2	0.13	7.66	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col22	3	0.60	7.66	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col22	4	0.60	7.66	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col22	5	0.66	7.66	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col22	6	0.48	7.66	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col22	7	0.48	7.66	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col22	8	-0.35	21.18	0.41	3.32	-1.64	2.65	0.02	0.12	0.60	0.00
Col22	9	-0.15	21.18	0.41	3.32	-1.64	2.65	0.01	0.12	0.61	0.00
Col22	10	-0.35	21.18	-0.47	3.32	1.90	2.65	0.02	0.14	0.70	0.00
Col22	11	-0.15	21.18	-0.47	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col22	12	-0.35	21.18	-0.47	3.32	1.90	2.65	0.02	0.14	0.70	0.00
Col22	13	-0.15	21.18	-0.47	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col22	14	-0.20	21.18	-0.47	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col22	15	-0.01	21.18	-0.47	3.32	1.90	2.65	0.00	0.14	0.72	0.00
Col22	16	0.42	7.66	-0.35	3.32	1.43	2.65	0.05	0.11	0.59	0.00
Col22	17	0.57	7.66	-0.35	3.32	1.43	2.65	0.07	0.11	0.61	0.00
Col22	18	0.31	7.66	-0.35	3.32	1.43	2.65	0.04	0.11	0.58	0.00
Col22	19	0.46	7.66	-0.35	3.32	1.43	2.65	0.06	0.11	0.60	0.00
Col22	20	0.25	7.66	-0.35	3.32	1.43	2.65	0.03	0.11	0.57	0.00
Col22	21	0.39	7.66	-0.35	3.32	1.43	2.65	0.05	0.11	0.59	0.00
Col22	22	0.14	7.66	-0.35	3.32	1.43	2.65	0.02	0.11	0.56	0.00
Col22	23	0.28	7.66	-0.35	3.32	1.43	2.65	0.04	0.11	0.58	0.00
Col22	24	0.25	7.66	-0.35	3.32	1.43	2.65	0.03	0.11	0.57	0.00
Col22	25	0.39	7.66	-0.35	3.32	1.43	2.65	0.05	0.11	0.59	0.00
Col22	26	0.14	7.66	-0.35	3.32	1.43	2.65	0.02	0.11	0.56	0.00
Col22	27	0.28	7.66	-0.35	3.32	1.43	2.65	0.04	0.11	0.58	0.00
Col22	28	-0.37	21.18	0.41	3.32	-1.64	2.65	0.02	0.12	0.60	0.00
Col22	29	-0.18	21.18	0.41	3.32	-1.64	2.65	0.01	0.12	0.61	0.00

Col22	30	-0.37	21.18	-0.47	3.32	1.90	2.65	0.02	0.14	0.70	0.00
Col22	31	-0.18	21.18	-0.47	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col22	32	-0.37	21.18	-0.47	3.32	1.90	2.65	0.02	0.14	0.70	0.00
Col22	33	-0.18	21.18	-0.47	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col22	34	-0.23	21.18	-0.47	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col22	35	-0.03	21.18	-0.47	3.32	1.90	2.65	0.00	0.14	0.72	0.00
Col22	36	0.13	7.66	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col22	37	0.13	7.66	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col22	38	0.66	7.66	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col22	39	0.66	7.66	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col22	40	0.49	7.66	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col22	41	0.49	7.66	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col22	42	0.49	7.66	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col22	43	0.49	7.66	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col22	44	0.08	7.66	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col22	45	0.08	7.66	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col22	46	0.69	7.66	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col22	47	0.32	7.66	-0.35	3.32	1.43	2.65	0.04	0.11	0.58	0.00
Col22	48	0.46	7.66	-0.35	3.32	1.43	2.65	0.06	0.11	0.60	0.00
Col22	49	0.13	7.66	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col22	50	0.13	7.66	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col22	51	0.09	7.66	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col22	52	0.09	7.66	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col22	53	0.60	7.66	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col22	54	0.49	7.66	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col22	55	0.49	7.66	-0.35	3.32	1.43	2.65	0.06	0.11	0.60	0.00
Col22	56	0.49	7.66	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col23	1	0.83	7.45	0.00	3.32	0.00	2.65	0.11	0.00	0.11	0.00
Col23	2	0.13	7.45	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col23	3	0.60	7.45	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col23	4	0.60	7.45	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col23	5	0.66	7.45	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col23	6	0.48	7.45	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col23	7	0.48	7.45	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col23	8	-0.35	21.18	0.41	3.32	-1.68	2.65	0.02	0.12	0.62	0.00
Col23	9	-0.15	21.18	0.41	3.32	-1.68	2.65	0.01	0.12	0.63	0.00
Col23	10	-0.35	21.18	-0.45	3.32	1.85	2.65	0.02	0.14	0.68	0.00
Col23	11	-0.15	21.18	-0.45	3.32	1.85	2.65	0.01	0.14	0.69	0.00
Col23	12	-0.35	21.18	-0.45	3.32	1.85	2.65	0.02	0.14	0.68	0.00
Col23	13	-0.15	21.18	-0.45	3.32	1.85	2.65	0.01	0.14	0.69	0.00
Col23	14	-0.20	21.18	-0.45	3.32	1.85	2.65	0.01	0.14	0.69	0.00
Col23	15	-0.01	21.18	-0.45	3.32	1.85	2.65	0.00	0.14	0.70	0.00
Col23	16	0.42	7.45	-0.34	3.32	1.39	2.65	0.06	0.10	0.58	0.00
Col23	17	0.57	7.45	-0.34	3.32	1.39	2.65	0.08	0.10	0.60	0.00
Col23	18	0.31	7.45	-0.34	3.32	1.39	2.65	0.04	0.10	0.57	0.00
Col23	19	0.46	7.45	-0.34	3.32	1.39	2.65	0.06	0.10	0.59	0.00
Col23	20	0.25	7.45	-0.34	3.32	1.39	2.65	0.03	0.10	0.56	0.00
Col23	21	0.39	7.45	-0.34	3.32	1.39	2.65	0.05	0.10	0.58	0.00
Col23	22	0.14	7.45	-0.34	3.32	1.39	2.65	0.02	0.10	0.54	0.00
Col23	23	0.28	7.45	-0.34	3.32	1.39	2.65	0.04	0.10	0.56	0.00
Col23	24	0.25	7.45	-0.34	3.32	1.39	2.65	0.03	0.10	0.56	0.00
Col23	25	0.39	7.45	-0.34	3.32	1.39	2.65	0.05	0.10	0.58	0.00
Col23	26	0.14	7.45	-0.34	3.32	1.39	2.65	0.02	0.10	0.54	0.00
Col23	27	0.28	7.45	-0.34	3.32	1.39	2.65	0.04	0.10	0.56	0.00
Col23	28	-0.37	21.18	0.41	3.32	-1.68	2.65	0.02	0.12	0.62	0.00
Col23	29	-0.18	21.18	0.41	3.32	-1.68	2.65	0.01	0.12	0.63	0.00
Col23	30	-0.37	21.18	-0.45	3.32	1.85	2.65	0.02	0.14	0.68	0.00
Col23	31	-0.18	21.18	-0.45	3.32	1.85	2.65	0.01	0.14	0.69	0.00
Col23	32	-0.37	21.18	-0.45	3.32	1.85	2.65	0.02	0.14	0.68	0.00
Col23	33	-0.18	21.18	-0.45	3.32	1.85	2.65	0.01	0.14	0.69	0.00
Col23	34	-0.23	21.18	-0.45	3.32	1.85	2.65	0.01	0.14	0.69	0.00
Col23	35	-0.03	21.18	-0.45	3.32	1.85	2.65	0.00	0.14	0.70	0.00
Col23	36	0.14	7.45	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col23	37	0.14	7.45	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col23	38	0.66	7.45	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00

Col123	39	0.66	7.45	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col123	40	0.49	7.45	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col123	41	0.49	7.45	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col123	42	0.49	7.45	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col123	43	0.49	7.45	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col123	44	0.08	7.45	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col123	45	0.08	7.45	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col123	46	0.69	7.45	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col123	47	0.32	7.45	-0.34	3.32	1.39	2.65	0.04	0.10	0.57	0.00
Col123	48	0.46	7.45	-0.34	3.32	1.39	2.65	0.06	0.10	0.59	0.00
Col123	49	0.13	7.45	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col123	50	0.13	7.45	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col123	51	0.09	7.45	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col123	52	0.09	7.45	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col123	53	0.60	7.45	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col123	54	0.49	7.45	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col123	55	0.49	7.45	-0.34	3.32	1.39	2.65	0.07	0.10	0.59	0.00
Col123	56	0.49	7.45	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col124	1	0.83	7.23	0.00	3.32	0.00	2.65	0.12	0.00	0.12	0.00
Col124	2	0.13	7.23	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col124	3	0.60	7.23	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col124	4	0.60	7.23	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col124	5	0.66	7.23	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col124	6	0.48	7.23	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col124	7	0.48	7.23	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col124	8	-0.34	21.18	0.42	3.32	-1.72	2.65	0.02	0.13	0.64	0.00
Col124	9	-0.15	21.18	0.42	3.32	-1.72	2.65	0.01	0.13	0.64	0.00
Col124	10	-0.34	21.18	-0.46	3.32	1.90	2.65	0.02	0.14	0.70	0.00
Col124	11	-0.15	21.18	-0.46	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col124	12	-0.34	21.18	-0.46	3.32	1.90	2.65	0.02	0.14	0.70	0.00
Col124	13	-0.15	21.18	-0.46	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col124	14	-0.20	21.18	-0.46	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col124	15	-0.01	21.18	-0.46	3.32	1.90	2.65	0.00	0.14	0.72	0.00
Col124	16	0.42	7.23	-0.34	3.32	1.42	2.65	0.06	0.10	0.60	0.00
Col124	17	0.57	7.23	-0.34	3.32	1.42	2.65	0.08	0.10	0.62	0.00
Col124	18	0.31	7.23	-0.34	3.32	1.42	2.65	0.04	0.10	0.58	0.00
Col124	19	0.46	7.23	-0.34	3.32	1.42	2.65	0.06	0.10	0.60	0.00
Col124	20	0.25	7.23	-0.34	3.32	1.42	2.65	0.03	0.10	0.57	0.00
Col124	21	0.39	7.23	-0.34	3.32	1.42	2.65	0.05	0.10	0.59	0.00
Col124	22	0.14	7.23	-0.34	3.32	1.42	2.65	0.02	0.10	0.56	0.00
Col124	23	0.28	7.23	-0.34	3.32	1.42	2.65	0.04	0.10	0.58	0.00
Col124	24	0.25	7.23	-0.34	3.32	1.42	2.65	0.03	0.10	0.57	0.00
Col124	25	0.39	7.23	-0.34	3.32	1.42	2.65	0.05	0.10	0.59	0.00
Col124	26	0.14	7.23	-0.34	3.32	1.42	2.65	0.02	0.10	0.56	0.00
Col124	27	0.28	7.23	-0.34	3.32	1.42	2.65	0.04	0.10	0.58	0.00
Col124	28	-0.37	21.18	0.42	3.32	-1.72	2.65	0.02	0.13	0.63	0.00
Col124	29	-0.18	21.18	0.42	3.32	-1.72	2.65	0.01	0.13	0.64	0.00
Col124	30	-0.37	21.18	-0.46	3.32	1.90	2.65	0.02	0.14	0.70	0.00
Col124	31	-0.18	21.18	-0.46	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col124	32	-0.37	21.18	-0.46	3.32	1.90	2.65	0.02	0.14	0.70	0.00
Col124	33	-0.18	21.18	-0.46	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col124	34	-0.23	21.18	-0.46	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col124	35	-0.03	21.18	-0.46	3.32	1.90	2.65	0.00	0.14	0.72	0.00
Col124	36	0.14	7.23	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col124	37	0.14	7.23	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col124	38	0.66	7.23	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col124	39	0.66	7.23	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col124	40	0.49	7.23	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col124	41	0.49	7.23	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col124	42	0.49	7.23	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col124	43	0.49	7.23	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col124	44	0.09	7.23	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col124	45	0.09	7.23	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col124	46	0.69	7.23	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col124	47	0.32	7.23	-0.34	3.32	1.42	2.65	0.04	0.10	0.58	0.00

Col24	48	0.46	7.23	-0.34	3.32	1.42	2.65	0.06	0.10	0.60	0.00
Col24	49	0.13	7.23	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col24	50	0.13	7.23	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col24	51	0.09	7.23	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col24	52	0.09	7.23	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col24	53	0.66	7.23	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col24	54	0.53	7.23	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col24	55	0.53	7.23	-0.34	3.32	1.42	2.65	0.07	0.10	0.61	0.00
Col24	56	0.53	7.23	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col25	1	0.83	7.01	0.00	3.32	0.00	2.65	0.12	0.00	0.12	0.00
Col25	2	0.13	7.01	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col25	3	0.60	7.01	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col25	4	0.60	7.01	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col25	5	0.66	7.01	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col25	6	0.49	7.01	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col25	7	0.49	7.01	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col25	8	-0.34	21.18	0.42	3.32	-1.77	2.65	0.02	0.13	0.65	0.00
Col25	9	-0.15	21.18	0.42	3.32	-1.77	2.65	0.01	0.13	0.66	0.00
Col25	10	-0.34	21.18	-0.46	3.32	1.95	2.65	0.02	0.14	0.72	0.00
Col25	11	-0.15	21.18	-0.46	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col25	12	-0.34	21.18	-0.46	3.32	1.95	2.65	0.02	0.14	0.72	0.00
Col25	13	-0.15	21.18	-0.46	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col25	14	-0.20	21.18	-0.46	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col25	15	-0.01	21.18	-0.46	3.32	1.95	2.65	0.00	0.14	0.74	0.00
Col25	16	0.42	7.01	-0.35	3.32	1.46	2.65	0.06	0.11	0.61	0.00
Col25	17	0.57	7.01	-0.35	3.32	1.46	2.65	0.08	0.11	0.63	0.00
Col25	18	0.31	7.01	-0.35	3.32	1.46	2.65	0.04	0.11	0.60	0.00
Col25	19	0.46	7.01	-0.35	3.32	1.46	2.65	0.07	0.11	0.62	0.00
Col25	20	0.25	7.01	-0.35	3.32	1.46	2.65	0.04	0.11	0.59	0.00
Col25	21	0.39	7.01	-0.35	3.32	1.46	2.65	0.06	0.11	0.61	0.00
Col25	22	0.14	7.01	-0.35	3.32	1.46	2.65	0.02	0.11	0.57	0.00
Col25	23	0.29	7.01	-0.35	3.32	1.46	2.65	0.04	0.11	0.59	0.00
Col25	24	0.25	7.01	-0.35	3.32	1.46	2.65	0.04	0.11	0.59	0.00
Col25	25	0.39	7.01	-0.35	3.32	1.46	2.65	0.06	0.11	0.61	0.00
Col25	26	0.14	7.01	-0.35	3.32	1.46	2.65	0.02	0.11	0.57	0.00
Col25	27	0.29	7.01	-0.35	3.32	1.46	2.65	0.04	0.11	0.59	0.00
Col25	28	-0.37	21.18	0.42	3.32	-1.77	2.65	0.02	0.13	0.65	0.00
Col25	29	-0.18	21.18	0.42	3.32	-1.77	2.65	0.01	0.13	0.66	0.00
Col25	30	-0.37	21.18	-0.46	3.32	1.95	2.65	0.02	0.14	0.72	0.00
Col25	31	-0.18	21.18	-0.46	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col25	32	-0.37	21.18	-0.46	3.32	1.95	2.65	0.02	0.14	0.72	0.00
Col25	33	-0.18	21.18	-0.46	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col25	34	-0.23	21.18	-0.46	3.32	1.95	2.65	0.01	0.14	0.72	0.00
Col25	35	-0.03	21.18	-0.46	3.32	1.95	2.65	0.00	0.14	0.73	0.00
Col25	36	0.14	7.01	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col25	37	0.14	7.01	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col25	38	0.66	7.01	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col25	39	0.66	7.01	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col25	40	0.49	7.01	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col25	41	0.49	7.01	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col25	42	0.49	7.01	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col25	43	0.49	7.01	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col25	44	0.09	7.01	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col25	45	0.09	7.01	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col25	46	0.69	7.01	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col25	47	0.32	7.01	-0.35	3.32	1.46	2.65	0.05	0.11	0.60	0.00
Col25	48	0.46	7.01	-0.35	3.32	1.46	2.65	0.07	0.11	0.62	0.00
Col25	49	0.13	7.01	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col25	50	0.13	7.01	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col25	51	0.09	7.01	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col25	52	0.09	7.01	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col25	53	0.77	7.01	0.00	3.32	0.00	2.65	0.11	0.00	0.11	0.00
Col25	54	0.61	7.01	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col25	55	0.61	7.01	-0.35	3.32	1.46	2.65	0.09	0.11	0.64	0.00
Col25	56	0.62	7.01	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00

Col26	1	0.83	6.79	0.00	3.32	0.00	2.65	0.12	0.00	0.12	0.00
Col26	2	0.13	6.79	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col26	3	0.60	6.79	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col26	4	0.60	6.79	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col26	5	0.66	6.79	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col26	6	0.49	6.79	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col26	7	0.49	6.79	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col26	8	-0.34	21.18	0.43	3.32	-1.81	2.65	0.02	0.13	0.67	0.00
Col26	9	-0.15	21.18	0.43	3.32	-1.81	2.65	0.01	0.13	0.68	0.00
Col26	10	-0.34	21.18	-0.47	3.32	2.00	2.65	0.02	0.14	0.74	0.00
Col26	11	-0.15	21.18	-0.47	3.32	2.00	2.65	0.01	0.14	0.75	0.00
Col26	12	-0.34	21.18	-0.47	3.32	2.00	2.65	0.02	0.14	0.74	0.00
Col26	13	-0.15	21.18	-0.47	3.32	2.00	2.65	0.01	0.14	0.75	0.00
Col26	14	-0.20	21.18	-0.47	3.32	2.00	2.65	0.01	0.14	0.74	0.00
Col26	15	0.00	21.18	-0.47	3.32	2.00	2.65	0.00	0.14	0.75	0.00
Col26	16	0.42	6.79	-0.35	3.32	1.50	2.65	0.06	0.11	0.63	0.00
Col26	17	0.57	6.79	-0.35	3.32	1.50	2.65	0.08	0.11	0.65	0.00
Col26	18	0.31	6.79	-0.35	3.32	1.50	2.65	0.05	0.11	0.61	0.00
Col26	19	0.46	6.79	-0.35	3.32	1.50	2.65	0.07	0.11	0.63	0.00
Col26	20	0.25	6.79	-0.35	3.32	1.50	2.65	0.04	0.11	0.60	0.00
Col26	21	0.39	6.79	-0.35	3.32	1.50	2.65	0.06	0.11	0.62	0.00
Col26	22	0.14	6.79	-0.35	3.32	1.50	2.65	0.02	0.11	0.59	0.00
Col26	23	0.29	6.79	-0.35	3.32	1.50	2.65	0.04	0.11	0.61	0.00
Col26	24	0.25	6.79	-0.35	3.32	1.50	2.65	0.04	0.11	0.60	0.00
Col26	25	0.39	6.79	-0.35	3.32	1.50	2.65	0.06	0.11	0.62	0.00
Col26	26	0.14	6.79	-0.35	3.32	1.50	2.65	0.02	0.11	0.59	0.00
Col26	27	0.29	6.79	-0.35	3.32	1.50	2.65	0.04	0.11	0.61	0.00
Col26	28	-0.37	21.18	0.43	3.32	-1.81	2.65	0.02	0.13	0.67	0.00
Col26	29	-0.18	21.18	0.43	3.32	-1.81	2.65	0.01	0.13	0.68	0.00
Col26	30	-0.37	21.18	-0.47	3.32	2.00	2.65	0.02	0.14	0.74	0.00
Col26	31	-0.18	21.18	-0.47	3.32	2.00	2.65	0.01	0.14	0.75	0.00
Col26	32	-0.37	21.18	-0.47	3.32	2.00	2.65	0.02	0.14	0.74	0.00
Col26	33	-0.18	21.18	-0.47	3.32	2.00	2.65	0.01	0.14	0.75	0.00
Col26	34	-0.23	21.18	-0.47	3.32	2.00	2.65	0.01	0.14	0.74	0.00
Col26	35	-0.03	21.18	-0.47	3.32	2.00	2.65	0.00	0.14	0.75	0.00
Col26	36	0.14	6.79	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col26	37	0.14	6.79	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col26	38	0.66	6.79	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col26	39	0.66	6.79	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col26	40	0.49	6.79	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col26	41	0.49	6.79	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col26	42	0.49	6.79	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col26	43	0.49	6.79	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col26	44	0.09	6.79	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col26	45	0.09	6.79	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col26	46	0.69	6.79	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col26	47	0.32	6.79	-0.35	3.32	1.50	2.65	0.05	0.11	0.61	0.00
Col26	48	0.46	6.79	-0.35	3.32	1.50	2.65	0.07	0.11	0.63	0.00
Col26	49	0.13	6.79	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col26	50	0.13	6.79	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col26	51	0.09	6.79	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col26	52	0.09	6.79	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col26	53	0.78	6.79	0.00	3.32	0.00	2.65	0.11	0.00	0.11	0.00
Col26	54	0.62	6.79	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col26	55	0.62	6.79	-0.35	3.32	1.50	2.65	0.09	0.11	0.66	0.00
Col26	56	0.62	6.79	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col27	1	0.83	6.57	0.00	3.32	0.00	2.65	0.13	0.00	0.13	0.00
Col27	2	0.13	6.57	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col27	3	0.60	6.57	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col27	4	0.60	6.57	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col27	5	0.66	6.57	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col27	6	0.49	6.57	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col27	7	0.49	6.57	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col27	8	-0.34	21.18	0.43	3.32	-1.86	2.65	0.02	0.13	0.69	0.00
Col27	9	-0.15	21.18	0.43	3.32	-1.86	2.65	0.01	0.13	0.69	0.00

Col27	10	-0.34	21.18	-0.48	3.32	2.04	2.65	0.02	0.14	0.76	0.00
Col27	11	-0.15	21.18	-0.48	3.32	2.04	2.65	0.01	0.14	0.77	0.00
Col27	12	-0.34	21.18	-0.48	3.32	2.04	2.65	0.02	0.14	0.76	0.00
Col27	13	-0.15	21.18	-0.48	3.32	2.04	2.65	0.01	0.14	0.77	0.00
Col27	14	-0.20	21.18	-0.48	3.32	2.04	2.65	0.01	0.14	0.76	0.00
Col27	15	0.00	21.18	-0.48	3.32	2.04	2.65	0.00	0.14	0.77	0.00
Col27	16	0.42	6.57	-0.36	3.32	1.53	2.65	0.06	0.11	0.64	0.00
Col27	17	0.57	6.57	-0.36	3.32	1.53	2.65	0.09	0.11	0.67	0.00
Col27	18	0.31	6.57	-0.36	3.32	1.53	2.65	0.05	0.11	0.63	0.00
Col27	19	0.46	6.57	-0.36	3.32	1.53	2.65	0.07	0.11	0.65	0.00
Col27	20	0.25	6.57	-0.36	3.32	1.53	2.65	0.04	0.11	0.62	0.00
Col27	21	0.40	6.57	-0.36	3.32	1.53	2.65	0.06	0.11	0.64	0.00
Col27	22	0.14	6.57	-0.36	3.32	1.53	2.65	0.02	0.11	0.60	0.00
Col27	23	0.29	6.57	-0.36	3.32	1.53	2.65	0.04	0.11	0.62	0.00
Col27	24	0.25	6.57	-0.36	3.32	1.53	2.65	0.04	0.11	0.62	0.00
Col27	25	0.40	6.57	-0.36	3.32	1.53	2.65	0.06	0.11	0.64	0.00
Col27	26	0.14	6.57	-0.36	3.32	1.53	2.65	0.02	0.11	0.60	0.00
Col27	27	0.29	6.57	-0.36	3.32	1.53	2.65	0.04	0.11	0.62	0.00
Col27	28	-0.37	21.18	0.43	3.32	-1.86	2.65	0.02	0.13	0.68	0.00
Col27	29	-0.18	21.18	0.43	3.32	-1.86	2.65	0.01	0.13	0.69	0.00
Col27	30	-0.37	21.18	-0.48	3.32	2.04	2.65	0.02	0.14	0.75	0.00
Col27	31	-0.18	21.18	-0.48	3.32	2.04	2.65	0.01	0.14	0.76	0.00
Col27	32	-0.37	21.18	-0.48	3.32	2.04	2.65	0.02	0.14	0.75	0.00
Col27	33	-0.18	21.18	-0.48	3.32	2.04	2.65	0.01	0.14	0.76	0.00
Col27	34	-0.23	21.18	-0.48	3.32	2.04	2.65	0.01	0.14	0.76	0.00
Col27	35	-0.03	21.18	-0.48	3.32	2.04	2.65	0.00	0.14	0.77	0.00
Col27	36	0.14	6.57	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col27	37	0.14	6.57	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col27	38	0.66	6.57	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col27	39	0.66	6.57	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col27	40	0.49	6.57	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col27	41	0.49	6.57	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col27	42	0.49	6.57	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col27	43	0.49	6.57	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col27	44	0.09	6.57	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col27	45	0.09	6.57	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col27	46	0.69	6.57	0.00	3.32	0.00	2.65	0.11	0.00	0.11	0.00
Col27	47	0.32	6.57	-0.36	3.32	1.53	2.65	0.05	0.11	0.63	0.00
Col27	48	0.46	6.57	-0.36	3.32	1.53	2.65	0.07	0.11	0.65	0.00
Col27	49	0.13	6.57	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col27	50	0.13	6.57	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col27	51	0.09	6.57	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col27	52	0.09	6.57	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col27	53	0.78	6.57	0.00	3.32	0.00	2.65	0.12	0.00	0.12	0.00
Col27	54	0.62	6.57	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col27	55	0.62	6.57	-0.36	3.32	1.53	2.65	0.09	0.11	0.67	0.00
Col27	56	0.62	6.57	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col28	1	0.83	8.50	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col28	2	0.13	8.50	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col28	3	0.60	8.50	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col28	4	0.60	8.50	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col28	5	0.66	8.50	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col28	6	0.49	8.50	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col28	7	0.49	8.50	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col28	8	-0.24	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col28	9	-0.24	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col28	10	-0.24	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col28	11	-0.24	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col28	12	-0.24	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col28	13	-0.24	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col28	14	-0.10	21.18	0.00	3.32	0.00	2.65	0.00	0.00	0.00	0.00
Col28	15	-0.10	21.18	0.00	3.32	0.00	2.65	0.00	0.00	0.00	0.00
Col28	16	0.50	8.50	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col28	17	0.50	8.50	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col28	18	0.39	8.50	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00

Col28	19	0.39	8.50	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col28	20	0.32	8.50	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col28	21	0.32	8.50	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col28	22	0.22	8.50	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col28	23	0.22	8.50	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col28	24	0.32	8.50	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col28	25	0.32	8.50	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col28	26	0.22	8.50	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col28	27	0.22	8.50	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col28	28	-0.27	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col28	29	-0.27	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col28	30	-0.27	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col28	31	-0.27	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col28	32	-0.27	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col28	33	-0.27	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col28	34	-0.13	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col28	35	-0.13	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col28	36	0.14	8.50	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col28	37	0.14	8.50	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col28	38	0.66	8.50	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col28	39	0.66	8.50	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col28	40	0.49	8.50	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col28	41	0.49	8.50	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col28	42	0.49	8.50	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col28	43	0.49	8.50	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col28	44	0.09	8.50	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col28	45	0.09	8.50	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col28	46	0.68	8.50	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col28	47	0.38	8.50	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col28	48	0.38	8.50	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col28	49	0.13	8.50	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col28	50	0.13	8.50	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col28	51	0.09	8.50	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col28	52	0.09	8.50	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col28	53	0.77	8.50	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col28	54	0.61	8.50	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col28	55	0.61	8.50	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col28	56	0.61	8.50	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col29	1	0.83	6.57	0.00	3.32	0.00	2.65	0.13	0.00	0.13	0.00
Col29	2	0.13	6.57	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col29	3	0.60	6.57	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col29	4	0.60	6.57	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col29	5	0.66	6.57	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col29	6	0.49	6.57	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col29	7	0.49	6.57	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col29	8	-0.15	21.18	0.43	3.32	-1.86	2.65	0.01	0.13	0.69	0.00
Col29	9	-0.34	21.18	0.43	3.32	-1.86	2.65	0.02	0.13	0.69	0.00
Col29	10	-0.15	21.18	-0.48	3.32	2.04	2.65	0.01	0.14	0.77	0.00
Col29	11	-0.34	21.18	-0.48	3.32	2.04	2.65	0.02	0.14	0.76	0.00
Col29	12	-0.15	21.18	-0.48	3.32	2.04	2.65	0.01	0.14	0.77	0.00
Col29	13	-0.34	21.18	-0.48	3.32	2.04	2.65	0.02	0.14	0.76	0.00
Col29	14	0.00	21.18	-0.48	3.32	2.04	2.65	0.00	0.14	0.77	0.00
Col29	15	-0.20	21.18	-0.48	3.32	2.04	2.65	0.01	0.14	0.76	0.00
Col29	16	0.57	6.57	-0.36	3.32	1.53	2.65	0.09	0.11	0.67	0.00
Col29	17	0.42	6.57	-0.36	3.32	1.53	2.65	0.06	0.11	0.64	0.00
Col29	18	0.46	6.57	-0.36	3.32	1.53	2.65	0.07	0.11	0.65	0.00
Col29	19	0.31	6.57	-0.36	3.32	1.53	2.65	0.05	0.11	0.63	0.00
Col29	20	0.40	6.57	-0.36	3.32	1.53	2.65	0.06	0.11	0.64	0.00
Col29	21	0.25	6.57	-0.36	3.32	1.53	2.65	0.04	0.11	0.62	0.00
Col29	22	0.29	6.57	-0.36	3.32	1.53	2.65	0.04	0.11	0.62	0.00
Col29	23	0.14	6.57	-0.36	3.32	1.53	2.65	0.02	0.11	0.60	0.00
Col29	24	0.40	6.57	-0.36	3.32	1.53	2.65	0.06	0.11	0.64	0.00
Col29	25	0.25	6.57	-0.36	3.32	1.53	2.65	0.04	0.11	0.62	0.00
Col29	26	0.29	6.57	-0.36	3.32	1.53	2.65	0.04	0.11	0.62	0.00
Col29	27	0.14	6.57	-0.36	3.32	1.53	2.65	0.02	0.11	0.60	0.00

Col129	28	-0.18	21.18	0.43	3.32	-1.86	2.65	0.01	0.13	0.69	0.00
Col129	29	-0.37	21.18	0.43	3.32	-1.86	2.65	0.02	0.13	0.68	0.00
Col129	30	-0.18	21.18	-0.48	3.32	2.04	2.65	0.01	0.14	0.76	0.00
Col129	31	-0.37	21.18	-0.48	3.32	2.04	2.65	0.02	0.14	0.75	0.00
Col129	32	-0.18	21.18	-0.48	3.32	2.04	2.65	0.01	0.14	0.76	0.00
Col129	33	-0.37	21.18	-0.48	3.32	2.04	2.65	0.02	0.14	0.75	0.00
Col129	34	-0.03	21.18	-0.48	3.32	2.04	2.65	0.00	0.14	0.77	0.00
Col129	35	-0.23	21.18	-0.48	3.32	2.04	2.65	0.01	0.14	0.76	0.00
Col129	36	0.14	6.57	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col129	37	0.14	6.57	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col129	38	0.66	6.57	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col129	39	0.66	6.57	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col129	40	0.49	6.57	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col129	41	0.49	6.57	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col129	42	0.49	6.57	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col129	43	0.49	6.57	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col129	44	0.09	6.57	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col129	45	0.09	6.57	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col129	46	0.69	6.57	0.00	3.32	0.00	2.65	0.11	0.00	0.11	0.00
Col129	47	0.46	6.57	-0.36	3.32	1.53	2.65	0.07	0.11	0.65	0.00
Col129	48	0.32	6.57	-0.36	3.32	1.53	2.65	0.05	0.11	0.63	0.00
Col129	49	0.13	6.57	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col129	50	0.13	6.57	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col129	51	0.09	6.57	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col129	52	0.09	6.57	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col129	53	0.79	6.57	0.00	3.32	0.00	2.65	0.12	0.00	0.12	0.00
Col129	54	0.63	6.57	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col129	55	0.63	6.57	-0.36	3.32	1.53	2.65	0.10	0.11	0.68	0.00
Col129	56	0.63	6.57	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col130	1	0.83	6.79	0.00	3.32	0.00	2.65	0.12	0.00	0.12	0.00
Col130	2	0.13	6.79	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col130	3	0.60	6.79	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col130	4	0.60	6.79	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col130	5	0.66	6.79	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col130	6	0.49	6.79	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col130	7	0.49	6.79	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col130	8	-0.15	21.18	0.43	3.32	-1.81	2.65	0.01	0.13	0.68	0.00
Col130	9	-0.34	21.18	0.43	3.32	-1.81	2.65	0.02	0.13	0.67	0.00
Col130	10	-0.15	21.18	-0.47	3.32	2.00	2.65	0.01	0.14	0.75	0.00
Col130	11	-0.34	21.18	-0.47	3.32	2.00	2.65	0.02	0.14	0.74	0.00
Col130	12	-0.15	21.18	-0.47	3.32	2.00	2.65	0.01	0.14	0.75	0.00
Col130	13	-0.34	21.18	-0.47	3.32	2.00	2.65	0.02	0.14	0.74	0.00
Col130	14	0.00	21.18	-0.47	3.32	2.00	2.65	0.00	0.14	0.75	0.00
Col130	15	-0.20	21.18	-0.47	3.32	2.00	2.65	0.01	0.14	0.74	0.00
Col130	16	0.57	6.79	-0.35	3.32	1.50	2.65	0.08	0.11	0.65	0.00
Col130	17	0.42	6.79	-0.35	3.32	1.50	2.65	0.06	0.11	0.63	0.00
Col130	18	0.46	6.79	-0.35	3.32	1.50	2.65	0.07	0.11	0.63	0.00
Col130	19	0.31	6.79	-0.35	3.32	1.50	2.65	0.05	0.11	0.61	0.00
Col130	20	0.39	6.79	-0.35	3.32	1.50	2.65	0.06	0.11	0.62	0.00
Col130	21	0.25	6.79	-0.35	3.32	1.50	2.65	0.04	0.11	0.60	0.00
Col130	22	0.29	6.79	-0.35	3.32	1.50	2.65	0.04	0.11	0.61	0.00
Col130	23	0.14	6.79	-0.35	3.32	1.50	2.65	0.02	0.11	0.59	0.00
Col130	24	0.39	6.79	-0.35	3.32	1.50	2.65	0.06	0.11	0.62	0.00
Col130	25	0.25	6.79	-0.35	3.32	1.50	2.65	0.04	0.11	0.60	0.00
Col130	26	0.29	6.79	-0.35	3.32	1.50	2.65	0.04	0.11	0.61	0.00
Col130	27	0.14	6.79	-0.35	3.32	1.50	2.65	0.02	0.11	0.59	0.00
Col130	28	-0.18	21.18	0.43	3.32	-1.81	2.65	0.01	0.13	0.68	0.00
Col130	29	-0.37	21.18	0.43	3.32	-1.81	2.65	0.02	0.13	0.67	0.00
Col130	30	-0.18	21.18	-0.47	3.32	2.00	2.65	0.01	0.14	0.75	0.00
Col130	31	-0.37	21.18	-0.47	3.32	2.00	2.65	0.02	0.14	0.74	0.00
Col130	32	-0.18	21.18	-0.47	3.32	2.00	2.65	0.01	0.14	0.75	0.00
Col130	33	-0.37	21.18	-0.47	3.32	2.00	2.65	0.02	0.14	0.74	0.00
Col130	34	-0.03	21.18	-0.47	3.32	2.00	2.65	0.00	0.14	0.75	0.00
Col130	35	-0.23	21.18	-0.47	3.32	2.00	2.65	0.01	0.14	0.74	0.00
Col130	36	0.14	6.79	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00

Col130	37	0.14	6.79	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col130	38	0.66	6.79	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col130	39	0.66	6.79	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col130	40	0.49	6.79	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col130	41	0.49	6.79	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col130	42	0.49	6.79	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col130	43	0.49	6.79	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col130	44	0.09	6.79	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col130	45	0.09	6.79	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col130	46	0.69	6.79	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col130	47	0.46	6.79	-0.35	3.32	1.50	2.65	0.07	0.11	0.63	0.00
Col130	48	0.32	6.79	-0.35	3.32	1.50	2.65	0.05	0.11	0.61	0.00
Col130	49	0.13	6.79	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col130	50	0.13	6.79	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col130	51	0.09	6.79	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col130	52	0.09	6.79	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col130	53	0.79	6.79	0.00	3.32	0.00	2.65	0.12	0.00	0.12	0.00
Col130	54	0.63	6.79	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col130	55	0.63	6.79	-0.35	3.32	1.50	2.65	0.09	0.11	0.66	0.00
Col130	56	0.63	6.79	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col131	1	0.83	7.01	0.00	3.32	0.00	2.65	0.12	0.00	0.12	0.00
Col131	2	0.13	7.01	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col131	3	0.60	7.01	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col131	4	0.60	7.01	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col131	5	0.66	7.01	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col131	6	0.49	7.01	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col131	7	0.49	7.01	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col131	8	-0.15	21.18	0.42	3.32	-1.77	2.65	0.01	0.13	0.66	0.00
Col131	9	-0.34	21.18	0.42	3.32	-1.77	2.65	0.02	0.13	0.65	0.00
Col131	10	-0.15	21.18	-0.46	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col131	11	-0.34	21.18	-0.46	3.32	1.95	2.65	0.02	0.14	0.72	0.00
Col131	12	-0.15	21.18	-0.46	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col131	13	-0.34	21.18	-0.46	3.32	1.95	2.65	0.02	0.14	0.72	0.00
Col131	14	-0.01	21.18	-0.46	3.32	1.95	2.65	0.00	0.14	0.74	0.00
Col131	15	-0.20	21.18	-0.46	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col131	16	0.57	7.01	-0.35	3.32	1.46	2.65	0.08	0.11	0.63	0.00
Col131	17	0.42	7.01	-0.35	3.32	1.46	2.65	0.06	0.11	0.61	0.00
Col131	18	0.46	7.01	-0.35	3.32	1.46	2.65	0.07	0.11	0.62	0.00
Col131	19	0.31	7.01	-0.35	3.32	1.46	2.65	0.04	0.11	0.60	0.00
Col131	20	0.39	7.01	-0.35	3.32	1.46	2.65	0.06	0.11	0.61	0.00
Col131	21	0.25	7.01	-0.35	3.32	1.46	2.65	0.04	0.11	0.59	0.00
Col131	22	0.29	7.01	-0.35	3.32	1.46	2.65	0.04	0.11	0.59	0.00
Col131	23	0.14	7.01	-0.35	3.32	1.46	2.65	0.02	0.11	0.57	0.00
Col131	24	0.39	7.01	-0.35	3.32	1.46	2.65	0.06	0.11	0.61	0.00
Col131	25	0.25	7.01	-0.35	3.32	1.46	2.65	0.04	0.11	0.59	0.00
Col131	26	0.29	7.01	-0.35	3.32	1.46	2.65	0.04	0.11	0.59	0.00
Col131	27	0.14	7.01	-0.35	3.32	1.46	2.65	0.02	0.11	0.57	0.00
Col131	28	-0.18	21.18	0.42	3.32	-1.77	2.65	0.01	0.13	0.66	0.00
Col131	29	-0.37	21.18	0.42	3.32	-1.77	2.65	0.02	0.13	0.65	0.00
Col131	30	-0.18	21.18	-0.46	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col131	31	-0.37	21.18	-0.46	3.32	1.95	2.65	0.02	0.14	0.72	0.00
Col131	32	-0.18	21.18	-0.46	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col131	33	-0.37	21.18	-0.46	3.32	1.95	2.65	0.02	0.14	0.72	0.00
Col131	34	-0.03	21.18	-0.46	3.32	1.95	2.65	0.00	0.14	0.73	0.00
Col131	35	-0.23	21.18	-0.46	3.32	1.95	2.65	0.01	0.14	0.72	0.00
Col131	36	0.14	7.01	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col131	37	0.14	7.01	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col131	38	0.66	7.01	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col131	39	0.66	7.01	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col131	40	0.49	7.01	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col131	41	0.49	7.01	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col131	42	0.49	7.01	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col131	43	0.49	7.01	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col131	44	0.09	7.01	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col131	45	0.09	7.01	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00

Col131	46	0.69	7.01	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col131	47	0.46	7.01	-0.35	3.32	1.46	2.65	0.07	0.11	0.62	0.00
Col131	48	0.32	7.01	-0.35	3.32	1.46	2.65	0.05	0.11	0.60	0.00
Col131	49	0.13	7.01	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col131	50	0.13	7.01	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col131	51	0.09	7.01	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col131	52	0.09	7.01	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col131	53	0.79	7.01	0.00	3.32	0.00	2.65	0.11	0.00	0.11	0.00
Col131	54	0.63	7.01	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col131	55	0.63	7.01	-0.35	3.32	1.46	2.65	0.09	0.11	0.64	0.00
Col131	56	0.63	7.01	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col132	1	0.83	7.23	0.00	3.32	0.00	2.65	0.12	0.00	0.12	0.00
Col132	2	0.13	7.23	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col132	3	0.60	7.23	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col132	4	0.60	7.23	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col132	5	0.66	7.23	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col132	6	0.48	7.23	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col132	7	0.48	7.23	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col132	8	-0.15	21.18	0.42	3.32	-1.72	2.65	0.01	0.13	0.64	0.00
Col132	9	-0.34	21.18	0.42	3.32	-1.72	2.65	0.02	0.13	0.64	0.00
Col132	10	-0.15	21.18	-0.46	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col132	11	-0.34	21.18	-0.46	3.32	1.90	2.65	0.02	0.14	0.70	0.00
Col132	12	-0.15	21.18	-0.46	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col132	13	-0.34	21.18	-0.46	3.32	1.90	2.65	0.02	0.14	0.70	0.00
Col132	14	-0.01	21.18	-0.46	3.32	1.90	2.65	0.00	0.14	0.72	0.00
Col132	15	-0.20	21.18	-0.46	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col132	16	0.57	7.23	-0.34	3.32	1.42	2.65	0.08	0.10	0.62	0.00
Col132	17	0.42	7.23	-0.34	3.32	1.42	2.65	0.06	0.10	0.60	0.00
Col132	18	0.46	7.23	-0.34	3.32	1.42	2.65	0.06	0.10	0.60	0.00
Col132	19	0.31	7.23	-0.34	3.32	1.42	2.65	0.04	0.10	0.58	0.00
Col132	20	0.39	7.23	-0.34	3.32	1.42	2.65	0.05	0.10	0.59	0.00
Col132	21	0.25	7.23	-0.34	3.32	1.42	2.65	0.03	0.10	0.57	0.00
Col132	22	0.28	7.23	-0.34	3.32	1.42	2.65	0.04	0.10	0.58	0.00
Col132	23	0.14	7.23	-0.34	3.32	1.42	2.65	0.02	0.10	0.56	0.00
Col132	24	0.39	7.23	-0.34	3.32	1.42	2.65	0.05	0.10	0.59	0.00
Col132	25	0.25	7.23	-0.34	3.32	1.42	2.65	0.03	0.10	0.57	0.00
Col132	26	0.28	7.23	-0.34	3.32	1.42	2.65	0.04	0.10	0.58	0.00
Col132	27	0.14	7.23	-0.34	3.32	1.42	2.65	0.02	0.10	0.56	0.00
Col132	28	-0.18	21.18	0.42	3.32	-1.72	2.65	0.01	0.13	0.64	0.00
Col132	29	-0.37	21.18	0.42	3.32	-1.72	2.65	0.02	0.13	0.63	0.00
Col132	30	-0.18	21.18	-0.46	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col132	31	-0.37	21.18	-0.46	3.32	1.90	2.65	0.02	0.14	0.70	0.00
Col132	32	-0.18	21.18	-0.46	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col132	33	-0.37	21.18	-0.46	3.32	1.90	2.65	0.02	0.14	0.70	0.00
Col132	34	-0.03	21.18	-0.46	3.32	1.90	2.65	0.00	0.14	0.72	0.00
Col132	35	-0.23	21.18	-0.46	3.32	1.90	2.65	0.01	0.14	0.71	0.00
Col132	36	0.14	7.23	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col132	37	0.14	7.23	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col132	38	0.66	7.23	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col132	39	0.66	7.23	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col132	40	0.49	7.23	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col132	41	0.49	7.23	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col132	42	0.49	7.23	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col132	43	0.49	7.23	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col132	44	0.09	7.23	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col132	45	0.09	7.23	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col132	46	0.69	7.23	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col132	47	0.46	7.23	-0.34	3.32	1.42	2.65	0.06	0.10	0.60	0.00
Col132	48	0.32	7.23	-0.34	3.32	1.42	2.65	0.04	0.10	0.58	0.00
Col132	49	0.13	7.23	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col132	50	0.13	7.23	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col132	51	0.09	7.23	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col132	52	0.09	7.23	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col132	53	0.73	7.23	0.00	3.32	0.00	2.65	0.10	0.00	0.10	0.00
Col132	54	0.58	7.23	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00

Col132	55	0.58	7.23	-0.34	3.32	1.42	2.65	0.08	0.10	0.62	0.00
Col132	56	0.58	7.23	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col133	1	0.83	7.45	0.00	3.32	0.00	2.65	0.11	0.00	0.11	0.00
Col133	2	0.13	7.45	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col133	3	0.60	7.45	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col133	4	0.60	7.45	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col133	5	0.66	7.45	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col133	6	0.48	7.45	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col133	7	0.48	7.45	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col133	8	-0.15	21.18	0.41	3.32	-1.68	2.65	0.01	0.12	0.63	0.00
Col133	9	-0.35	21.18	0.41	3.32	-1.68	2.65	0.02	0.12	0.62	0.00
Col133	10	-0.15	21.18	-0.48	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col133	11	-0.35	21.18	-0.48	3.32	1.95	2.65	0.02	0.14	0.72	0.00
Col133	12	-0.15	21.18	-0.48	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col133	13	-0.35	21.18	-0.48	3.32	1.95	2.65	0.02	0.14	0.72	0.00
Col133	14	-0.01	21.18	-0.48	3.32	1.95	2.65	0.00	0.14	0.74	0.00
Col133	15	-0.20	21.18	-0.48	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col133	16	0.57	7.45	-0.36	3.32	1.46	2.65	0.08	0.11	0.63	0.00
Col133	17	0.42	7.45	-0.36	3.32	1.46	2.65	0.06	0.11	0.61	0.00
Col133	18	0.46	7.45	-0.36	3.32	1.46	2.65	0.06	0.11	0.61	0.00
Col133	19	0.31	7.45	-0.36	3.32	1.46	2.65	0.04	0.11	0.60	0.00
Col133	20	0.39	7.45	-0.36	3.32	1.46	2.65	0.05	0.11	0.61	0.00
Col133	21	0.25	7.45	-0.36	3.32	1.46	2.65	0.03	0.11	0.59	0.00
Col133	22	0.28	7.45	-0.36	3.32	1.46	2.65	0.04	0.11	0.59	0.00
Col133	23	0.14	7.45	-0.36	3.32	1.46	2.65	0.02	0.11	0.57	0.00
Col133	24	0.39	7.45	-0.36	3.32	1.46	2.65	0.05	0.11	0.61	0.00
Col133	25	0.25	7.45	-0.36	3.32	1.46	2.65	0.03	0.11	0.59	0.00
Col133	26	0.28	7.45	-0.36	3.32	1.46	2.65	0.04	0.11	0.59	0.00
Col133	27	0.14	7.45	-0.36	3.32	1.46	2.65	0.02	0.11	0.57	0.00
Col133	28	-0.18	21.18	0.41	3.32	-1.68	2.65	0.01	0.12	0.63	0.00
Col133	29	-0.37	21.18	0.41	3.32	-1.68	2.65	0.02	0.12	0.62	0.00
Col133	30	-0.18	21.18	-0.48	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col133	31	-0.37	21.18	-0.48	3.32	1.95	2.65	0.02	0.14	0.72	0.00
Col133	32	-0.18	21.18	-0.48	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col133	33	-0.37	21.18	-0.48	3.32	1.95	2.65	0.02	0.14	0.72	0.00
Col133	34	-0.03	21.18	-0.48	3.32	1.95	2.65	0.00	0.14	0.74	0.00
Col133	35	-0.23	21.18	-0.48	3.32	1.95	2.65	0.01	0.14	0.73	0.00
Col133	36	0.14	7.45	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col133	37	0.14	7.45	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col133	38	0.66	7.45	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col133	39	0.66	7.45	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col133	40	0.49	7.45	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col133	41	0.49	7.45	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col133	42	0.49	7.45	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col133	43	0.49	7.45	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col133	44	0.08	7.45	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col133	45	0.08	7.45	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col133	46	0.69	7.45	0.00	3.32	0.00	2.65	0.09	0.00	0.09	0.00
Col133	47	0.46	7.45	-0.36	3.32	1.46	2.65	0.06	0.11	0.62	0.00
Col133	48	0.32	7.45	-0.36	3.32	1.46	2.65	0.04	0.11	0.60	0.00
Col133	49	0.13	7.45	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col133	50	0.13	7.45	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col133	51	0.09	7.45	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col133	52	0.09	7.45	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col133	53	0.61	7.45	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col133	54	0.49	7.45	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col133	55	0.49	7.45	-0.36	3.32	1.46	2.65	0.07	0.11	0.62	0.00
Col133	56	0.49	7.45	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00

COLUMN REACTIONS:

Id	Load		In_Plane		Out_Plane
	Id	Vert (k)	Horz (k)	Horz (k)	
Col122	1	0.83	0.00	0.00	

Col22	2	0.13	0.00	0.00
Col22	3	0.60	0.00	0.00
Col22	4	0.60	0.00	0.00
Col22	5	0.66	0.00	0.00
Col22	6	0.48	0.00	0.00
Col22	7	0.48	0.00	0.00
Col22	8	-0.35	0.00	-0.41
Col22	9	-0.15	0.00	-0.41
Col22	10	-0.35	0.00	0.47
Col22	11	-0.15	0.00	0.47
Col22	12	-0.35	0.00	0.47
Col22	13	-0.15	0.00	0.47
Col22	14	-0.20	0.00	0.47
Col22	15	-0.01	0.00	0.47
Col22	16	0.42	0.00	0.35
Col22	17	0.57	0.00	0.35
Col22	18	0.31	0.00	0.35
Col22	19	0.46	0.00	0.35
Col22	20	0.25	0.00	0.35
Col22	21	0.39	0.00	0.35
Col22	22	0.14	0.00	0.35
Col22	23	0.28	0.00	0.35
Col22	24	0.25	0.00	0.35
Col22	25	0.39	0.00	0.35
Col22	26	0.14	0.00	0.35
Col22	27	0.28	0.00	0.35
Col22	28	-0.37	0.00	-0.41
Col22	29	-0.18	0.00	-0.41
Col22	30	-0.37	0.00	0.47
Col22	31	-0.18	0.00	0.47
Col22	32	-0.37	0.00	0.47
Col22	33	-0.18	0.00	0.47
Col22	34	-0.23	0.00	0.47
Col22	35	-0.03	0.00	0.47
Col22	36	0.13	0.00	0.00
Col22	37	0.13	0.00	0.00
Col22	38	0.66	0.00	0.00
Col22	39	0.66	0.00	0.00
Col22	40	0.49	0.00	0.00
Col22	41	0.49	0.00	0.00
Col22	42	0.49	0.00	0.00
Col22	43	0.49	0.00	0.00
Col22	44	0.08	0.00	0.00
Col22	45	0.08	0.00	0.00
Col22	46	0.69	0.00	0.00
Col22	47	0.32	0.00	0.35
Col22	48	0.46	0.00	0.35
Col22	49	0.13	0.00	0.00
Col22	50	0.13	0.00	0.00
Col22	51	0.09	0.00	0.00
Col22	52	0.09	0.00	0.00
Col22	53	0.60	0.00	0.00
Col22	54	0.49	0.00	0.00
Col22	55	0.49	0.00	0.35
Col22	56	0.49	0.00	0.00
Col23	1	0.83	0.00	0.00
Col23	2	0.13	0.00	0.00
Col23	3	0.60	0.00	0.00
Col23	4	0.60	0.00	0.00
Col23	5	0.66	0.00	0.00
Col23	6	0.48	0.00	0.00
Col23	7	0.48	0.00	0.00
Col23	8	-0.35	0.00	-0.41
Col23	9	-0.15	0.00	-0.41
Col23	10	-0.35	0.00	0.45

Col23	11	-0.15	0.00	0.45
Col23	12	-0.35	0.00	0.45
Col23	13	-0.15	0.00	0.45
Col23	14	-0.20	0.00	0.45
Col23	15	-0.01	0.00	0.45
Col23	16	0.42	0.00	0.34
Col23	17	0.57	0.00	0.34
Col23	18	0.31	0.00	0.34
Col23	19	0.46	0.00	0.34
Col23	20	0.25	0.00	0.34
Col23	21	0.39	0.00	0.34
Col23	22	0.14	0.00	0.34
Col23	23	0.28	0.00	0.34
Col23	24	0.25	0.00	0.34
Col23	25	0.39	0.00	0.34
Col23	26	0.14	0.00	0.34
Col23	27	0.28	0.00	0.34
Col23	28	-0.37	0.00	-0.41
Col23	29	-0.18	0.00	-0.41
Col23	30	-0.37	0.00	0.45
Col23	31	-0.18	0.00	0.45
Col23	32	-0.37	0.00	0.45
Col23	33	-0.18	0.00	0.45
Col23	34	-0.23	0.00	0.45
Col23	35	-0.03	0.00	0.45
Col23	36	0.14	0.00	0.00
Col23	37	0.14	0.00	0.00
Col23	38	0.66	0.00	0.00
Col23	39	0.66	0.00	0.00
Col23	40	0.49	0.00	0.00
Col23	41	0.49	0.00	0.00
Col23	42	0.49	0.00	0.00
Col23	43	0.49	0.00	0.00
Col23	44	0.08	0.00	0.00
Col23	45	0.08	0.00	0.00
Col23	46	0.69	0.00	0.00
Col23	47	0.32	0.00	0.34
Col23	48	0.46	0.00	0.34
Col23	49	0.13	0.00	0.00
Col23	50	0.13	0.00	0.00
Col23	51	0.09	0.00	0.00
Col23	52	0.09	0.00	0.00
Col23	53	0.60	0.00	0.00
Col23	54	0.49	0.00	0.00
Col23	55	0.49	0.00	0.34
Col23	56	0.49	0.00	0.00
Col24	1	0.83	0.00	0.00
Col24	2	0.13	0.00	0.00
Col24	3	0.60	0.00	0.00
Col24	4	0.60	0.00	0.00
Col24	5	0.66	0.00	0.00
Col24	6	0.48	0.00	0.00
Col24	7	0.48	0.00	0.00
Col24	8	-0.34	0.00	-0.42
Col24	9	-0.15	0.00	-0.42
Col24	10	-0.34	0.00	0.46
Col24	11	-0.15	0.00	0.46
Col24	12	-0.34	0.00	0.46
Col24	13	-0.15	0.00	0.46
Col24	14	-0.20	0.00	0.46
Col24	15	-0.01	0.00	0.46
Col24	16	0.42	0.00	0.34
Col24	17	0.57	0.00	0.34
Col24	18	0.31	0.00	0.34
Col24	19	0.46	0.00	0.34

Col24	20	0.25	0.00	0.34
Col24	21	0.39	0.00	0.34
Col24	22	0.14	0.00	0.34
Col24	23	0.28	0.00	0.34
Col24	24	0.25	0.00	0.34
Col24	25	0.39	0.00	0.34
Col24	26	0.14	0.00	0.34
Col24	27	0.28	0.00	0.34
Col24	28	-0.37	0.00	-0.42
Col24	29	-0.18	0.00	-0.42
Col24	30	-0.37	0.00	0.46
Col24	31	-0.18	0.00	0.46
Col24	32	-0.37	0.00	0.46
Col24	33	-0.18	0.00	0.46
Col24	34	-0.23	0.00	0.46
Col24	35	-0.03	0.00	0.46
Col24	36	0.14	0.00	0.00
Col24	37	0.14	0.00	0.00
Col24	38	0.66	0.00	0.00
Col24	39	0.66	0.00	0.00
Col24	40	0.49	0.00	0.00
Col24	41	0.49	0.00	0.00
Col24	42	0.49	0.00	0.00
Col24	43	0.49	0.00	0.00
Col24	44	0.09	0.00	0.00
Col24	45	0.09	0.00	0.00
Col24	46	0.69	0.00	0.00
Col24	47	0.32	0.00	0.34
Col24	48	0.46	0.00	0.34
Col24	49	0.13	0.00	0.00
Col24	50	0.13	0.00	0.00
Col24	51	0.09	0.00	0.00
Col24	52	0.09	0.00	0.00
Col24	53	0.66	0.00	0.00
Col24	54	0.53	0.00	0.00
Col24	55	0.53	0.00	0.34
Col24	56	0.53	0.00	0.00
Col25	1	0.83	0.00	0.00
Col25	2	0.13	0.00	0.00
Col25	3	0.60	0.00	0.00
Col25	4	0.60	0.00	0.00
Col25	5	0.66	0.00	0.00
Col25	6	0.49	0.00	0.00
Col25	7	0.49	0.00	0.00
Col25	8	-0.34	0.00	-0.42
Col25	9	-0.15	0.00	-0.42
Col25	10	-0.34	0.00	0.46
Col25	11	-0.15	0.00	0.46
Col25	12	-0.34	0.00	0.46
Col25	13	-0.15	0.00	0.46
Col25	14	-0.20	0.00	0.46
Col25	15	-0.01	0.00	0.46
Col25	16	0.42	0.00	0.35
Col25	17	0.57	0.00	0.35
Col25	18	0.31	0.00	0.35
Col25	19	0.46	0.00	0.35
Col25	20	0.25	0.00	0.35
Col25	21	0.39	0.00	0.35
Col25	22	0.14	0.00	0.35
Col25	23	0.29	0.00	0.35
Col25	24	0.25	0.00	0.35
Col25	25	0.39	0.00	0.35
Col25	26	0.14	0.00	0.35
Col25	27	0.29	0.00	0.35
Col25	28	-0.37	0.00	-0.42

Col125	29	-0.18	0.00	-0.42
Col125	30	-0.37	0.00	0.46
Col125	31	-0.18	0.00	0.46
Col125	32	-0.37	0.00	0.46
Col125	33	-0.18	0.00	0.46
Col125	34	-0.23	0.00	0.46
Col125	35	-0.03	0.00	0.46
Col125	36	0.14	0.00	0.00
Col125	37	0.14	0.00	0.00
Col125	38	0.66	0.00	0.00
Col125	39	0.66	0.00	0.00
Col125	40	0.49	0.00	0.00
Col125	41	0.49	0.00	0.00
Col125	42	0.49	0.00	0.00
Col125	43	0.49	0.00	0.00
Col125	44	0.09	0.00	0.00
Col125	45	0.09	0.00	0.00
Col125	46	0.69	0.00	0.00
Col125	47	0.32	0.00	0.35
Col125	48	0.46	0.00	0.35
Col125	49	0.13	0.00	0.00
Col125	50	0.13	0.00	0.00
Col125	51	0.09	0.00	0.00
Col125	52	0.09	0.00	0.00
Col125	53	0.77	0.00	0.00
Col125	54	0.61	0.00	0.00
Col125	55	0.61	0.00	0.35
Col125	56	0.62	0.00	0.00
Col126	1	0.83	0.00	0.00
Col126	2	0.13	0.00	0.00
Col126	3	0.60	0.00	0.00
Col126	4	0.60	0.00	0.00
Col126	5	0.66	0.00	0.00
Col126	6	0.49	0.00	0.00
Col126	7	0.49	0.00	0.00
Col126	8	-0.34	0.00	-0.43
Col126	9	-0.15	0.00	-0.43
Col126	10	-0.34	0.00	0.47
Col126	11	-0.15	0.00	0.47
Col126	12	-0.34	0.00	0.47
Col126	13	-0.15	0.00	0.47
Col126	14	-0.20	0.00	0.47
Col126	15	0.00	0.00	0.47
Col126	16	0.42	0.00	0.35
Col126	17	0.57	0.00	0.35
Col126	18	0.31	0.00	0.35
Col126	19	0.46	0.00	0.35
Col126	20	0.25	0.00	0.35
Col126	21	0.39	0.00	0.35
Col126	22	0.14	0.00	0.35
Col126	23	0.29	0.00	0.35
Col126	24	0.25	0.00	0.35
Col126	25	0.39	0.00	0.35
Col126	26	0.14	0.00	0.35
Col126	27	0.29	0.00	0.35
Col126	28	-0.37	0.00	-0.43
Col126	29	-0.18	0.00	-0.43
Col126	30	-0.37	0.00	0.47
Col126	31	-0.18	0.00	0.47
Col126	32	-0.37	0.00	0.47
Col126	33	-0.18	0.00	0.47
Col126	34	-0.23	0.00	0.47
Col126	35	-0.03	0.00	0.47
Col126	36	0.14	0.00	0.00
Col126	37	0.14	0.00	0.00

Col26	38	0.66	0.00	0.00
Col26	39	0.66	0.00	0.00
Col26	40	0.49	0.00	0.00
Col26	41	0.49	0.00	0.00
Col26	42	0.49	0.00	0.00
Col26	43	0.49	0.00	0.00
Col26	44	0.09	0.00	0.00
Col26	45	0.09	0.00	0.00
Col26	46	0.69	0.00	0.00
Col26	47	0.32	0.00	0.35
Col26	48	0.46	0.00	0.35
Col26	49	0.13	0.00	0.00
Col26	50	0.13	0.00	0.00
Col26	51	0.09	0.00	0.00
Col26	52	0.09	0.00	0.00
Col26	53	0.78	0.00	0.00
Col26	54	0.62	0.00	0.00
Col26	55	0.62	0.00	0.35
Col26	56	0.62	0.00	0.00
Col27	1	0.83	0.00	0.00
Col27	2	0.13	0.00	0.00
Col27	3	0.60	0.00	0.00
Col27	4	0.60	0.00	0.00
Col27	5	0.66	0.00	0.00
Col27	6	0.49	0.00	0.00
Col27	7	0.49	0.00	0.00
Col27	8	-0.34	0.00	-0.43
Col27	9	-0.15	0.00	-0.43
Col27	10	-0.34	0.00	0.48
Col27	11	-0.15	0.00	0.48
Col27	12	-0.34	0.00	0.48
Col27	13	-0.15	0.00	0.48
Col27	14	-0.20	0.00	0.48
Col27	15	0.00	0.00	0.48
Col27	16	0.42	0.00	0.36
Col27	17	0.57	0.00	0.36
Col27	18	0.31	0.00	0.36
Col27	19	0.46	0.00	0.36
Col27	20	0.25	0.00	0.36
Col27	21	0.40	0.00	0.36
Col27	22	0.14	0.00	0.36
Col27	23	0.29	0.00	0.36
Col27	24	0.25	0.00	0.36
Col27	25	0.40	0.00	0.36
Col27	26	0.14	0.00	0.36
Col27	27	0.29	0.00	0.36
Col27	28	-0.37	0.00	-0.43
Col27	29	-0.18	0.00	-0.43
Col27	30	-0.37	0.00	0.48
Col27	31	-0.18	0.00	0.48
Col27	32	-0.37	0.00	0.48
Col27	33	-0.18	0.00	0.48
Col27	34	-0.23	0.00	0.48
Col27	35	-0.03	0.00	0.48
Col27	36	0.14	0.00	0.00
Col27	37	0.14	0.00	0.00
Col27	38	0.66	0.00	0.00
Col27	39	0.66	0.00	0.00
Col27	40	0.49	0.00	0.00
Col27	41	0.49	0.00	0.00
Col27	42	0.49	0.00	0.00
Col27	43	0.49	0.00	0.00
Col27	44	0.09	0.00	0.00
Col27	45	0.09	0.00	0.00
Col27	46	0.69	0.00	0.00

Col127	47	0.32	0.00	0.36
Col127	48	0.46	0.00	0.36
Col127	49	0.13	0.00	0.00
Col127	50	0.13	0.00	0.00
Col127	51	0.09	0.00	0.00
Col127	52	0.09	0.00	0.00
Col127	53	0.78	0.00	0.00
Col127	54	0.62	0.00	0.00
Col127	55	0.62	0.00	0.36
Col127	56	0.62	0.00	0.00
Col128	1	0.83	0.00	0.00
Col128	2	0.13	0.00	0.00
Col128	3	0.60	0.00	0.00
Col128	4	0.60	0.00	0.00
Col128	5	0.66	0.00	0.00
Col128	6	0.49	0.00	0.00
Col128	7	0.49	0.00	0.00
Col128	8	-0.24	0.00	0.00
Col128	9	-0.24	0.00	0.00
Col128	10	-0.24	0.00	0.00
Col128	11	-0.24	0.00	0.00
Col128	12	-0.24	0.00	0.00
Col128	13	-0.24	0.00	0.00
Col128	14	-0.10	0.00	0.00
Col128	15	-0.10	0.00	0.00
Col128	16	0.50	0.00	0.00
Col128	17	0.50	0.00	0.00
Col128	18	0.39	0.00	0.00
Col128	19	0.39	0.00	0.00
Col128	20	0.32	0.00	0.00
Col128	21	0.32	0.00	0.00
Col128	22	0.22	0.00	0.00
Col128	23	0.22	0.00	0.00
Col128	24	0.32	0.00	0.00
Col128	25	0.32	0.00	0.00
Col128	26	0.22	0.00	0.00
Col128	27	0.22	0.00	0.00
Col128	28	-0.27	0.00	0.00
Col128	29	-0.27	0.00	0.00
Col128	30	-0.27	0.00	0.00
Col128	31	-0.27	0.00	0.00
Col128	32	-0.27	0.00	0.00
Col128	33	-0.27	0.00	0.00
Col128	34	-0.13	0.00	0.00
Col128	35	-0.13	0.00	0.00
Col128	36	0.14	0.00	0.00
Col128	37	0.14	0.00	0.00
Col128	38	0.66	0.00	0.00
Col128	39	0.66	0.00	0.00
Col128	40	0.49	0.00	0.00
Col128	41	0.49	0.00	0.00
Col128	42	0.49	0.00	0.00
Col128	43	0.49	0.00	0.00
Col128	44	0.09	0.00	0.00
Col128	45	0.09	0.00	0.00
Col128	46	0.68	0.00	0.00
Col128	47	0.38	0.00	0.00
Col128	48	0.38	0.00	0.00
Col128	49	0.13	0.00	0.00
Col128	50	0.13	0.00	0.00
Col128	51	0.09	0.00	0.00
Col128	52	0.09	0.00	0.00
Col128	53	0.77	0.00	0.00
Col128	54	0.61	0.00	0.00
Col128	55	0.61	0.00	0.00

Col128	56	0.61	0.00	0.00
Col129	1	0.83	0.00	0.00
Col129	2	0.13	0.00	0.00
Col129	3	0.60	0.00	0.00
Col129	4	0.60	0.00	0.00
Col129	5	0.66	0.00	0.00
Col129	6	0.49	0.00	0.00
Col129	7	0.49	0.00	0.00
Col129	8	-0.15	0.00	-0.43
Col129	9	-0.34	0.00	-0.43
Col129	10	-0.15	0.00	0.48
Col129	11	-0.34	0.00	0.48
Col129	12	-0.15	0.00	0.48
Col129	13	-0.34	0.00	0.48
Col129	14	0.00	0.00	0.48
Col129	15	-0.20	0.00	0.48
Col129	16	0.57	0.00	0.36
Col129	17	0.42	0.00	0.36
Col129	18	0.46	0.00	0.36
Col129	19	0.31	0.00	0.36
Col129	20	0.40	0.00	0.36
Col129	21	0.25	0.00	0.36
Col129	22	0.29	0.00	0.36
Col129	23	0.14	0.00	0.36
Col129	24	0.40	0.00	0.36
Col129	25	0.25	0.00	0.36
Col129	26	0.29	0.00	0.36
Col129	27	0.14	0.00	0.36
Col129	28	-0.18	0.00	-0.43
Col129	29	-0.37	0.00	-0.43
Col129	30	-0.18	0.00	0.48
Col129	31	-0.37	0.00	0.48
Col129	32	-0.18	0.00	0.48
Col129	33	-0.37	0.00	0.48
Col129	34	-0.03	0.00	0.48
Col129	35	-0.23	0.00	0.48
Col129	36	0.14	0.00	0.00
Col129	37	0.14	0.00	0.00
Col129	38	0.66	0.00	0.00
Col129	39	0.66	0.00	0.00
Col129	40	0.49	0.00	0.00
Col129	41	0.49	0.00	0.00
Col129	42	0.49	0.00	0.00
Col129	43	0.49	0.00	0.00
Col129	44	0.09	0.00	0.00
Col129	45	0.09	0.00	0.00
Col129	46	0.69	0.00	0.00
Col129	47	0.46	0.00	0.36
Col129	48	0.32	0.00	0.36
Col129	49	0.13	0.00	0.00
Col129	50	0.13	0.00	0.00
Col129	51	0.09	0.00	0.00
Col129	52	0.09	0.00	0.00
Col129	53	0.79	0.00	0.00
Col129	54	0.63	0.00	0.00
Col129	55	0.63	0.00	0.36
Col129	56	0.63	0.00	0.00
Col130	1	0.83	0.00	0.00
Col130	2	0.13	0.00	0.00
Col130	3	0.60	0.00	0.00
Col130	4	0.60	0.00	0.00
Col130	5	0.66	0.00	0.00
Col130	6	0.49	0.00	0.00
Col130	7	0.49	0.00	0.00
Col130	8	-0.15	0.00	-0.43

Col130	9	-0.34	0.00	-0.43
Col130	10	-0.15	0.00	0.47
Col130	11	-0.34	0.00	0.47
Col130	12	-0.15	0.00	0.47
Col130	13	-0.34	0.00	0.47
Col130	14	0.00	0.00	0.47
Col130	15	-0.20	0.00	0.47
Col130	16	0.57	0.00	0.35
Col130	17	0.42	0.00	0.35
Col130	18	0.46	0.00	0.35
Col130	19	0.31	0.00	0.35
Col130	20	0.39	0.00	0.35
Col130	21	0.25	0.00	0.35
Col130	22	0.29	0.00	0.35
Col130	23	0.14	0.00	0.35
Col130	24	0.39	0.00	0.35
Col130	25	0.25	0.00	0.35
Col130	26	0.29	0.00	0.35
Col130	27	0.14	0.00	0.35
Col130	28	-0.18	0.00	-0.43
Col130	29	-0.37	0.00	-0.43
Col130	30	-0.18	0.00	0.47
Col130	31	-0.37	0.00	0.47
Col130	32	-0.18	0.00	0.47
Col130	33	-0.37	0.00	0.47
Col130	34	-0.03	0.00	0.47
Col130	35	-0.23	0.00	0.47
Col130	36	0.14	0.00	0.00
Col130	37	0.14	0.00	0.00
Col130	38	0.66	0.00	0.00
Col130	39	0.66	0.00	0.00
Col130	40	0.49	0.00	0.00
Col130	41	0.49	0.00	0.00
Col130	42	0.49	0.00	0.00
Col130	43	0.49	0.00	0.00
Col130	44	0.09	0.00	0.00
Col130	45	0.09	0.00	0.00
Col130	46	0.69	0.00	0.00
Col130	47	0.46	0.00	0.35
Col130	48	0.32	0.00	0.35
Col130	49	0.13	0.00	0.00
Col130	50	0.13	0.00	0.00
Col130	51	0.09	0.00	0.00
Col130	52	0.09	0.00	0.00
Col130	53	0.79	0.00	0.00
Col130	54	0.63	0.00	0.00
Col130	55	0.63	0.00	0.35
Col130	56	0.63	0.00	0.00
Col131	1	0.83	0.00	0.00
Col131	2	0.13	0.00	0.00
Col131	3	0.60	0.00	0.00
Col131	4	0.60	0.00	0.00
Col131	5	0.66	0.00	0.00
Col131	6	0.49	0.00	0.00
Col131	7	0.49	0.00	0.00
Col131	8	-0.15	0.00	-0.42
Col131	9	-0.34	0.00	-0.42
Col131	10	-0.15	0.00	0.46
Col131	11	-0.34	0.00	0.46
Col131	12	-0.15	0.00	0.46
Col131	13	-0.34	0.00	0.46
Col131	14	-0.01	0.00	0.46
Col131	15	-0.20	0.00	0.46
Col131	16	0.57	0.00	0.35
Col131	17	0.42	0.00	0.35

Col131	18	0.46	0.00	0.35
Col131	19	0.31	0.00	0.35
Col131	20	0.39	0.00	0.35
Col131	21	0.25	0.00	0.35
Col131	22	0.29	0.00	0.35
Col131	23	0.14	0.00	0.35
Col131	24	0.39	0.00	0.35
Col131	25	0.25	0.00	0.35
Col131	26	0.29	0.00	0.35
Col131	27	0.14	0.00	0.35
Col131	28	-0.18	0.00	-0.42
Col131	29	-0.37	0.00	-0.42
Col131	30	-0.18	0.00	0.46
Col131	31	-0.37	0.00	0.46
Col131	32	-0.18	0.00	0.46
Col131	33	-0.37	0.00	0.46
Col131	34	-0.03	0.00	0.46
Col131	35	-0.23	0.00	0.46
Col131	36	0.14	0.00	0.00
Col131	37	0.14	0.00	0.00
Col131	38	0.66	0.00	0.00
Col131	39	0.66	0.00	0.00
Col131	40	0.49	0.00	0.00
Col131	41	0.49	0.00	0.00
Col131	42	0.49	0.00	0.00
Col131	43	0.49	0.00	0.00
Col131	44	0.09	0.00	0.00
Col131	45	0.09	0.00	0.00
Col131	46	0.69	0.00	0.00
Col131	47	0.46	0.00	0.35
Col131	48	0.32	0.00	0.35
Col131	49	0.13	0.00	0.00
Col131	50	0.13	0.00	0.00
Col131	51	0.09	0.00	0.00
Col131	52	0.09	0.00	0.00
Col131	53	0.79	0.00	0.00
Col131	54	0.63	0.00	0.00
Col131	55	0.63	0.00	0.35
Col131	56	0.63	0.00	0.00
Col132	1	0.83	0.00	0.00
Col132	2	0.13	0.00	0.00
Col132	3	0.60	0.00	0.00
Col132	4	0.60	0.00	0.00
Col132	5	0.66	0.00	0.00
Col132	6	0.48	0.00	0.00
Col132	7	0.48	0.00	0.00
Col132	8	-0.15	0.00	-0.42
Col132	9	-0.34	0.00	-0.42
Col132	10	-0.15	0.00	0.46
Col132	11	-0.34	0.00	0.46
Col132	12	-0.15	0.00	0.46
Col132	13	-0.34	0.00	0.46
Col132	14	-0.01	0.00	0.46
Col132	15	-0.20	0.00	0.46
Col132	16	0.57	0.00	0.34
Col132	17	0.42	0.00	0.34
Col132	18	0.46	0.00	0.34
Col132	19	0.31	0.00	0.34
Col132	20	0.39	0.00	0.34
Col132	21	0.25	0.00	0.34
Col132	22	0.28	0.00	0.34
Col132	23	0.14	0.00	0.34
Col132	24	0.39	0.00	0.34
Col132	25	0.25	0.00	0.34
Col132	26	0.28	0.00	0.34

Col32	27	0.14	0.00	0.34
Col32	28	-0.18	0.00	-0.42
Col32	29	-0.37	0.00	-0.42
Col32	30	-0.18	0.00	0.46
Col32	31	-0.37	0.00	0.46
Col32	32	-0.18	0.00	0.46
Col32	33	-0.37	0.00	0.46
Col32	34	-0.03	0.00	0.46
Col32	35	-0.23	0.00	0.46
Col32	36	0.14	0.00	0.00
Col32	37	0.14	0.00	0.00
Col32	38	0.66	0.00	0.00
Col32	39	0.66	0.00	0.00
Col32	40	0.49	0.00	0.00
Col32	41	0.49	0.00	0.00
Col32	42	0.49	0.00	0.00
Col32	43	0.49	0.00	0.00
Col32	44	0.09	0.00	0.00
Col32	45	0.09	0.00	0.00
Col32	46	0.69	0.00	0.00
Col32	47	0.46	0.00	0.34
Col32	48	0.32	0.00	0.34
Col32	49	0.13	0.00	0.00
Col32	50	0.13	0.00	0.00
Col32	51	0.09	0.00	0.00
Col32	52	0.09	0.00	0.00
Col32	53	0.73	0.00	0.00
Col32	54	0.58	0.00	0.00
Col32	55	0.58	0.00	0.34
Col32	56	0.58	0.00	0.00
Col33	1	0.83	0.00	0.00
Col33	2	0.13	0.00	0.00
Col33	3	0.60	0.00	0.00
Col33	4	0.60	0.00	0.00
Col33	5	0.66	0.00	0.00
Col33	6	0.48	0.00	0.00
Col33	7	0.48	0.00	0.00
Col33	8	-0.15	0.00	-0.41
Col33	9	-0.35	0.00	-0.41
Col33	10	-0.15	0.00	0.48
Col33	11	-0.35	0.00	0.48
Col33	12	-0.15	0.00	0.48
Col33	13	-0.35	0.00	0.48
Col33	14	-0.01	0.00	0.48
Col33	15	-0.20	0.00	0.48
Col33	16	0.57	0.00	0.36
Col33	17	0.42	0.00	0.36
Col33	18	0.46	0.00	0.36
Col33	19	0.31	0.00	0.36
Col33	20	0.39	0.00	0.36
Col33	21	0.25	0.00	0.36
Col33	22	0.28	0.00	0.36
Col33	23	0.14	0.00	0.36
Col33	24	0.39	0.00	0.36
Col33	25	0.25	0.00	0.36
Col33	26	0.28	0.00	0.36
Col33	27	0.14	0.00	0.36
Col33	28	-0.18	0.00	-0.41
Col33	29	-0.37	0.00	-0.41
Col33	30	-0.18	0.00	0.48
Col33	31	-0.37	0.00	0.48
Col33	32	-0.18	0.00	0.48
Col33	33	-0.37	0.00	0.48
Col33	34	-0.03	0.00	0.48
Col33	35	-0.23	0.00	0.48

Col133	36	0.14	0.00	0.00
Col133	37	0.14	0.00	0.00
Col133	38	0.66	0.00	0.00
Col133	39	0.66	0.00	0.00
Col133	40	0.49	0.00	0.00
Col133	41	0.49	0.00	0.00
Col133	42	0.49	0.00	0.00
Col133	43	0.49	0.00	0.00
Col133	44	0.08	0.00	0.00
Col133	45	0.08	0.00	0.00
Col133	46	0.69	0.00	0.00
Col133	47	0.46	0.00	0.36
Col133	48	0.32	0.00	0.36
Col133	49	0.13	0.00	0.00
Col133	50	0.13	0.00	0.00
Col133	51	0.09	0.00	0.00
Col133	52	0.09	0.00	0.00
Col133	53	0.61	0.00	0.00
Col133	54	0.49	0.00	0.00
Col133	55	0.49	0.00	0.36
Col133	56	0.49	0.00	0.00

COLUMN DEFLECTIONS:

Load		Deflection(in)	
Id	Id	Calc	Limit
-----	----	-----	-----
Col122	1	0.00	1.08
Col122	2	0.00	1.08
Col122	3	0.00	1.08
Col122	4	0.00	1.08
Col122	5	0.00	1.08
Col122	6	0.00	1.08
Col122	7	0.00	1.08
Col122	8	-0.69	1.08
Col122	9	-0.69	1.08
Col122	10	0.80	1.08
Col122	11	0.80	1.08
Col122	12	0.80	1.08
Col122	13	0.80	1.08
Col122	14	0.80	1.08
Col122	15	0.80	1.08
Col122	16	0.60	1.08
Col122	17	0.60	1.08
Col122	18	0.60	1.08
Col122	19	0.60	1.08
Col122	20	0.60	1.08
Col122	21	0.60	1.08
Col122	22	0.60	1.08
Col122	23	0.60	1.08
Col122	24	0.60	1.08
Col122	25	0.60	1.08
Col122	26	0.60	1.08
Col122	27	0.60	1.08
Col122	28	-0.69	1.08
Col122	29	-0.69	1.08
Col122	30	0.80	1.08
Col122	31	0.80	1.08
Col122	32	0.80	1.08
Col122	33	0.80	1.08
Col122	34	0.80	1.08
Col122	35	0.80	1.08
Col122	36	0.00	1.08
Col122	37	0.00	1.08
Col122	38	0.00	1.08

Col22	39	0.00	1.08
Col22	40	0.00	1.08
Col22	41	0.00	1.08
Col22	42	0.00	1.08
Col22	43	0.00	1.08
Col22	44	0.00	1.08
Col22	45	0.00	1.08
Col22	46	0.00	1.08
Col22	47	0.36	1.08
Col22	48	0.36	1.08
Col22	49	0.00	1.08
Col22	50	0.00	1.08
Col22	51	0.60	1.08
Col22	52	0.00	1.08
Col23	1	0.00	1.09
Col23	2	0.00	1.09
Col23	3	0.00	1.09
Col23	4	0.00	1.09
Col23	5	0.00	1.09
Col23	6	0.00	1.09
Col23	7	0.00	1.09
Col23	8	-0.73	1.09
Col23	9	-0.73	1.09
Col23	10	0.80	1.09
Col23	11	0.80	1.09
Col23	12	0.80	1.09
Col23	13	0.80	1.09
Col23	14	0.80	1.09
Col23	15	0.80	1.09
Col23	16	0.60	1.09
Col23	17	0.60	1.09
Col23	18	0.60	1.09
Col23	19	0.60	1.09
Col23	20	0.60	1.09
Col23	21	0.60	1.09
Col23	22	0.60	1.09
Col23	23	0.60	1.09
Col23	24	0.60	1.09
Col23	25	0.60	1.09
Col23	26	0.60	1.09
Col23	27	0.60	1.09
Col23	28	-0.73	1.09
Col23	29	-0.73	1.09
Col23	30	0.80	1.09
Col23	31	0.80	1.09
Col23	32	0.80	1.09
Col23	33	0.80	1.09
Col23	34	0.80	1.09
Col23	35	0.80	1.09
Col23	36	0.00	1.09
Col23	37	0.00	1.09
Col23	38	0.00	1.09
Col23	39	0.00	1.09
Col23	40	0.00	1.09
Col23	41	0.00	1.09
Col23	42	0.00	1.09
Col23	43	0.00	1.09
Col23	44	0.00	1.09
Col23	45	0.00	1.09
Col23	46	0.00	1.09
Col23	47	0.36	1.09
Col23	48	0.36	1.09
Col23	49	0.00	1.09
Col23	50	0.00	1.09
Col23	51	0.60	1.09

Col23	52	0.00	1.09
Col24	1	0.00	1.10
Col24	2	0.00	1.10
Col24	3	0.00	1.10
Col24	4	0.00	1.10
Col24	5	0.00	1.10
Col24	6	0.00	1.10
Col24	7	0.00	1.10
Col24	8	-0.77	1.10
Col24	9	-0.77	1.10
Col24	10	0.84	1.10
Col24	11	0.84	1.10
Col24	12	0.84	1.10
Col24	13	0.84	1.10
Col24	14	0.84	1.10
Col24	15	0.84	1.10
Col24	16	0.63	1.10
Col24	17	0.63	1.10
Col24	18	0.63	1.10
Col24	19	0.63	1.10
Col24	20	0.63	1.10
Col24	21	0.63	1.10
Col24	22	0.63	1.10
Col24	23	0.63	1.10
Col24	24	0.63	1.10
Col24	25	0.63	1.10
Col24	26	0.63	1.10
Col24	27	0.63	1.10
Col24	28	-0.77	1.10
Col24	29	-0.77	1.10
Col24	30	0.84	1.10
Col24	31	0.84	1.10
Col24	32	0.84	1.10
Col24	33	0.84	1.10
Col24	34	0.84	1.10
Col24	35	0.84	1.10
Col24	36	0.00	1.10
Col24	37	0.00	1.10
Col24	38	0.00	1.10
Col24	39	0.00	1.10
Col24	40	0.00	1.10
Col24	41	0.00	1.10
Col24	42	0.00	1.10
Col24	43	0.00	1.10
Col24	44	0.00	1.10
Col24	45	0.00	1.10
Col24	46	0.00	1.10
Col24	47	0.38	1.10
Col24	48	0.38	1.10
Col24	49	0.00	1.10
Col24	50	0.00	1.10
Col24	51	0.63	1.10
Col24	52	0.00	1.10
Col25	1	0.00	1.12
Col25	2	0.00	1.12
Col25	3	0.00	1.12
Col25	4	0.00	1.12
Col25	5	0.00	1.12
Col25	6	0.00	1.12
Col25	7	0.00	1.12
Col25	8	-0.81	1.12
Col25	9	-0.81	1.12
Col25	10	0.89	1.12
Col25	11	0.89	1.12
Col25	12	0.89	1.12

Col25	13	0.89	1.12
Col25	14	0.89	1.12
Col25	15	0.89	1.12
Col25	16	0.67	1.12
Col25	17	0.67	1.12
Col25	18	0.67	1.12
Col25	19	0.67	1.12
Col25	20	0.67	1.12
Col25	21	0.67	1.12
Col25	22	0.67	1.12
Col25	23	0.67	1.12
Col25	24	0.67	1.12
Col25	25	0.67	1.12
Col25	26	0.67	1.12
Col25	27	0.67	1.12
Col25	28	-0.81	1.12
Col25	29	-0.81	1.12
Col25	30	0.89	1.12
Col25	31	0.89	1.12
Col25	32	0.89	1.12
Col25	33	0.89	1.12
Col25	34	0.89	1.12
Col25	35	0.89	1.12
Col25	36	0.00	1.12
Col25	37	0.00	1.12
Col25	38	0.00	1.12
Col25	39	0.00	1.12
Col25	40	0.00	1.12
Col25	41	0.00	1.12
Col25	42	0.00	1.12
Col25	43	0.00	1.12
Col25	44	0.00	1.12
Col25	45	0.00	1.12
Col25	46	0.00	1.12
Col25	47	0.40	1.12
Col25	48	0.40	1.12
Col25	49	0.00	1.12
Col25	50	0.00	1.12
Col25	51	0.67	1.12
Col25	52	0.00	1.12
Col26	1	0.00	1.13
Col26	2	0.00	1.13
Col26	3	0.00	1.13
Col26	4	0.00	1.13
Col26	5	0.00	1.13
Col26	6	0.00	1.13
Col26	7	0.00	1.13
Col26	8	-0.85	1.13
Col26	9	-0.85	1.13
Col26	10	0.93	1.13
Col26	11	0.93	1.13
Col26	12	0.93	1.13
Col26	13	0.93	1.13
Col26	14	0.93	1.13
Col26	15	0.93	1.13
Col26	16	0.70	1.13
Col26	17	0.70	1.13
Col26	18	0.70	1.13
Col26	19	0.70	1.13
Col26	20	0.70	1.13
Col26	21	0.70	1.13
Col26	22	0.70	1.13
Col26	23	0.70	1.13
Col26	24	0.70	1.13
Col26	25	0.70	1.13

Col26	26	0.70	1.13
Col26	27	0.70	1.13
Col26	28	-0.85	1.13
Col26	29	-0.85	1.13
Col26	30	0.93	1.13
Col26	31	0.93	1.13
Col26	32	0.93	1.13
Col26	33	0.93	1.13
Col26	34	0.93	1.13
Col26	35	0.93	1.13
Col26	36	0.00	1.13
Col26	37	0.00	1.13
Col26	38	0.00	1.13
Col26	39	0.00	1.13
Col26	40	0.00	1.13
Col26	41	0.00	1.13
Col26	42	0.00	1.13
Col26	43	0.00	1.13
Col26	44	0.00	1.13
Col26	45	0.00	1.13
Col26	46	0.00	1.13
Col26	47	0.42	1.13
Col26	48	0.42	1.13
Col26	49	0.00	1.13
Col26	50	0.00	1.13
Col26	51	0.70	1.13
Col26	52	0.00	1.13
Col27	1	0.00	1.14
Col27	2	0.00	1.14
Col27	3	0.00	1.14
Col27	4	0.00	1.14
Col27	5	0.00	1.14
Col27	6	0.00	1.14
Col27	7	0.00	1.14
Col27	8	-0.89	1.14
Col27	9	-0.89	1.14
Col27	10	0.98	1.14
Col27	11	0.98	1.14
Col27	12	0.98	1.14
Col27	13	0.98	1.14
Col27	14	0.98	1.14
Col27	15	0.98	1.14
Col27	16	0.73	1.14
Col27	17	0.73	1.14
Col27	18	0.73	1.14
Col27	19	0.73	1.14
Col27	20	0.73	1.14
Col27	21	0.73	1.14
Col27	22	0.73	1.14
Col27	23	0.73	1.14
Col27	24	0.73	1.14
Col27	25	0.73	1.14
Col27	26	0.73	1.14
Col27	27	0.73	1.14
Col27	28	-0.89	1.14
Col27	29	-0.89	1.14
Col27	30	0.98	1.14
Col27	31	0.98	1.14
Col27	32	0.98	1.14
Col27	33	0.98	1.14
Col27	34	0.98	1.14
Col27	35	0.98	1.14
Col27	36	0.00	1.14
Col27	37	0.00	1.14
Col27	38	0.00	1.14

Col27	39	0.00	1.14
Col27	40	0.00	1.14
Col27	41	0.00	1.14
Col27	42	0.00	1.14
Col27	43	0.00	1.14
Col27	44	0.00	1.14
Col27	45	0.00	1.14
Col27	46	0.00	1.14
Col27	47	0.44	1.14
Col27	48	0.44	1.14
Col27	49	0.00	1.14
Col27	50	0.00	1.14
Col27	51	0.73	1.14
Col27	52	0.00	1.14
Col28	1	0.00	1.15
Col28	2	0.00	1.15
Col28	3	0.00	1.15
Col28	4	0.00	1.15
Col28	5	0.00	1.15
Col28	6	0.00	1.15
Col28	7	0.00	1.15
Col28	8	0.00	1.15
Col28	9	0.00	1.15
Col28	10	0.00	1.15
Col28	11	0.00	1.15
Col28	12	0.00	1.15
Col28	13	0.00	1.15
Col28	14	0.00	1.15
Col28	15	0.00	1.15
Col28	16	0.00	1.15
Col28	17	0.00	1.15
Col28	18	0.00	1.15
Col28	19	0.00	1.15
Col28	20	0.00	1.15
Col28	21	0.00	1.15
Col28	22	0.00	1.15
Col28	23	0.00	1.15
Col28	24	0.00	1.15
Col28	25	0.00	1.15
Col28	26	0.00	1.15
Col28	27	0.00	1.15
Col28	28	0.00	1.15
Col28	29	0.00	1.15
Col28	30	0.00	1.15
Col28	31	0.00	1.15
Col28	32	0.00	1.15
Col28	33	0.00	1.15
Col28	34	0.00	1.15
Col28	35	0.00	1.15
Col28	36	0.00	1.15
Col28	37	0.00	1.15
Col28	38	0.00	1.15
Col28	39	0.00	1.15
Col28	40	0.00	1.15
Col28	41	0.00	1.15
Col28	42	0.00	1.15
Col28	43	0.00	1.15
Col28	44	0.00	1.15
Col28	45	0.00	1.15
Col28	46	0.00	1.15
Col28	47	0.00	1.15
Col28	48	0.00	1.15
Col28	49	0.00	1.15
Col28	50	0.00	1.15
Col28	51	0.00	1.15

Col28	52	0.00	1.15
Col29	1	0.00	1.14
Col29	2	0.00	1.14
Col29	3	0.00	1.14
Col29	4	0.00	1.14
Col29	5	0.00	1.14
Col29	6	0.00	1.14
Col29	7	0.00	1.14
Col29	8	-0.89	1.14
Col29	9	-0.89	1.14
Col29	10	0.98	1.14
Col29	11	0.98	1.14
Col29	12	0.98	1.14
Col29	13	0.98	1.14
Col29	14	0.98	1.14
Col29	15	0.98	1.14
Col29	16	0.73	1.14
Col29	17	0.73	1.14
Col29	18	0.73	1.14
Col29	19	0.73	1.14
Col29	20	0.73	1.14
Col29	21	0.73	1.14
Col29	22	0.73	1.14
Col29	23	0.73	1.14
Col29	24	0.73	1.14
Col29	25	0.73	1.14
Col29	26	0.73	1.14
Col29	27	0.73	1.14
Col29	28	-0.89	1.14
Col29	29	-0.89	1.14
Col29	30	0.98	1.14
Col29	31	0.98	1.14
Col29	32	0.98	1.14
Col29	33	0.98	1.14
Col29	34	0.98	1.14
Col29	35	0.98	1.14
Col29	36	0.00	1.14
Col29	37	0.00	1.14
Col29	38	0.00	1.14
Col29	39	0.00	1.14
Col29	40	0.00	1.14
Col29	41	0.00	1.14
Col29	42	0.00	1.14
Col29	43	0.00	1.14
Col29	44	0.00	1.14
Col29	45	0.00	1.14
Col29	46	0.00	1.14
Col29	47	0.44	1.14
Col29	48	0.44	1.14
Col29	49	0.00	1.14
Col29	50	0.00	1.14
Col29	51	0.73	1.14
Col29	52	0.00	1.14
Col30	1	0.00	1.13
Col30	2	0.00	1.13
Col30	3	0.00	1.13
Col30	4	0.00	1.13
Col30	5	0.00	1.13
Col30	6	0.00	1.13
Col30	7	0.00	1.13
Col30	8	-0.85	1.13
Col30	9	-0.85	1.13
Col30	10	0.93	1.13
Col30	11	0.93	1.13
Col30	12	0.93	1.13

Col30	13	0.93	1.13
Col30	14	0.93	1.13
Col30	15	0.93	1.13
Col30	16	0.70	1.13
Col30	17	0.70	1.13
Col30	18	0.70	1.13
Col30	19	0.70	1.13
Col30	20	0.70	1.13
Col30	21	0.70	1.13
Col30	22	0.70	1.13
Col30	23	0.70	1.13
Col30	24	0.70	1.13
Col30	25	0.70	1.13
Col30	26	0.70	1.13
Col30	27	0.70	1.13
Col30	28	-0.85	1.13
Col30	29	-0.85	1.13
Col30	30	0.93	1.13
Col30	31	0.93	1.13
Col30	32	0.93	1.13
Col30	33	0.93	1.13
Col30	34	0.93	1.13
Col30	35	0.93	1.13
Col30	36	0.00	1.13
Col30	37	0.00	1.13
Col30	38	0.00	1.13
Col30	39	0.00	1.13
Col30	40	0.00	1.13
Col30	41	0.00	1.13
Col30	42	0.00	1.13
Col30	43	0.00	1.13
Col30	44	0.00	1.13
Col30	45	0.00	1.13
Col30	46	0.00	1.13
Col30	47	0.42	1.13
Col30	48	0.42	1.13
Col30	49	0.00	1.13
Col30	50	0.00	1.13
Col30	51	0.70	1.13
Col30	52	0.00	1.13
Col31	1	0.00	1.12
Col31	2	0.00	1.12
Col31	3	0.00	1.12
Col31	4	0.00	1.12
Col31	5	0.00	1.12
Col31	6	0.00	1.12
Col31	7	0.00	1.12
Col31	8	-0.81	1.12
Col31	9	-0.81	1.12
Col31	10	0.89	1.12
Col31	11	0.89	1.12
Col31	12	0.89	1.12
Col31	13	0.89	1.12
Col31	14	0.89	1.12
Col31	15	0.89	1.12
Col31	16	0.67	1.12
Col31	17	0.67	1.12
Col31	18	0.67	1.12
Col31	19	0.67	1.12
Col31	20	0.67	1.12
Col31	21	0.67	1.12
Col31	22	0.67	1.12
Col31	23	0.67	1.12
Col31	24	0.67	1.12
Col31	25	0.67	1.12

Col131	26	0.67	1.12
Col131	27	0.67	1.12
Col131	28	-0.81	1.12
Col131	29	-0.81	1.12
Col131	30	0.89	1.12
Col131	31	0.89	1.12
Col131	32	0.89	1.12
Col131	33	0.89	1.12
Col131	34	0.89	1.12
Col131	35	0.89	1.12
Col131	36	0.00	1.12
Col131	37	0.00	1.12
Col131	38	0.00	1.12
Col131	39	0.00	1.12
Col131	40	0.00	1.12
Col131	41	0.00	1.12
Col131	42	0.00	1.12
Col131	43	0.00	1.12
Col131	44	0.00	1.12
Col131	45	0.00	1.12
Col131	46	0.00	1.12
Col131	47	0.40	1.12
Col131	48	0.40	1.12
Col131	49	0.00	1.12
Col131	50	0.00	1.12
Col131	51	0.67	1.12
Col131	52	0.00	1.12
Col132	1	0.00	1.10
Col132	2	0.00	1.10
Col132	3	0.00	1.10
Col132	4	0.00	1.10
Col132	5	0.00	1.10
Col132	6	0.00	1.10
Col132	7	0.00	1.10
Col132	8	-0.77	1.10
Col132	9	-0.77	1.10
Col132	10	0.84	1.10
Col132	11	0.84	1.10
Col132	12	0.84	1.10
Col132	13	0.84	1.10
Col132	14	0.84	1.10
Col132	15	0.84	1.10
Col132	16	0.63	1.10
Col132	17	0.63	1.10
Col132	18	0.63	1.10
Col132	19	0.63	1.10
Col132	20	0.63	1.10
Col132	21	0.63	1.10
Col132	22	0.63	1.10
Col132	23	0.63	1.10
Col132	24	0.63	1.10
Col132	25	0.63	1.10
Col132	26	0.63	1.10
Col132	27	0.63	1.10
Col132	28	-0.77	1.10
Col132	29	-0.77	1.10
Col132	30	0.84	1.10
Col132	31	0.84	1.10
Col132	32	0.84	1.10
Col132	33	0.84	1.10
Col132	34	0.84	1.10
Col132	35	0.84	1.10
Col132	36	0.00	1.10
Col132	37	0.00	1.10
Col132	38	0.00	1.10

Col32	39	0.00	1.10
Col32	40	0.00	1.10
Col32	41	0.00	1.10
Col32	42	0.00	1.10
Col32	43	0.00	1.10
Col32	44	0.00	1.10
Col32	45	0.00	1.10
Col32	46	0.00	1.10
Col32	47	0.38	1.10
Col32	48	0.38	1.10
Col32	49	0.00	1.10
Col32	50	0.00	1.10
Col32	51	0.63	1.10
Col32	52	0.00	1.10
Col33	1	0.00	1.09
Col33	2	0.00	1.09
Col33	3	0.00	1.09
Col33	4	0.00	1.09
Col33	5	0.00	1.09
Col33	6	0.00	1.09
Col33	7	0.00	1.09
Col33	8	-0.73	1.09
Col33	9	-0.73	1.09
Col33	10	0.85	1.09
Col33	11	0.85	1.09
Col33	12	0.85	1.09
Col33	13	0.85	1.09
Col33	14	0.85	1.09
Col33	15	0.85	1.09
Col33	16	0.64	1.09
Col33	17	0.64	1.09
Col33	18	0.64	1.09
Col33	19	0.64	1.09
Col33	20	0.64	1.09
Col33	21	0.64	1.09
Col33	22	0.64	1.09
Col33	23	0.64	1.09
Col33	24	0.64	1.09
Col33	25	0.64	1.09
Col33	26	0.64	1.09
Col33	27	0.64	1.09
Col33	28	-0.73	1.09
Col33	29	-0.73	1.09
Col33	30	0.85	1.09
Col33	31	0.85	1.09
Col33	32	0.85	1.09
Col33	33	0.85	1.09
Col33	34	0.85	1.09
Col33	35	0.85	1.09
Col33	36	0.00	1.09
Col33	37	0.00	1.09
Col33	38	0.00	1.09
Col33	39	0.00	1.09
Col33	40	0.00	1.09
Col33	41	0.00	1.09
Col33	42	0.00	1.09
Col33	43	0.00	1.09
Col33	44	0.00	1.09
Col33	45	0.00	1.09
Col33	46	0.00	1.09
Col33	47	0.38	1.09
Col33	48	0.38	1.09
Col33	49	0.00	1.09
Col33	50	0.00	1.09
Col33	51	0.64	1.09

Col33 52 0.00 1.09

COLUMN KL/R RATIO, MOMENT REDUCTION:

Id	Major (ft)	--Minor (ft)--		----KL/R----		Available Reduction Factor	
		Bend	Axial	Major	Minor	Out	In
Col22	16.1	4.1	4.1	84	66	0.00	0.00
Col23	16.3	4.3	4.3	85	70	0.00	0.00
Col24	16.5	4.5	4.5	86	73	0.00	0.00
Col25	16.8	4.8	4.8	87	77	0.00	0.00
Col26	17.0	5.0	5.0	88	80	0.00	0.00
Col27	17.2	5.2	5.2	89	83	0.00	0.00
Col28	0.1	5.3	5.3	1	85	0.00	0.00
Col29	17.2	5.2	5.2	89	83	0.00	0.00
Col30	17.0	5.0	5.0	88	80	0.00	0.00
Col31	16.7	4.7	4.7	87	77	0.00	0.00
Col32	16.5	4.5	4.5	86	73	0.00	0.00
Col33	16.3	4.3	4.3	85	70	0.00	0.00

GIRT LAYOUT:

Bay Id	Girt Id	Locate	Part	Design Length	Available Reduction Factor	
					Out	In
1	1	4.000	6X2C16	4.500	0.00	0.70
	2	8.000	6X2C16	4.500	0.00	0.70
	3	12.000	6X2C16	4.500	0.00	0.70
2	1	4.000	6X2C16	4.500	0.00	0.70
	2	8.000	6X2C16	4.500	0.00	0.70
	3	12.000	6X2C16	4.500	0.00	0.70
3	1	4.000	6X2C16	4.500	0.00	0.70
	2	8.000	6X2C16	4.500	0.00	0.70
	3	12.000	6X2C16	4.500	0.00	0.70
4	1	4.000	6X2C16	4.500	0.00	0.70
	2	8.000	6X2C16	4.500	0.00	0.70
	3	12.000	6X2C16	4.500	0.00	0.70
5	1	4.000	6X2C16	4.500	0.00	0.70
	2	8.000	6X2C16	4.500	0.00	0.70
	3	12.000	6X2C16	4.500	0.00	0.70
6	1	4.000	6X2C16	4.500	0.00	0.70
	2	8.000	6X2C16	4.500	0.00	0.70
	3	12.000	6X2C16	4.500	0.00	0.70
7	1	4.000	6X2C16	4.500	0.00	0.70
	2	8.000	6X2C16	4.500	0.00	0.70
	3	12.000	6X2C16	4.500	0.00	0.70
8	1	4.000	6X2C16	4.500	0.00	0.70
	2	8.000	6X2C16	4.500	0.00	0.70
	3	12.000	6X2C16	4.500	0.00	0.70
9	1	4.000	6X2C16	4.500	0.00	0.70
	2	8.000	6X2C16	4.500	0.00	0.70
	3	12.000	6X2C16	4.500	0.00	0.70
10	1	4.000	6X2C16	4.500	0.00	0.70
	2	8.000	6X2C16	4.500	0.00	0.70
	3	12.000	6X2C16	4.500	0.00	0.70
11	1	4.000	6X2C16	4.500	0.00	0.70
	2	8.000	6X2C16	4.500	0.00	0.70
	3	12.000	6X2C16	4.500	0.00	0.70
12	1	4.000	6X2C16	4.500	0.00	0.70
	2	8.000	6X2C16	4.500	0.00	0.70
	3	12.000	6X2C16	4.500	0.00	0.70
13	1	4.000	6X2C16	4.625	0.00	0.70
	2	8.000	6X2C16	4.625	0.00	0.70
	3	12.000	6X2C16	4.625	0.00	0.70

GIRT ACTIONS:

Bay Id	Girt Id	Load	-Shear(k)-		Moment(f-k)		Max UC	Deflect(in)	
			Calc	Limit	Calc	Limit		Calc	Limit
1	1	WP	-0.09	3.32	-0.10	2.65	0.04	0.00	0.60
		WS	0.11	3.32	0.12	2.65	0.05	0.00	0.60
2	1	WP	-0.09	3.32	-0.10	2.65	0.04	0.00	0.60
		WS	0.10	3.32	0.11	2.65	0.04	0.00	0.60
	3	WP	-0.09	3.32	-0.10	2.65	0.04	0.00	0.60
		WS	0.10	3.32	0.12	2.65	0.04	0.00	0.60
3	1	WP	-0.09	3.32	-0.10	2.65	0.04	0.00	0.60
		WS	0.10	3.32	0.11	2.65	0.04	0.00	0.60
	3	WP	-0.09	3.32	-0.11	2.65	0.04	0.00	0.60
		WS	0.10	3.32	0.12	2.65	0.04	0.00	0.60
4	1	WP	-0.09	3.32	-0.10	2.65	0.04	0.00	0.60

		WS	0.10	3.32	0.11	2.65	0.04	0.00	0.60
	3	WP	-0.10	3.32	-0.11	2.65	0.04	0.00	0.60
		WS	0.11	3.32	0.12	2.65	0.05	0.00	0.60
5	1	WP	-0.09	3.32	-0.10	2.65	0.04	0.00	0.60
		WS	0.10	3.32	0.11	2.65	0.04	0.00	0.60
	3	WP	-0.10	3.32	-0.11	2.65	0.04	0.00	0.60
		WS	0.11	3.32	0.12	2.65	0.05	0.00	0.60
6	1	WP	-0.09	3.32	-0.10	2.65	0.04	0.00	0.60
		WS	0.10	3.32	0.11	2.65	0.04	0.00	0.60
	3	WP	-0.10	3.32	-0.11	2.65	0.04	0.00	0.60
		WS	0.11	3.32	0.13	2.65	0.05	0.00	0.60
7	1	WP	-0.09	3.32	-0.10	2.65	0.04	0.00	0.60
		WS	0.10	3.32	0.11	2.65	0.04	0.00	0.60
	3	WP	-0.10	3.32	-0.12	2.65	0.04	0.00	0.60
		WS	0.11	3.32	0.13	2.65	0.05	0.00	0.60
8	1	WP	-0.09	3.32	-0.10	2.65	0.04	0.00	0.60
		WS	0.10	3.32	0.11	2.65	0.04	0.00	0.60
	3	WP	-0.10	3.32	-0.12	2.65	0.04	0.00	0.60
		WS	0.11	3.32	0.13	2.65	0.05	0.00	0.60
9	1	WP	-0.09	3.32	-0.10	2.65	0.04	0.00	0.60
		WS	0.10	3.32	0.11	2.65	0.04	0.00	0.60
	3	WP	-0.10	3.32	-0.11	2.65	0.04	0.00	0.60
		WS	0.11	3.32	0.13	2.65	0.05	0.00	0.60
10	1	WP	-0.09	3.32	-0.10	2.65	0.04	0.00	0.60
		WS	0.10	3.32	0.11	2.65	0.04	0.00	0.60
	3	WP	-0.10	3.32	-0.11	2.65	0.04	0.00	0.60
		WS	0.11	3.32	0.12	2.65	0.05	0.00	0.60
11	1	WP	-0.09	3.32	-0.10	2.65	0.04	0.00	0.60
		WS	0.10	3.32	0.11	2.65	0.04	0.00	0.60
	3	WP	-0.10	3.32	-0.11	2.65	0.04	0.00	0.60
		WS	0.11	3.32	0.12	2.65	0.05	0.00	0.60
12	1	WP	-0.09	3.32	-0.10	2.65	0.04	0.00	0.60
		WS	0.10	3.32	0.11	2.65	0.04	0.00	0.60
	3	WP	-0.09	3.32	-0.11	2.65	0.04	0.00	0.60
		WS	0.11	3.32	0.12	2.65	0.05	0.00	0.60
13	1	WP	-0.09	3.32	-0.11	2.65	0.04	0.00	0.62
		WS	0.11	3.32	0.13	2.65	0.05	0.00	0.62

WP - Wind_Pressure

WS - Wind_Suction

PANEL DATA:

Table with 5 columns: Bay, Part, Type, Gage, Yield. Row 1: 7, CUSPANL, CP, 20.00, 50.0

MOMENTS & DEFLECTION:

Table with 13 columns: Span Id, Locate (ft) Start, End, Load, Moment (ft-lb/ft) Calc, Limit, Deflect (in) Calc, Limit. Includes legend: WP - Wind_Pressure, WS - Wind_Suction

PANEL:

Part	Thick (in)	Yield (ksi)	Tensile Strength (ksi)
CUSPANL	0.038	50.00	65.00

GIRT SCREWS:

Part	Dia (in)	Washer (in)	Limit (k)
#29	0.21	0.50	2.90

PANEL ZONE LAYOUT:

Zone		----Wall (ft)----		Bay		--Girt (ft,ft,in)--			Panel
Id	Description	Offset1	Offset2	Id	Locate	Load	Min	Thick	Span
		Offset1	Offset2	Id	Locate	Width	Thick		(ft)
1	Interior	6.43	58.57	7	12.00	4.59	0.059		4.14
2	Lt Edge	0.00	6.43	1	4.00	4.00	0.059		4.00
3	Rt Edge	58.57	65.00	13	12.00	4.07	0.059		4.14

GIRT SCREW CHECK:

Zone		Wind		-----Limit(k)-----				
Id	Screw	Suction	Load	Girt	Panel	Screw	Max	
	Space	(psf)	(k)	Pullout	Pullover	Tension	UC	
1	1.00	16.62	0.08	0.22	0.61	0.77	0.35	
2	1.00	16.62	0.07	0.22	0.61	0.77	0.30	
3	1.00	16.62	0.07	0.22	0.61	0.77	0.31	

11 12	Back SW - Column & Rafter Design	8/25/22 2:32pm
-------	----------------------------------	----------------

WALL LAYOUT:

Wall Id	Orn	Load Width
4	L	2.50

MEMBER LAYOUT:

Id	Locate		---Web(in)---		-Flange(in)-		Length (ft)	Weight (lb)	----Max_Load----		
	(ft)	Part	Depth	Thick	Width	Thick			Id	UC	Report
Col35	0.0	6X2C16	6.00	16ga	2.00	16ga	16.1	35.2	17	0.09	Mom+Axl
Col36	14.0	6X2C16	6.00	16ga	2.00	16ga	16.1	35.2	1	0.08	Mom+Axl
Col37	28.0	6X2C16	6.00	16ga	2.00	16ga	16.1	35.2	1	0.08	Mom+Axl
Col38	42.0	6X2C16	6.00	16ga	2.00	16ga	16.1	35.2	1	0.08	Mom+Axl
Col39	56.0	6X2C16	6.00	16ga	2.00	16ga	16.1	35.2	1	0.08	Mom+Axl
Col40	70.0	6X2C16	6.00	16ga	2.00	16ga	16.1	35.2	17	0.09	Mom+Axl
Raf4		PB6EC	6.13	16ga	2.06	16ga	14.0	29.4			
Raf5		PB6EC	6.13	16ga	2.06	16ga	28.0	58.8			
Raf6		PB6EC	6.13	16ga	2.06	16ga	28.0	58.8			
Total=								358.3			

DESIGN ACTIONS/STRENGTH:

								-----Unity_Check-----			
Id	Load Id	-Axial(k)-		-Shear(k)-		Moment(f-k)		Axial	Shear	Axial+	Shear+
		Calc	Limit	Calc	Limit	Calc	Limit			Moment	Moment
Col35	1	0.44	7.71	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col35	2	0.09	7.71	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col35	3	0.33	7.71	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col35	4	0.33	7.71	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col35	5	0.36	7.71	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col35	6	0.27	7.71	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col35	7	0.27	7.71	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col35	8	-0.14	21.18	0.04	3.32	-0.16	2.65	0.01	0.01	0.05	0.00
Col35	9	-0.05	21.18	0.04	3.32	-0.16	2.65	0.00	0.01	0.06	0.00
Col35	10	-0.14	21.18	-0.05	3.32	0.19	2.65	0.01	0.01	0.07	0.00
Col35	11	-0.05	21.18	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00
Col35	12	-0.14	21.18	-0.05	3.32	0.19	2.65	0.01	0.01	0.07	0.00
Col35	13	-0.05	21.18	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00
Col35	14	-0.07	21.18	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00
Col35	15	0.02	7.71	-0.05	3.32	0.19	2.65	0.00	0.01	0.08	0.00
Col35	16	0.24	7.71	-0.04	3.32	0.14	2.65	0.03	0.01	0.09	0.00
Col35	17	0.31	7.71	-0.04	3.32	0.14	2.65	0.04	0.01	0.09	0.00
Col35	18	0.18	7.71	-0.04	3.32	0.14	2.65	0.02	0.01	0.08	0.00
Col35	19	0.26	7.71	-0.04	3.32	0.14	2.65	0.03	0.01	0.09	0.00
Col35	20	0.15	7.71	-0.04	3.32	0.14	2.65	0.02	0.01	0.07	0.00
Col35	21	0.22	7.71	-0.04	3.32	0.14	2.65	0.03	0.01	0.08	0.00
Col35	22	0.10	7.71	-0.04	3.32	0.14	2.65	0.01	0.01	0.07	0.00
Col35	23	0.17	7.71	-0.04	3.32	0.14	2.65	0.02	0.01	0.08	0.00
Col35	24	0.15	7.71	-0.04	3.32	0.14	2.65	0.02	0.01	0.07	0.00
Col35	25	0.22	7.71	-0.04	3.32	0.14	2.65	0.03	0.01	0.08	0.00
Col35	26	0.10	7.71	-0.04	3.32	0.14	2.65	0.01	0.01	0.07	0.00
Col35	27	0.17	7.71	-0.04	3.32	0.14	2.65	0.02	0.01	0.08	0.00
Col35	28	-0.16	21.18	0.04	3.32	-0.16	2.65	0.01	0.01	0.05	0.00
Col35	29	-0.06	21.18	0.04	3.32	-0.16	2.65	0.00	0.01	0.06	0.00
Col35	30	-0.16	21.18	-0.05	3.32	0.19	2.65	0.01	0.01	0.07	0.00
Col35	31	-0.06	21.18	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00

Col135	32	-0.16	21.18	-0.05	3.32	0.19	2.65	0.01	0.01	0.07	0.00
Col135	33	-0.06	21.18	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00
Col135	34	-0.09	21.18	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00
Col135	35	0.01	7.71	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00
Col135	36	0.09	7.71	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col135	37	0.09	7.71	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col135	38	0.36	7.71	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col135	39	0.36	7.71	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col135	40	0.27	7.71	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col135	41	0.27	7.71	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col135	42	0.27	7.71	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col135	43	0.27	7.71	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col135	44	0.07	7.71	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col135	45	0.07	7.71	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col135	46	0.37	7.71	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col135	47	0.19	7.71	-0.04	3.32	0.14	2.65	0.02	0.01	0.08	0.00
Col135	48	0.26	7.71	-0.04	3.32	0.14	2.65	0.03	0.01	0.09	0.00
Col135	49	0.09	7.71	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col135	50	0.09	7.71	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col135	51	0.07	7.71	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col135	52	0.07	7.71	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col135	53	0.33	7.71	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col135	54	0.27	7.71	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col135	55	0.27	7.71	-0.04	3.32	0.14	2.65	0.04	0.01	0.09	0.00
Col135	56	0.27	7.71	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col136	1	0.85	10.37	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col136	2	0.15	10.37	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col136	3	0.62	10.37	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col136	4	0.62	10.37	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col136	5	0.68	10.37	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col136	6	0.50	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col136	7	0.50	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col136	8	-0.33	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col136	9	-0.13	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col136	10	-0.33	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col136	11	-0.13	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col136	12	-0.33	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col136	13	-0.13	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col136	14	-0.18	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col136	15	0.01	10.37	0.00	3.32	0.00	2.65	0.00	0.00	0.00	0.00
Col136	16	0.44	10.37	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col136	17	0.59	10.37	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col136	18	0.33	10.37	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col136	19	0.48	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col136	20	0.27	10.37	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col136	21	0.41	10.37	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col136	22	0.16	10.37	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col136	23	0.30	10.37	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col136	24	0.27	10.37	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col136	25	0.41	10.37	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col136	26	0.16	10.37	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col136	27	0.30	10.37	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col136	28	-0.35	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col136	29	-0.16	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col136	30	-0.35	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col136	31	-0.16	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col136	32	-0.35	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col136	33	-0.16	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col136	34	-0.21	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col136	35	-0.01	21.18	0.00	3.32	0.00	2.65	0.00	0.00	0.00	0.00
Col136	36	0.15	10.37	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col136	37	0.15	10.37	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col136	38	0.68	10.37	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col136	39	0.68	10.37	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col136	40	0.51	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00

Col36	41	0.51	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col36	42	0.51	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col36	43	0.51	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col36	44	0.10	10.37	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col36	45	0.10	10.37	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col36	46	0.71	10.37	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col36	47	0.34	10.37	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col36	48	0.48	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col36	49	0.15	10.37	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col36	50	0.15	10.37	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col36	51	0.11	10.37	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col36	52	0.11	10.37	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col36	53	0.62	10.37	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col36	54	0.50	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col36	55	0.50	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col36	56	0.51	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col37	1	0.85	10.37	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col37	2	0.15	10.37	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col37	3	0.62	10.37	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col37	4	0.62	10.37	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col37	5	0.68	10.37	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col37	6	0.50	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col37	7	0.50	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col37	8	-0.33	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col37	9	-0.13	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col37	10	-0.33	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col37	11	-0.13	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col37	12	-0.33	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col37	13	-0.13	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col37	14	-0.18	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col37	15	0.01	10.37	0.00	3.32	0.00	2.65	0.00	0.00	0.00	0.00
Col37	16	0.44	10.37	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col37	17	0.59	10.37	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col37	18	0.33	10.37	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col37	19	0.48	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col37	20	0.27	10.37	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col37	21	0.41	10.37	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col37	22	0.16	10.37								

Col137	50	0.15	10.37	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col137	51	0.11	10.37	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col137	52	0.11	10.37	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col137	53	0.62	10.37	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col137	54	0.50	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col137	55	0.50	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col137	56	0.51	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col138	1	0.85	10.37	0.00	3.32	0.00	2.65	0.08	0.00	0.08	0.00
Col138	2	0.15	10.37	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col138	3	0.62	10.37	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col138	4	0.62	10.37	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col138	5	0.68	10.37	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col138	6	0.50	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col138	7	0.50	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col138	8	-0.33	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col138	9	-0.13	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col138	10	-0.33	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col138	11	-0.13	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col138	12	-0.33	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col138	13	-0.13	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col138	14	-0.18	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col138	15	0.01	10.37	0.00	3.32	0.00	2.65	0.00	0.00	0.00	0.00
Col138	16	0.44	10.37	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col138	17	0.59	10.37	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col138	18	0.33	10.37	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col138	19	0.48	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col138	20	0.27	10.37	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col138	21	0.41	10.37	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col138	22	0.16	10.37	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col138	23	0.30	10.37	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col138	24	0.27	10.37	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col138	25	0.41	10.37	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col138	26	0.16	10.37	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col138	27	0.30	10.37	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col138	28	-0.35	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col138	29	-0.16	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col138	30	-0.35	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00</

Col139	3	0.62	10.37	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col139	4	0.62	10.37	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col139	5	0.68	10.37	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col139	6	0.50	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col139	7	0.50	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col139	8	-0.33	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col139	9	-0.13	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col139	10	-0.33	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col139	11	-0.13	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col139	12	-0.33	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col139	13	-0.13	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col139	14	-0.18	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col139	15	0.01	10.37	0.00	3.32	0.00	2.65	0.00	0.00	0.00	0.00
Col139	16	0.44	10.37	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col139	17	0.59	10.37	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col139	18	0.33	10.37	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col139	19	0.48	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col139	20	0.27	10.37	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col139	21	0.41	10.37	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col139	22	0.16	10.37	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col139	23	0.30	10.37	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col139	24	0.27	10.37	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col139	25	0.41	10.37	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col139	26	0.16	10.37	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col139	27	0.30	10.37	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col139	28	-0.35	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col139	29	-0.16	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col139	30	-0.35	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col139	31	-0.16	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col139	32	-0.35	21.18	0.00	3.32	0.00	2.65	0.02	0.00	0.02	0.00
Col139	33	-0.16	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col139	34	-0.21	21.18	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col139	35	-0.01	21.18	0.00	3.32	0.00	2.65	0.00	0.00	0.00	0.00
Col139	36	0.15	10.37	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col139	37	0.15	10.37	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col139	38	0.68	10.37	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col139	39	0.68	10.37	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col139	40	0.51	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col139	41	0.51	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col139	42	0.51	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col139	43	0.51	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col139	44	0.10	10.37	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col139	45	0.10	10.37	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col139	46	0.71	10.37	0.00	3.32	0.00	2.65	0.07	0.00	0.07	0.00
Col139	47	0.34	10.37	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col139	48	0.48	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col139	49	0.15	10.37	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col139	50	0.15	10.37	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col139	51	0.11	10.37	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col139	52	0.11	10.37	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col139	53	0.62	10.37	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col139	54	0.50	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col139	55	0.50	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col139	56	0.51	10.37	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col140	1	0.44	7.71	0.00	3.32	0.00	2.65	0.06	0.00	0.06	0.00
Col140	2	0.09	7.71	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col140	3	0.33	7.71	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col140	4	0.33	7.71	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col140	5	0.36	7.71	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col140	6	0.27	7.71	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col140	7	0.27	7.71	0.00	3.32	0.00	2.65	0.03	0.00	0.03	0.00
Col140	8	-0.14	21.18	0.04	3.32	-0.16	2.65	0.01	0.01	0.05	0.00
Col140	9	-0.05	21.18	0.04	3.32	-0.16	2.65	0.00	0.01	0.06	0.00
Col140	10	-0.14	21.18	-0.05	3.32	0.19	2.65	0.01	0.01	0.07	0.00
Col140	11	-0.05	21.18	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00

Col40	12	-0.14	21.18	-0.05	3.32	0.19	2.65	0.01	0.01	0.07	0.00
Col40	13	-0.05	21.18	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00
Col40	14	-0.07	21.18	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00
Col40	15	0.02	7.71	-0.05	3.32	0.19	2.65	0.00	0.01	0.08	0.00
Col40	16	0.24	7.71	-0.04	3.32	0.14	2.65	0.03	0.01	0.09	0.00
Col40	17	0.31	7.71	-0.04	3.32	0.14	2.65	0.04	0.01	0.09	0.00
Col40	18	0.18	7.71	-0.04	3.32	0.14	2.65	0.02	0.01	0.08	0.00
Col40	19	0.26	7.71	-0.04	3.32	0.14	2.65	0.03	0.01	0.09	0.00
Col40	20	0.15	7.71	-0.04	3.32	0.14	2.65	0.02	0.01	0.07	0.00
Col40	21	0.22	7.71	-0.04	3.32	0.14	2.65	0.03	0.01	0.08	0.00
Col40	22	0.10	7.71	-0.04	3.32	0.14	2.65	0.01	0.01	0.07	0.00
Col40	23	0.17	7.71	-0.04	3.32	0.14	2.65	0.02	0.01	0.08	0.00
Col40	24	0.15	7.71	-0.04	3.32	0.14	2.65	0.02	0.01	0.07	0.00
Col40	25	0.22	7.71	-0.04	3.32	0.14	2.65	0.03	0.01	0.08	0.00
Col40	26	0.10	7.71	-0.04	3.32	0.14	2.65	0.01	0.01	0.07	0.00
Col40	27	0.17	7.71	-0.04	3.32	0.14	2.65	0.02	0.01	0.08	0.00
Col40	28	-0.16	21.18	0.04	3.32	-0.16	2.65	0.01	0.01	0.05	0.00
Col40	29	-0.06	21.18	0.04	3.32	-0.16	2.65	0.00	0.01	0.06	0.00
Col40	30	-0.16	21.18	-0.05	3.32	0.19	2.65	0.01	0.01	0.07	0.00
Col40	31	-0.06	21.18	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00
Col40	32	-0.16	21.18	-0.05	3.32	0.19	2.65	0.01	0.01	0.07	0.00
Col40	33	-0.06	21.18	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00
Col40	34	-0.09	21.18	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00
Col40	35	0.01	7.71	-0.05	3.32	0.19	2.65	0.00	0.01	0.07	0.00
Col40	36	0.09	7.71	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col40	37	0.09	7.71	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col40	38	0.36	7.71	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col40	39	0.36	7.71	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col40	40	0.27	7.71	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col40	41	0.27	7.71	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col40	42	0.27	7.71	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col40	43	0.27	7.71	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col40	44	0.07	7.71	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col40	45	0.07	7.71	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col40	46	0.37	7.71	0.00	3.32	0.00	2.65	0.05	0.00	0.05	0.00
Col40	47	0.19	7.71	-0.04	3.32	0.14	2.65	0.02	0.01	0.08	0.00
Col40	48	0.26	7.71	-0.04	3.32	0.14	2.65	0.03	0.01	0.09	0.00
Col40	49	0.09	7.71	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col40	50	0.09	7.71	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col40	51	0.07	7.71	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col40	52	0.07	7.71	0.00	3.32	0.00	2.65	0.01	0.00	0.01	0.00
Col40	53	0.33	7.71	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col40	54	0.27	7.71	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00
Col40	55	0.27	7.71	-0.04	3.32	0.14	2.65	0.04	0.01	0.09	0.00
Col40	56	0.27	7.71	0.00	3.32	0.00	2.65	0.04	0.00	0.04	0.00

Raf4	1	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf4	2	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf4	3	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf4	4	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf4	5	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf4	6	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf4	7	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf4	8	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf4	9	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf4	10	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf4	11	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf4	12	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf4	13	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf4	14	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf4	15	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf4	16	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf4	17	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf4	18	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf4	19	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00

[illegible]

[illegible]

Raf6	38	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf6	39	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf6	40	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf6	41	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf6	42	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf6	43	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf6	44	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf6	45	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf6	46	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf6	47	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf6	48	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf6	49	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf6	50	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf6	51	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf6	52	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf6	53	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf6	54	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf6	55	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00
Raf6	56	0.00	5.27	0.00	3.77	0.00	1.71	0.00	0.00	0.00	0.00

COLUMN REACTIONS:

Id	Load		In_Plane		Out_Plane
	Id	Vert(k)	Horz(k)	Horz(k)	
-----	-----	-----	-----	-----	
Col35	1	0.44	0.00	0.00	
Col35	2	0.09	0.00	0.00	
Col35	3	0.33	0.00	0.00	
Col35	4	0.33	0.00	0.00	
Col35	5	0.36	0.00	0.00	
Col35	6	0.27	0.00	0.00	
Col35	7	0.27	0.00	0.00	
Col35	8	-0.14	0.00	-0.04	
Col35	9	-0.05	0.00	-0.04	
Col35	10	-0.14	0.00	0.05	
Col35	11	-0.05	0.00	0.05	
Col35	12	-0.14	0.00	0.05	
Col35	13	-0.05	0.00	0.05	
Col35	14	-0.07	0.00	0.05	
Col35	15	0.02	0.00	0.05	
Col35	16	0.24	0.00	0.04	
Col35	17	0.31	0.00	0.04	
Col35	18	0.18	0.00	0.04	
Col35	19	0.26	0.00	0.04	
Col35	20	0.15	0.00	0.04	
Col35	21	0.22	0.00	0.04	
Col35	22	0.10	0.00	0.04	
Col35	23	0.17	0.00	0.04	
Col35	24	0.15	0.00	0.04	
Col35	25	0.22	0.00	0.04	
Col35	26	0.10	0.00	0.04	
Col35	27	0.17	0.00	0.04	
Col35	28	-0.16	0.00	-0.04	
Col35	29	-0.06	0.00	-0.04	
Col35	30	-0.16	0.00	0.05	
Col35	31	-0.06	0.00	0.05	
Col35	32	-0.16	0.00	0.05	
Col35	33	-0.06	0.00	0.05	
Col35	34	-0.09	0.00	0.05	
Col35	35	0.01	0.00	0.05	
Col35	36	0.09	0.00	0.00	
Col35	37	0.09	0.00	0.00	
Col35	38	0.36	0.00	0.00	
Col35	39	0.36	0.00	0.00	
Col35	40	0.27	0.00	0.00	

Col135	41	0.27	0.00	0.00
Col135	42	0.27	0.00	0.00
Col135	43	0.27	0.00	0.00
Col135	44	0.07	0.00	0.00
Col135	45	0.07	0.00	0.00
Col135	46	0.37	0.00	0.00
Col135	47	0.19	0.00	0.04
Col135	48	0.26	0.00	0.04
Col135	49	0.09	0.00	0.00
Col135	50	0.09	0.00	0.00
Col135	51	0.07	0.00	0.00
Col135	52	0.07	0.00	0.00
Col135	53	0.33	0.00	0.00
Col135	54	0.27	0.00	0.00
Col135	55	0.27	0.00	0.04
Col135	56	0.27	0.00	0.00
Col136	1	0.85	0.00	0.00
Col136	2	0.15	0.00	0.00
Col136	3	0.62	0.00	0.00
Col136	4	0.62	0.00	0.00
Col136	5	0.68	0.00	0.00
Col136	6	0.50	0.00	0.00
Col136	7	0.50	0.00	0.00
Col136	8	-0.33	0.00	0.00
Col136	9	-0.13	0.00	0.00
Col136	10	-0.33	0.00	0.00
Col136	11	-0.13	0.00	0.00
Col136	12	-0.33	0.00	0.00
Col136	13	-0.13	0.00	0.00
Col136	14	-0.18	0.00	0.00
Col136	15	0.01	0.00	0.00
Col136	16	0.44	0.00	0.00
Col136	17	0.59	0.00	0.00
Col136	18	0.33	0.00	0.00
Col136	19	0.48	0.00	0.00
Col136	20	0.27	0.00	0.00
Col136	21	0.41	0.00	0.00
Col136	22	0.16	0.00	0.00
Col136	23	0.30	0.00	0.00
Col136	24	0.27	0.00	0.00
Col136	25	0.41	0.00	0.00
Col136	26	0.16	0.00	0.00
Col136	27	0.30	0.00	0.00
Col136	28	-0.35	0.00	0.00
Col136	29	-0.16	0.00	0.00
Col136	30	-0.35	0.00	0.00
Col136	31	-0.16	0.00	0.00
Col136	32	-0.35	0.00	0.00
Col136	33	-0.16	0.00	0.00
Col136	34	-0.21	0.00	0.00
Col136	35	-0.01	0.00	0.00
Col136	36	0.15	0.00	0.00
Col136	37	0.15	0.00	0.00
Col136	38	0.68	0.00	0.00
Col136	39	0.68	0.00	0.00
Col136	40	0.51	0.00	0.00
Col136	41	0.51	0.00	0.00
Col136	42	0.51	0.00	0.00
Col136	43	0.51	0.00	0.00
Col136	44	0.10	0.00	0.00
Col136	45	0.10	0.00	0.00
Col136	46	0.71	0.00	0.00
Col136	47	0.34	0.00	0.00
Col136	48	0.48	0.00	0.00
Col136	49	0.15	0.00	0.00

Col136	50	0.15	0.00	0.00
Col136	51	0.11	0.00	0.00
Col136	52	0.11	0.00	0.00
Col136	53	0.62	0.00	0.00
Col136	54	0.50	0.00	0.00
Col136	55	0.50	0.00	0.00
Col136	56	0.51	0.00	0.00
Col137	1	0.85	0.00	0.00
Col137	2	0.15	0.00	0.00
Col137	3	0.62	0.00	0.00
Col137	4	0.62	0.00	0.00
Col137	5	0.68	0.00	0.00
Col137	6	0.50	0.00	0.00
Col137	7	0.50	0.00	0.00
Col137	8	-0.33	0.00	0.00
Col137	9	-0.13	0.00	0.00
Col137	10	-0.33	0.00	0.00
Col137	11	-0.13	0.00	0.00
Col137	12	-0.33	0.00	0.00
Col137	13	-0.13	0.00	0.00
Col137	14	-0.18	0.00	0.00
Col137	15	0.01	0.00	0.00
Col137	16	0.44	0.00	0.00
Col137	17	0.59	0.00	0.00
Col137	18	0.33	0.00	0.00
Col137	19	0.48	0.00	0.00
Col137	20	0.27	0.00	0.00
Col137	21	0.41	0.00	0.00
Col137	22	0.16	0.00	0.00
Col137	23	0.30	0.00	0.00
Col137	24	0.27	0.00	0.00
Col137	25	0.41	0.00	0.00
Col137	26	0.16	0.00	0.00
Col137	27	0.30	0.00	0.00
Col137	28	-0.35	0.00	0.00
Col137	29	-0.16	0.00	0.00
Col137	30	-0.35	0.00	0.00
Col137	31	-0.16	0.00	0.00
Col137	32	-0.35	0.00	0.00
Col137	33	-0.16	0.00	0.00
Col137	34	-0.21	0.00	0.00
Col137	35	-0.01	0.00	0.00
Col137	36	0.15	0.00	0.00
Col137	37	0.15	0.00	0.00
Col137	38	0.68	0.00	0.00
Col137	39	0.68	0.00	0.00
Col137	40	0.51	0.00	0.00
Col137	41	0.51	0.00	0.00
Col137	42	0.51	0.00	0.00
Col137	43	0.51	0.00	0.00
Col137	44	0.10	0.00	0.00
Col137	45	0.10	0.00	0.00
Col137	46	0.71	0.00	0.00
Col137	47	0.34	0.00	0.00
Col137	48	0.48	0.00	0.00
Col137	49	0.15	0.00	0.00
Col137	50	0.15	0.00	0.00
Col137	51	0.11	0.00	0.00
Col137	52	0.11	0.00	0.00
Col137	53	0.62	0.00	0.00
Col137	54	0.50	0.00	0.00
Col137	55	0.50	0.00	0.00
Col137	56	0.51	0.00	0.00
Col138	1	0.85	0.00	0.00
Col138	2	0.15	0.00	0.00

Col138	3	0.62	0.00	0.00
Col138	4	0.62	0.00	0.00
Col138	5	0.68	0.00	0.00
Col138	6	0.50	0.00	0.00
Col138	7	0.50	0.00	0.00
Col138	8	-0.33	0.00	0.00
Col138	9	-0.13	0.00	0.00
Col138	10	-0.33	0.00	0.00
Col138	11	-0.13	0.00	0.00
Col138	12	-0.33	0.00	0.00
Col138	13	-0.13	0.00	0.00
Col138	14	-0.18	0.00	0.00
Col138	15	0.01	0.00	0.00
Col138	16	0.44	0.00	0.00
Col138	17	0.59	0.00	0.00
Col138	18	0.33	0.00	0.00
Col138	19	0.48	0.00	0.00
Col138	20	0.27	0.00	0.00
Col138	21	0.41	0.00	0.00
Col138	22	0.16	0.00	0.00
Col138	23	0.30	0.00	0.00
Col138	24	0.27	0.00	0.00
Col138	25	0.41	0.00	0.00
Col138	26	0.16	0.00	0.00
Col138	27	0.30	0.00	0.00
Col138	28	-0.35	0.00	0.00
Col138	29	-0.16	0.00	0.00
Col138	30	-0.35	0.00	0.00
Col138	31	-0.16	0.00	0.00
Col138	32	-0.35	0.00	0.00
Col138	33	-0.16	0.00	0.00
Col138	34	-0.21	0.00	0.00
Col138	35	-0.01	0.00	0.00
Col138	36	0.15	0.00	0.00
Col138	37	0.15	0.00	0.00
Col138	38	0.68	0.00	0.00
Col138	39	0.68	0.00	0.00
Col138	40	0.51	0.00	0.00
Col138	41	0.51	0.00	0.00
Col138	42	0.51	0.00	0.00
Col138	43	0.51	0.00	0.00
Col138	44	0.10	0.00	0.00
Col138	45	0.10	0.00	0.00
Col138	46	0.71	0.00	0.00
Col138	47	0.34	0.00	0.00
Col138	48	0.48	0.00	0.00
Col138	49	0.15	0.00	0.00
Col138	50	0.15	0.00	0.00
Col138	51	0.11	0.00	0.00
Col138	52	0.11	0.00	0.00
Col138	53	0.62	0.00	0.00
Col138	54	0.50	0.00	0.00
Col138	55	0.50	0.00	0.00
Col138	56	0.51	0.00	0.00
Col139	1	0.85	0.00	0.00
Col139	2	0.15	0.00	0.00
Col139	3	0.62	0.00	0.00
Col139	4	0.62	0.00	0.00
Col139	5	0.68	0.00	0.00
Col139	6	0.50	0.00	0.00
Col139	7	0.50	0.00	0.00
Col139	8	-0.33	0.00	0.00
Col139	9	-0.13	0.00	0.00
Col139	10	-0.33	0.00	0.00
Col139	11	-0.13	0.00	0.00

Col139	12	-0.33	0.00	0.00
Col139	13	-0.13	0.00	0.00
Col139	14	-0.18	0.00	0.00
Col139	15	0.01	0.00	0.00
Col139	16	0.44	0.00	0.00
Col139	17	0.59	0.00	0.00
Col139	18	0.33	0.00	0.00
Col139	19	0.48	0.00	0.00
Col139	20	0.27	0.00	0.00
Col139	21	0.41	0.00	0.00
Col139	22	0.16	0.00	0.00
Col139	23	0.30	0.00	0.00
Col139	24	0.27	0.00	0.00
Col139	25	0.41	0.00	0.00
Col139	26	0.16	0.00	0.00
Col139	27	0.30	0.00	0.00
Col139	28	-0.35	0.00	0.00
Col139	29	-0.16	0.00	0.00
Col139	30	-0.35	0.00	0.00
Col139	31	-0.16	0.00	0.00
Col139	32	-0.35	0.00	0.00
Col139	33	-0.16	0.00	0.00
Col139	34	-0.21	0.00	0.00
Col139	35	-0.01	0.00	0.00
Col139	36	0.15	0.00	0.00
Col139	37	0.15	0.00	0.00
Col139	38	0.68	0.00	0.00
Col139	39	0.68	0.00	0.00
Col139	40	0.51	0.00	0.00
Col139	41	0.51	0.00	0.00
Col139	42	0.51	0.00	0.00
Col139	43	0.51	0.00	0.00
Col139	44	0.10	0.00	0.00
Col139	45	0.10	0.00	0.00
Col139	46	0.71	0.00	0.00
Col139	47	0.34	0.00	0.00
Col139	48	0.48	0.00	0.00
Col139	49	0.15	0.00	0.00
Col139	50	0.15	0.00	0.00
Col139	51	0.11	0.00	0.00
Col139	52	0.11	0.00	0.00
Col139	53	0.62	0.00	0.00
Col139	54	0.50	0.00	0.00
Col139	55	0.50	0.00	0.00
Col139	56	0.51	0.00	0.00
Col140	1	0.44	0.00	0.00
Col140	2	0.09	0.00	0.00
Col140	3	0.33	0.00	0.00
Col140	4	0.33	0.00	0.00
Col140	5	0.36	0.00	0.00
Col140	6	0.27	0.00	0.00
Col140	7	0.27	0.00	0.00
Col140	8	-0.14	0.00	-0.04
Col140	9	-0.05	0.00	-0.04
Col140	10	-0.14	0.00	0.05
Col140	11	-0.05	0.00	0.05
Col140	12	-0.14	0.00	0.05
Col140	13	-0.05	0.00	0.05
Col140	14	-0.07	0.00	0.05
Col140	15	0.02	0.00	0.05
Col140	16	0.24	0.00	0.04
Col140	17	0.31	0.00	0.04
Col140	18	0.18	0.00	0.04
Col140	19	0.26	0.00	0.04
Col140	20	0.15	0.00	0.04

Col40	21	0.22	0.00	0.04
Col40	22	0.10	0.00	0.04
Col40	23	0.17	0.00	0.04
Col40	24	0.15	0.00	0.04
Col40	25	0.22	0.00	0.04
Col40	26	0.10	0.00	0.04
Col40	27	0.17	0.00	0.04
Col40	28	-0.16	0.00	-0.04
Col40	29	-0.06	0.00	-0.04
Col40	30	-0.16	0.00	0.05
Col40	31	-0.06	0.00	0.05
Col40	32	-0.16	0.00	0.05
Col40	33	-0.06	0.00	0.05
Col40	34	-0.09	0.00	0.05
Col40	35	0.01	0.00	0.05
Col40	36	0.09	0.00	0.00
Col40	37	0.09	0.00	0.00
Col40	38	0.36	0.00	0.00
Col40	39	0.36	0.00	0.00
Col40	40	0.27	0.00	0.00
Col40	41	0.27	0.00	0.00
Col40	42	0.27	0.00	0.00
Col40	43	0.27	0.00	0.00
Col40	44	0.07	0.00	0.00
Col40	45	0.07	0.00	0.00
Col40	46	0.37	0.00	0.00
Col40	47	0.19	0.00	0.04
Col40	48	0.26	0.00	0.04
Col40	49	0.09	0.00	0.00
Col40	50	0.09	0.00	0.00
Col40	51	0.07	0.00	0.00
Col40	52	0.07	0.00	0.00
Col40	53	0.33	0.00	0.00
Col40	54	0.27	0.00	0.00
Col40	55	0.27	0.00	0.04
Col40	56	0.27	0.00	0.00

COLUMN DEFLECTIONS:

Load		Deflection(in)	
Id	Id	Calc	Limit
-----	----	-----	-----
Col135	1	0.00	1.07
Col135	2	0.00	1.07
Col135	3	0.00	1.07
Col135	4	0.00	1.07
Col135	5	0.00	1.07
Col135	6	0.00	1.07
Col135	7	0.00	1.07
Col135	8	-0.07	1.07
Col135	9	-0.07	1.07
Col135	10	0.08	1.07
Col135	11	0.08	1.07
Col135	12	0.08	1.07
Col135	13	0.08	1.07
Col135	14	0.08	1.07
Col135	15	0.08	1.07
Col135	16	0.06	1.07
Col135	17	0.06	1.07
Col135	18	0.06	1.07
Col135	19	0.06	1.07
Col135	20	0.06	1.07
Col135	21	0.06	1.07
Col135	22	0.06	1.07
Col135	23	0.06	1.07

Col135	24	0.06	1.07
Col135	25	0.06	1.07
Col135	26	0.06	1.07
Col135	27	0.06	1.07
Col135	28	-0.07	1.07
Col135	29	-0.07	1.07
Col135	30	0.08	1.07
Col135	31	0.08	1.07
Col135	32	0.08	1.07
Col135	33	0.08	1.07
Col135	34	0.08	1.07
Col135	35	0.08	1.07
Col135	36	0.00	1.07
Col135	37	0.00	1.07
Col135	38	0.00	1.07
Col135	39	0.00	1.07
Col135	40	0.00	1.07
Col135	41	0.00	1.07
Col135	42	0.00	1.07
Col135	43	0.00	1.07
Col135	44	0.00	1.07
Col135	45	0.00	1.07
Col135	46	0.00	1.07
Col135	47	0.04	1.07
Col135	48	0.04	1.07
Col135	49	0.00	1.07
Col135	50	0.00	1.07
Col135	51	0.06	1.07
Col135	52	0.00	1.07
Col136	1	0.00	1.07
Col136	2	0.00	1.07
Col136	3	0.00	1.07
Col136	4	0.00	1.07
Col136	5	0.00	1.07
Col136	6	0.00	1.07
Col136	7	0.00	1.07
Col136	8	0.00	1.07
Col136	9	0.00	1.07
Col136	10	0.00	1.07
Col136	11	0.00	1.07
Col136	12	0.00	1.07
Col136	13	0.00	1.07
Col136	14	0.00	1.07
Col136	15	0.00	1.07
Col136	16	0.00	1.07
Col136	17	0.00	1.07
Col136	18	0.00	1.07
Col136	19	0.00	1.07
Col136	20	0.00	1.07
Col136	21	0.00	1.07
Col136	22	0.00	1.07
Col136	23	0.00	1.07
Col136	24	0.00	1.07
Col136	25	0.00	1.07
Col136	26	0.00	1.07
Col136	27	0.00	1.07
Col136	28	0.00	1.07
Col136	29	0.00	1.07
Col136	30	0.00	1.07
Col136	31	0.00	1.07
Col136	32	0.00	1.07
Col136	33	0.00	1.07
Col136	34	0.00	1.07
Col136	35	0.00	1.07
Col136	36	0.00	1.07

Col136	37	0.00	1.07
Col136	38	0.00	1.07
Col136	39	0.00	1.07
Col136	40	0.00	1.07
Col136	41	0.00	1.07
Col136	42	0.00	1.07
Col136	43	0.00	1.07
Col136	44	0.00	1.07
Col136	45	0.00	1.07
Col136	46	0.00	1.07
Col136	47	0.00	1.07
Col136	48	0.00	1.07
Col136	49	0.00	1.07
Col136	50	0.00	1.07
Col136	51	0.00	1.07
Col136	52	0.00	1.07
Col137	1	0.00	1.07
Col137	2	0.00	1.07
Col137	3	0.00	1.07
Col137	4	0.00	1.07
Col137	5	0.00	1.07
Col137	6	0.00	1.07
Col137	7	0.00	1.07
Col137	8	0.00	1.07
Col137	9	0.00	1.07
Col137	10	0.00	1.07
Col137	11	0.00	1.07
Col137	12	0.00	1.07
Col137	13	0.00	1.07
Col137	14	0.00	1.07
Col137	15	0.00	1.07
Col137	16	0.00	1.07
Col137	17	0.00	1.07
Col137	18	0.00	1.07
Col137	19	0.00	1.07
Col137	20	0.00	1.07
Col137	21	0.00	1.07
Col137	22	0.00	1.07
Col137	23	0.00	1.07
Col137	24	0.00	1.07
Col137	25	0.00	1.07
Col137	26	0.00	1.07
Col137	27	0.00	1.07
Col137	28	0.00	1.07
Col137	29	0.00	1.07
Col137	30	0.00	1.07
Col137	31	0.00	1.07
Col137	32	0.00	1.07
Col137	33	0.00	1.07
Col137	34	0.00	1.07
Col137	35	0.00	1.07
Col137	36	0.00	1.07
Col137	37	0.00	1.07
Col137	38	0.00	1.07
Col137	39	0.00	1.07
Col137	40	0.00	1.07
Col137	41	0.00	1.07
Col137	42	0.00	1.07
Col137	43	0.00	1.07
Col137	44	0.00	1.07
Col137	45	0.00	1.07
Col137	46	0.00	1.07
Col137	47	0.00	1.07
Col137	48	0.00	1.07
Col137	49	0.00	1.07

Col137	50	0.00	1.07
Col137	51	0.00	1.07
Col137	52	0.00	1.07
Col138	1	0.00	1.07
Col138	2	0.00	1.07
Col138	3	0.00	1.07
Col138	4	0.00	1.07
Col138	5	0.00	1.07
Col138	6	0.00	1.07
Col138	7	0.00	1.07
Col138	8	0.00	1.07
Col138	9	0.00	1.07
Col138	10	0.00	1.07
Col138	11	0.00	1.07
Col138	12	0.00	1.07
Col138	13	0.00	1.07
Col138	14	0.00	1.07
Col138	15	0.00	1.07
Col138	16	0.00	1.07
Col138	17	0.00	1.07
Col138	18	0.00	1.07
Col138	19	0.00	1.07
Col138	20	0.00	1.07
Col138	21	0.00	1.07
Col138	22	0.00	1.07
Col138	23	0.00	1.07
Col138	24	0.00	1.07
Col138	25	0.00	1.07
Col138	26	0.00	1.07
Col138	27	0.00	1.07
Col138	28	0.00	1.07
Col138	29	0.00	1.07
Col138	30	0.00	1.07
Col138	31	0.00	1.07
Col138	32	0.00	1.07
Col138	33	0.00	1.07
Col138	34	0.00	1.07
Col138	35	0.00	1.07
Col138	36	0.00	1.07
Col138	37	0.00	1.07
Col138	38	0.00	1.07
Col138	39	0.00	1.07
Col138	40	0.00	1.07
Col138	41	0.00	1.07
Col138	42	0.00	1.07
Col138	43	0.00	1.07
Col138	44	0.00	1.07
Col138	45	0.00	1.07
Col138	46	0.00	1.07
Col138	47	0.00	1.07
Col138	48	0.00	1.07
Col138	49	0.00	1.07
Col138	50	0.00	1.07
Col138	51	0.00	1.07
Col138	52	0.00	1.07
Col139	1	0.00	1.07
Col139	2	0.00	1.07
Col139	3	0.00	1.07
Col139	4	0.00	1.07
Col139	5	0.00	1.07
Col139	6	0.00	1.07
Col139	7	0.00	1.07
Col139	8	0.00	1.07
Col139	9	0.00	1.07
Col139	10	0.00	1.07

Col39	11	0.00	1.07
Col39	12	0.00	1.07
Col39	13	0.00	1.07
Col39	14	0.00	1.07
Col39	15	0.00	1.07
Col39	16	0.00	1.07
Col39	17	0.00	1.07
Col39	18	0.00	1.07
Col39	19	0.00	1.07
Col39	20	0.00	1.07
Col39	21	0.00	1.07
Col39	22	0.00	1.07
Col39	23	0.00	1.07
Col39	24	0.00	1.07
Col39	25	0.00	1.07
Col39	26	0.00	1.07
Col39	27	0.00	1.07
Col39	28	0.00	1.07
Col39	29	0.00	1.07
Col39	30	0.00	1.07
Col39	31	0.00	1.07
Col39	32	0.00	1.07
Col39	33	0.00	1.07
Col39	34	0.00	1.07
Col39	35	0.00	1.07
Col39	36	0.00	1.07
Col39	37	0.00	1.07
Col39	38	0.00	1.07
Col39	39	0.00	1.07
Col39	40	0.00	1.07
Col39	41	0.00	1.07
Col39	42	0.00	1.07
Col39	43	0.00	1.07
Col39	44	0.00	1.07
Col39	45	0.00	1.07
Col39	46	0.00	1.07
Col39	47	0.00	1.07
Col39	48	0.00	1.07
Col39	49	0.00	1.07
Col39	50	0.00	1.07
Col39	51	0.00	1.07
Col39	52	0.00	1.07
Col40	1	0.00	1.07
Col40	2	0.00	1.07
Col40	3	0.00	1.07
Col40	4	0.00	1.07
Col40	5	0.00	1.07
Col40	6	0.00	1.07
Col40	7	0.00	1.07
Col40	8	-0.07	1.07
Col40	9	-0.07	1.07
Col40	10	0.08	1.07
Col40	11	0.08	1.07
Col40	12	0.08	1.07
Col40	13	0.08	1.07
Col40	14	0.08	1.07
Col40	15	0.08	1.07
Col40	16	0.06	1.07
Col40	17	0.06	1.07
Col40	18	0.06	1.07
Col40	19	0.06	1.07
Col40	20	0.06	1.07
Col40	21	0.06	1.07
Col40	22	0.06	1.07
Col40	23	0.06	1.07

Col40	24	0.06	1.07
Col40	25	0.06	1.07
Col40	26	0.06	1.07
Col40	27	0.06	1.07
Col40	28	-0.07	1.07
Col40	29	-0.07	1.07
Col40	30	0.08	1.07
Col40	31	0.08	1.07
Col40	32	0.08	1.07
Col40	33	0.08	1.07
Col40	34	0.08	1.07
Col40	35	0.08	1.07
Col40	36	0.00	1.07
Col40	37	0.00	1.07
Col40	38	0.00	1.07
Col40	39	0.00	1.07
Col40	40	0.00	1.07
Col40	41	0.00	1.07
Col40	42	0.00	1.07
Col40	43	0.00	1.07
Col40	44	0.00	1.07
Col40	45	0.00	1.07
Col40	46	0.00	1.07
Col40	47	0.04	1.07
Col40	48	0.04	1.07
Col40	49	0.00	1.07
Col40	50	0.00	1.07
Col40	51	0.06	1.07
Col40	52	0.00	1.07

RAFTER DEFLECTIONS:

Id	Load	Deflection(in)	
	Id	Calc	Limit
-----	----	-----	-----
Raf4	1	0.00	0.93
Raf4	2	0.00	0.93
Raf4	3	0.00	0.93
Raf4	4	0.00	0.93
Raf4	5	0.00	0.93
Raf4	6	0.00	0.93
Raf4	7	0.00	0.93
Raf4	8	0.00	0.93
Raf4	9	0.00	0.93
Raf4	10	0.00	0.93
Raf4	11	0.00	0.93
Raf4	12	0.00	0.93
Raf4	13	0.00	0.93
Raf4	14	0.00	0.93
Raf4	15	0.00	0.93
Raf4	16	0.00	0.93
Raf4	17	0.00	0.93
Raf4	18	0.00	0.93
Raf4	19	0.00	0.93
Raf4	20	0.00	0.93
Raf4	21	0.00	0.93
Raf4	22	0.00	0.93
Raf4	23	0.00	0.93
Raf4	24	0.00	0.93
Raf4	25	0.00	0.93
Raf4	26	0.00	0.93
Raf4	27	0.00	0.93
Raf4	28	0.00	0.93
Raf4	29	0.00	0.93
Raf4	30	0.00	0.93

Raf4	31	0.00	0.93
Raf4	32	0.00	0.93
Raf4	33	0.00	0.93
Raf4	34	0.00	0.93
Raf4	35	0.00	0.93
Raf4	36	0.00	0.93
Raf4	37	0.00	0.93
Raf4	38	0.00	0.93
Raf4	39	0.00	0.93
Raf4	40	0.00	0.93
Raf4	41	0.00	0.93
Raf4	42	0.00	0.93
Raf4	43	0.00	0.93
Raf4	44	0.00	0.93
Raf4	45	0.00	0.93
Raf4	46	0.00	0.93
Raf4	47	0.00	0.93
Raf4	48	0.00	0.93
Raf4	49	0.00	0.93
Raf4	50	0.00	0.93
Raf4	51	0.00	0.93
Raf4	52	0.00	0.93
Raf5	1	0.00	0.93
Raf5	2	0.00	0.93
Raf5	3	0.00	0.93
Raf5	4	0.00	0.93
Raf5	5	0.00	0.93
Raf5	6	0.00	0.93
Raf5	7	0.00	0.93
Raf5	8	0.00	0.93
Raf5	9	0.00	0.93
Raf5	10	0.00	0.93
Raf5	11	0.00	0.93
Raf5	12	0.00	0.93
Raf5	13	0.00	0.93
Raf5	14	0.00	0.93
Raf5	15	0.00	0.93
Raf5	16	0.00	0.93
Raf5	17	0.00	0.93
Raf5	18	0.00	0.93
Raf5	19	0.00	0.93
Raf5	20	0.00	0.93
Raf5	21	0.00	0.93
Raf5	22	0.00	0.93
Raf5	23	0.00	0.93
Raf5	24	0.00	0.93
Raf5	25	0.00	0.93
Raf5	26	0.00	0.93
Raf5	27	0.00	0.93
Raf5	28	0.00	0.93
Raf5	29	0.00	0.93
Raf5	30	0.00	0.93
Raf5	31	0.00	0.93
Raf5	32	0.00	0.93
Raf5	33	0.00	0.93
Raf5	34	0.00	0.93
Raf5	35	0.00	0.93
Raf5	36	0.00	0.93
Raf5	37	0.00	0.93
Raf5	38	0.00	0.93
Raf5	39	0.00	0.93
Raf5	40	0.00	0.93
Raf5	41	0.00	0.93
Raf5	42	0.00	0.93
Raf5	43	0.00	0.93

Raf5	44	0.00	0.93
Raf5	45	0.00	0.93
Raf5	46	0.00	0.93
Raf5	47	0.00	0.93
Raf5	48	0.00	0.93
Raf5	49	0.00	0.93
Raf5	50	0.00	0.93
Raf5	51	0.00	0.93
Raf5	52	0.00	0.93
Raf6	1	0.00	0.93
Raf6	2	0.00	0.93
Raf6	3	0.00	0.93
Raf6	4	0.00	0.93
Raf6	5	0.00	0.93
Raf6	6	0.00	0.93
Raf6	7	0.00	0.93
Raf6	8	0.00	0.93
Raf6	9	0.00	0.93
Raf6	10	0.00	0.93
Raf6	11	0.00	0.93
Raf6	12	0.00	0.93
Raf6	13	0.00	0.93
Raf6	14	0.00	0.93
Raf6	15	0.00	0.93
Raf6	16	0.00	0.93
Raf6	17	0.00	0.93
Raf6	18	0.00	0.93
Raf6	19	0.00	0.93
Raf6	20	0.00	0.93
Raf6	21	0.00	0.93
Raf6	22	0.00	0.93
Raf6	23	0.00	0.93
Raf6	24	0.00	0.93
Raf6	25	0.00	0.93
Raf6	26	0.00	0.93
Raf6	27	0.00	0.93
Raf6	28	0.00	0.93
Raf6	29	0.00	0.93
Raf6	30	0.00	0.93
Raf6	31	0.00	0.93
Raf6	32	0.00	0.93
Raf6	33	0.00	0.93
Raf6	34	0.00	0.93
Raf6	35	0.00	0.93
Raf6	36	0.00	0.93
Raf6	37	0.00	0.93
Raf6	38	0.00	0.93
Raf6	39	0.00	0.93
Raf6	40	0.00	0.93
Raf6	41	0.00	0.93
Raf6	42	0.00	0.93
Raf6	43	0.00	0.93
Raf6	44	0.00	0.93
Raf6	45	0.00	0.93
Raf6	46	0.00	0.93
Raf6	47	0.00	0.93
Raf6	48	0.00	0.93
Raf6	49	0.00	0.93
Raf6	50	0.00	0.93
Raf6	51	0.00	0.93
Raf6	52	0.00	0.93

COLUMN KL/R RATIO, MOMENT REDUCTION:

Available
Reduction

Id	Major	--Minor(ft)--		----KL/R----		Factor	
	(ft)	Bend	Axial	Major	Minor	Out	In
Col35	16.1	4.1	4.1	83	66	0.00	0.00
Col36	0.1	4.1	4.1	1	66	0.00	0.00
Col37	0.1	4.1	4.1	1	66	0.00	0.00
Col38	0.1	4.1	4.1	1	66	0.00	0.00
Col39	0.1	4.1	4.1	1	66	0.00	0.00
Col40	16.1	4.1	4.1	83	66	0.00	0.00

JAMB/HEADER LAYOUT:

Bay	Id	Part	Length	Weight
----	-----	-----	-----	-----
1	JambL	PBMJ6	16.08	56.0
	JambR	PBMJ6	16.08	56.0
	Header	6X25C16	12.00	28.1
2	JambL	PBMJ6	16.08	56.0
	JambR	PBMJ6	16.08	56.0
	Header	6X25C16	12.00	28.1
3	JambL	PBMJ6	16.08	56.0
	JambR	PBMJ6	16.08	56.0
	Header	6X25C16	12.00	28.1
4	JambL	PBMJ6	16.08	56.0
	JambR	PBMJ6	16.08	56.0
	Header	6X25C16	12.00	28.1
5	JambL	PBMJ6	16.08	56.0
	JambR	PBMJ6	16.08	56.0
	Header	6X25C16	12.00	28.1

STRENGTH/DEFLECTION:

Bay	Id	Load	-Shear(k)-		Moment(f-k)		Max	Deflect(in)	
----	-----	-----	Calc	Limit	Calc	Limit	UC	Calc	Limit
----	-----	-----	-----	-----	-----	-----	-----	-----	-----
1	JambL	WP	-0.53	5.26	-2.12	3.90	0.54	-0.29	2.14
		WS	0.62	5.26	2.48	3.90	0.64	0.34	2.14
	JambR	WP	-0.53	5.26	-2.12	3.90	0.54	-0.29	2.14
		WS	0.58	5.26	2.33	3.90	0.60	0.32	2.14
	Header	WP	-0.06	3.86	-0.19	0.98	0.19	-0.02	1.60
		WS	0.07	3.86	0.21	1.93	0.11	0.03	1.60
2	JambL	WP	-0.53	5.26	-2.12	3.90	0.54	-0.29	2.14
		WS	0.58	5.26	2.33	3.90	0.60	0.32	2.14
	JambR	WP	-0.53	5.26	-2.12	3.90	0.54	-0.29	2.14
		WS	0.58	5.26	2.33	3.90	0.60	0.32	2.14
	Header	WP	-0.06	3.86	-0.19	0.98	0.19	-0.02	1.60
		WS	0.07	3.86	0.21	1.93	0.11	0.03	1.60
3	JambL	WP	-0.53	5.26	-2.12	3.90	0.54	-0.29	2.14
		WS	0.58	5.26	2.33	3.90	0.60	0.32	2.14
	JambR	WP	-0.53	5.26	-2.12	3.90	0.54	-0.29	2.14
		WS	0.58	5.26	2.33	3.90	0.60	0.32	2.14
	Header	WP	-0.06	3.86	-0.19	0.98	0.19	-0.02	1.60
		WS	0.07	3.86	0.21	1.93	0.11	0.03	1.60
4	JambL	WP	-0.53	5.26	-2.12	3.90	0.54	-0.29	2.14
		WS	0.58	5.26	2.33	3.90	0.60	0.32	2.14
	JambR	WP	-0.53	5.26	-2.12	3.90	0.54	-0.29	2.14
		WS	0.58	5.26	2.33	3.90	0.60	0.32	2.14
	Header	WP	-0.06	3.86	-0.19	0.98	0.19	-0.02	1.60
		WS	0.07	3.86	0.21	1.93	0.11	0.03	1.60
5	JambL	WP	-0.53	5.26	-2.12	3.90	0.54	-0.29	2.14
		WS	0.58	5.26	2.33	3.90	0.60	0.32	2.14
	JambR	WP	-0.53	5.26	-2.12	3.90	0.54	-0.29	2.14
		WS	0.62	5.26	2.48	3.90	0.64	0.34	2.14
	Header	WP	-0.06	3.86	-0.19	0.98	0.19	-0.02	1.60
		WS	0.07	3.86	0.21	1.93	0.11	0.03	1.60

WP - Wind_Pressure
WS - Wind_Suction

PANEL:

Table with 4 columns: Part, Thick (in), Yield (ksi), Tensile Strength (ksi). Row 1: CUSPANL, 0.038, 50.00, 65.00.

GIRT SCREWS:

Table with 4 columns: Part, Dia (in), Washer (in), Limit (k). Row 1: #29, 0.21, 0.50, 2.90.

PANEL ZONE LAYOUT:

Table with 9 columns: Zone Id, Description, Wall (ft) Offset1, Wall (ft) Offset2, Bay Id, Girt (ft, ft, in) Locate, Load Width, Min Thick, Panel Span (ft). Rows 1-3: Interior, Lt Edge, Rt Edge.

GIRT SCREW CHECK:

Table with 8 columns: Zone Id, Screw Space, Wind Suction (psf), Load (k), Limit (k) Pullout, Panel Pullover, Screw Tension, Max UC. Rows 1-3: 1.00, 16.62, 0.07.

11 12	Wall	6 - Column & Rafter Design	8/25/22	2:32pm
-------	------	----------------------------	---------	--------

WALL LAYOUT:

Wall Id	Orn	LeftEW Offset	BackSW Offset	Wall Length	Load Width
6	T	14.00	0.00	65.00	14.00

MEMBER LAYOUT:

Id	Locate (ft)	Part	---Web(in)--- Depth	Thick	-Flange(in)- Width	Thick	Length (ft)	Weight (lb)	----Max_Load---- Id	UC	Report
Col42	5.0	6X2C16	6.00	16ga	2.00	16ga	16.3	35.8	8	0.40	Deflect
Col43	10.0	6X2C16	6.00	16ga	2.00	16ga	16.5	36.2	8	0.41	Deflect
Col44	15.0	6X2C16	6.00	16ga	2.00	16ga	16.7	36.7	8	0.43	Deflect
Col45	20.0	6X2C16	6.00	16ga	2.00	16ga	17.0	37.1	8	0.45	Deflect
Col46	25.0	6X2C16	6.00	16ga	2.00	16ga	17.2	37.6	8	0.46	Deflect
Col47	30.0	6X2C16	6.00	16ga	2.00	16ga	17.3	37.9	8	0.47	Deflect
Col48	35.0	6X2C16	6.00	16ga	2.00	16ga	17.2	37.6	8	0.46	Deflect
Col49	40.0	6X2C16	6.00	16ga	2.00	16ga	17.0	37.1	8	0.45	Deflect
Col50	45.0	6X2C16	6.00	16ga	2.00	16ga	16.7	36.7	8	0.43	Deflect
Col51	50.0	6X2C16	6.00	16ga	2.00	16ga	16.5	36.2	8	0.41	Deflect
Col52	55.0	6X2C16	6.00	16ga	2.00	16ga	16.3	35.8	8	0.40	Deflect
Col53	60.0	6X2C16	6.00	16ga	2.00	16ga	16.1	35.3	8	0.38	Deflect
Total=								440.0			

DESIGN ACTIONS/STRENGTH:

-----Unity_Check-----											
Id	Load Id	-Axial(k)- Calc Limit		-Shear(k)- Calc Limit		Moment(f-k) Calc Limit		Axial	Shear	Axial+	Shear+
										Moment	Moment
Col42	1	1.62	8.55	0.00	3.32	0.00	3.07	0.19	0.00	0.19	0.00
Col42	2	0.22	8.55	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col42	3	1.16	8.55	0.00	3.32	0.00	3.07	0.14	0.00	0.14	0.00
Col42	4	1.16	8.55	0.00	3.32	0.00	3.07	0.14	0.00	0.14	0.00
Col42	5	1.27	8.55	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col42	6	0.92	8.55	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col42	7	0.92	8.55	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col42	8	-0.74	21.18	0.24	3.32	-1.00	3.07	0.03	0.07	0.29	0.00
Col42	9	-0.35	21.18	0.24	3.32	-1.00	3.07	0.02	0.07	0.31	0.00
Col42	10	-0.74	21.18	-0.24	3.32	1.00	3.07	0.03	0.07	0.29	0.00
Col42	11	-0.35	21.18	-0.24	3.32	1.00	3.07	0.02	0.07	0.31	0.00
Col42	12	-0.74	21.18	-0.24	3.32	1.00	3.07	0.03	0.07	0.29	0.00
Col42	13	-0.35	21.18	-0.24	3.32	1.00	3.07	0.02	0.07	0.31	0.00
Col42	14	-0.45	21.18	-0.24	3.32	1.00	3.07	0.02	0.07	0.30	0.00
Col42	15	-0.06	21.18	-0.24	3.32	1.00	3.07	0.00	0.07	0.32	0.00
Col42	16	0.80	8.55	-0.18	3.32	0.75	3.07	0.09	0.06	0.34	0.00
Col42	17	1.09	8.55	-0.18	3.32	0.75	3.07	0.13	0.06	0.37	0.00
Col42	18	0.58	8.55	-0.18	3.32	0.75	3.07	0.07	0.06	0.31	0.00
Col42	19	0.87	8.55	-0.18	3.32	0.75	3.07	0.10	0.06	0.35	0.00
Col42	20	0.45	8.55	-0.18	3.32	0.75	3.07	0.05	0.06	0.30	0.00
Col42	21	0.74	8.55	-0.18	3.32	0.75	3.07	0.09	0.06	0.33	0.00
Col42	22	0.23	8.55	-0.18	3.32	0.75	3.07	0.03	0.06	0.27	0.00
Col42	23	0.52	8.55	-0.18	3.32	0.75	3.07	0.06	0.06	0.31	0.00
Col42	24	0.45	8.55	-0.18	3.32	0.75	3.07	0.05	0.06	0.30	0.00
Col42	25	0.74	8.55	-0.18	3.32	0.75	3.07	0.09	0.06	0.33	0.00
Col42	26	0.23	8.55	-0.18	3.32	0.75	3.07	0.03	0.06	0.27	0.00
Col42	27	0.52	8.55	-0.18	3.32	0.75	3.07	0.06	0.06	0.31	0.00
Col42	28	-0.79	21.18	0.24	3.32	-1.00	3.07	0.04	0.07	0.29	0.00
Col42	29	-0.40	21.18	0.24	3.32	-1.00	3.07	0.02	0.07	0.31	0.00

Col142	30	-0.79	21.18	-0.24	3.32	1.00	3.07	0.04	0.07	0.29	0.00
Col142	31	-0.40	21.18	-0.24	3.32	1.00	3.07	0.02	0.07	0.31	0.00
Col142	32	-0.79	21.18	-0.24	3.32	1.00	3.07	0.04	0.07	0.29	0.00
Col142	33	-0.40	21.18	-0.24	3.32	1.00	3.07	0.02	0.07	0.31	0.00
Col142	34	-0.50	21.18	-0.24	3.32	1.00	3.07	0.02	0.07	0.30	0.00
Col142	35	-0.11	21.18	-0.24	3.32	1.00	3.07	0.01	0.07	0.32	0.00
Col142	36	0.23	8.55	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col142	37	0.23	8.55	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col142	38	1.27	8.55	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col142	39	1.27	8.55	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col142	40	0.93	8.55	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col142	41	0.93	8.55	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col142	42	0.93	8.55	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col142	43	0.93	8.55	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col142	44	0.12	8.55	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col142	45	0.12	8.55	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col142	46	1.34	8.55	0.00	3.32	0.00	3.07	0.16	0.00	0.16	0.00
Col142	47	0.59	8.55	-0.18	3.32	0.75	3.07	0.07	0.06	0.31	0.00
Col142	48	0.88	8.55	-0.18	3.32	0.75	3.07	0.10	0.06	0.35	0.00
Col142	49	0.22	8.55	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col142	50	0.22	8.55	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col142	51	0.13	8.55	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col142	52	0.13	8.55	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col142	53	1.17	8.55	0.00	3.32	0.00	3.07	0.14	0.00	0.14	0.00
Col142	54	0.93	8.55	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col142	55	0.93	8.55	-0.18	3.32	0.75	3.07	0.11	0.06	0.35	0.00
Col142	56	0.93	8.55	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col143	1	1.62	8.44	0.00	3.32	0.00	3.07	0.19	0.00	0.19	0.00
Col143	2	0.22	8.44	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col143	3	1.16	8.44	0.00	3.32	0.00	3.07	0.14	0.00	0.14	0.00
Col143	4	1.16	8.44	0.00	3.32	0.00	3.07	0.14	0.00	0.14	0.00
Col143	5	1.27	8.44	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col143	6	0.92	8.44	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col143	7	0.92	8.44	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col143	8	-0.74	21.18	0.25	3.32	-1.03	3.07	0.03	0.07	0.30	0.00
Col143	9	-0.35	21.18	0.25	3.32	-1.03	3.07	0.02	0.07	0.32	0.00
Col143	10	-0.74	21.18	-0.25	3.32	1.03	3.07	0.03	0.07	0.30	0.00
Col143	11	-0.35	21.18	-0.25	3.32	1.03	3.07	0.02	0.07	0.32	0.00
Col143	12	-0.74	21.18	-0.25	3.32	1.03	3.07	0.03	0.07	0.30	0.00
Col143	13	-0.35	21.18	-0.25	3.32	1.03	3.07	0.02	0.07	0.32	0.00
Col143	14	-0.44	21.18	-0.25	3.32	1.03	3.07	0.02	0.07	0.31	0.00
Col143	15	-0.06	21.18	-0.25	3.32	1.03	3.07	0.00	0.07	0.33	0.00
Col143	16	0.80	8.44	-0.19	3.32	0.77	3.07	0.09	0.06	0.35	0.00
Col143	17	1.09	8.44	-0.19	3.32	0.77	3.07	0.13	0.06	0.38	0.00
Col143	18	0.58	8.44	-0.19	3.32	0.77	3.07	0.07	0.06	0.32	0.00
Col143	19	0.87	8.44	-0.19	3.32	0.77	3.07	0.10	0.06	0.35	0.00
Col143	20	0.45	8.44	-0.19	3.32	0.77	3.07	0.05	0.06	0.30	0.00
Col143	21	0.74	8.44	-0.19	3.32	0.77	3.07	0.09	0.06	0.34	0.00
Col143	22	0.23	8.44	-0.19	3.32	0.77	3.07	0.03	0.06	0.28	0.00
Col143	23	0.52	8.44	-0.19	3.32	0.77	3.07	0.06	0.06	0.31	0.00
Col143	24	0.45	8.44	-0.19	3.32	0.77	3.07	0.05	0.06	0.30	0.00
Col143	25	0.74	8.44	-0.19	3.32	0.77	3.07	0.09	0.06	0.34	0.00
Col143	26	0.23	8.44	-0.19	3.32	0.77	3.07	0.03	0.06	0.28	0.00
Col143	27	0.52	8.44	-0.19	3.32	0.77	3.07	0.06	0.06	0.31	0.00
Col143	28	-0.79	21.18	0.25	3.32	-1.03	3.07	0.04	0.07	0.30	0.00
Col143	29	-0.40	21.18	0.25	3.32	-1.03	3.07	0.02	0.07	0.32	0.00
Col143	30	-0.79	21.18	-0.25	3.32	1.03	3.07	0.04	0.07	0.30	0.00
Col143	31	-0.40	21.18	-0.25	3.32	1.03	3.07	0.02	0.07	0.32	0.00
Col143	32	-0.79	21.18	-0.25	3.32	1.03	3.07	0.04	0.07	0.30	0.00
Col143	33	-0.40	21.18	-0.25	3.32	1.03	3.07	0.02	0.07	0.32	0.00
Col143	34	-0.50	21.18	-0.25	3.32	1.03	3.07	0.02	0.07	0.31	0.00
Col143	35	-0.11	21.18	-0.25	3.32	1.03	3.07	0.01	0.07	0.33	0.00
Col143	36	0.23	8.44	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col143	37	0.23	8.44	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col143	38	1.27	8.44	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00

Col143	39	1.27	8.44	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col143	40	0.93	8.44	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col143	41	0.93	8.44	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col143	42	0.93	8.44	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col143	43	0.93	8.44	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col143	44	0.13	8.44	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col143	45	0.13	8.44	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col143	46	1.34	8.44	0.00	3.32	0.00	3.07	0.16	0.00	0.16	0.00
Col143	47	0.59	8.44	-0.19	3.32	0.77	3.07	0.07	0.06	0.32	0.00
Col143	48	0.88	8.44	-0.19	3.32	0.77	3.07	0.10	0.06	0.35	0.00
Col143	49	0.22	8.44	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col143	50	0.22	8.44	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col143	51	0.13	8.44	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col143	52	0.13	8.44	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col143	53	1.41	8.44	0.00	3.32	0.00	3.07	0.17	0.00	0.17	0.00
Col143	54	1.12	8.44	0.00	3.32	0.00	3.07	0.13	0.00	0.13	0.00
Col143	55	1.12	8.44	-0.19	3.32	0.77	3.07	0.13	0.06	0.38	0.00
Col143	56	1.12	8.44	0.00	3.32	0.00	3.07	0.13	0.00	0.13	0.00
Col144	1	1.62	8.34	0.00	3.32	0.00	3.07	0.19	0.00	0.19	0.00
Col144	2	0.22	8.34	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col144	3	1.16	8.34	0.00	3.32	0.00	3.07	0.14	0.00	0.14	0.00
Col144	4	1.16	8.34	0.00	3.32	0.00	3.07	0.14	0.00	0.14	0.00
Col144	5	1.27	8.34	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col144	6	0.92	8.34	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col144	7	0.92	8.34	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col144	8	-0.73	21.18	0.25	3.32	-1.05	3.07	0.03	0.08	0.31	0.00
Col144	9	-0.35	21.18	0.25	3.32	-1.05	3.07	0.02	0.08	0.33	0.00
Col144	10	-0.73	21.18	-0.25	3.32	1.05	3.07	0.03	0.08	0.31	0.00
Col144	11	-0.35	21.18	-0.25	3.32	1.05	3.07	0.02	0.08	0.33	0.00
Col144	12	-0.73	21.18	-0.25	3.32	1.05	3.07	0.03	0.08	0.31	0.00
Col144	13	-0.35	21.18	-0.25	3.32	1.05	3.07	0.02	0.08	0.33	0.00
Col144	14	-0.44	21.18	-0.25	3.32	1.05	3.07	0.02	0.08	0.32	0.00
Col144	15	-0.06	21.18	-0.25	3.32	1.05	3.07	0.00	0.08	0.34	0.00
Col144	16	0.80	8.34	-0.19	3.32	0.79	3.07	0.10	0.06	0.35	0.00
Col144	17	1.09	8.34	-0.19	3.32	0.79	3.07	0.13	0.06	0.39	0.00
Col144	18	0.58	8.34	-0.19	3.32	0.79	3.07	0.07	0.06	0.33	0.00
Col144	19	0.87	8.34	-0.19	3.32	0.79	3.07	0.10	0.06	0.36	0.00
Col144	20	0.45	8.34	-0.19	3.32	0.79	3.07	0.05	0.06	0.31	0.00
Col144	21	0.74	8.34	-0.19	3.32	0.79	3.07	0.09	0.06	0.35	0.00
Col144	22	0.23	8.34	-0.19	3.32	0.79	3.07	0.03	0.06	0.29	0.00
Col144	23	0.52	8.34	-0.19	3.32	0.79	3.07	0.06	0.06	0.32	0.00
Col144	24	0.45	8.34	-0.19	3.32	0.79	3.07	0.05	0.06	0.31	0.00
Col144	25	0.74	8.34	-0.19	3.32	0.79	3.07	0.09	0.06	0.35	0.00
Col144	26	0.23	8.34	-0.19	3.32	0.79	3.07	0.03	0.06	0.29	0.00
Col144	27	0.52	8.34	-0.19	3.32	0.79	3.07	0.06	0.06	0.32	0.00
Col144	28	-0.79	21.18	0.25	3.32	-1.05	3.07	0.04	0.08	0.31	0.00
Col144	29	-0.40	21.18	0.25	3.32	-1.05	3.07	0.02	0.08	0.32	0.00
Col144	30	-0.79	21.18	-0.25	3.32	1.05	3.07	0.04	0.08	0.31	0.00
Col144	31	-0.40	21.18	-0.25	3.32	1.05	3.07	0.02	0.08	0.32	0.00
Col144	32	-0.79	21.18	-0.25	3.32	1.05	3.07	0.04	0.08	0.31	0.00
Col144	33	-0.40	21.18	-0.25	3.32	1.05	3.07	0.02	0.08	0.32	0.00
Col144	34	-0.50	21.18	-0.25	3.32	1.05	3.07	0.02	0.08	0.32	0.00
Col144	35	-0.11	21.18	-0.25	3.32	1.05	3.07	0.01	0.08	0.34	0.00
Col144	36	0.23	8.34	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col144	37	0.23	8.34	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col144	38	1.27	8.34	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col144	39	1.27	8.34	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col144	40	0.93	8.34	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col144	41	0.93	8.34	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col144	42	0.93	8.34	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col144	43	0.93	8.34	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col144	44	0.13	8.34	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col144	45	0.13	8.34	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col144	46	1.34	8.34	0.00	3.32	0.00	3.07	0.16	0.00	0.16	0.00
Col144	47	0.59	8.34	-0.19	3.32	0.79	3.07	0.07	0.06	0.33	0.00

Col144	48	0.88	8.34	-0.19	3.32	0.79	3.07	0.11	0.06	0.36	0.00
Col144	49	0.22	8.34	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col144	50	0.22	8.34	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col144	51	0.13	8.34	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col144	52	0.13	8.34	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col144	53	1.54	8.34	0.00	3.32	0.00	3.07	0.18	0.00	0.18	0.00
Col144	54	1.21	8.34	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col144	55	1.21	8.34	-0.19	3.32	0.79	3.07	0.15	0.06	0.40	0.00
Col144	56	1.21	8.34	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col145	1	1.62	8.23	0.00	3.32	0.00	3.07	0.20	0.00	0.20	0.00
Col145	2	0.22	8.23	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col145	3	1.16	8.23	0.00	3.32	0.00	3.07	0.14	0.00	0.14	0.00
Col145	4	1.16	8.23	0.00	3.32	0.00	3.07	0.14	0.00	0.14	0.00
Col145	5	1.27	8.23	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col145	6	0.92	8.23	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col145	7	0.92	8.23	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col145	8	-0.73	21.18	0.25	3.32	-1.08	3.07	0.03	0.08	0.32	0.00
Col145	9	-0.35	21.18	0.25	3.32	-1.08	3.07	0.02	0.08	0.33	0.00
Col145	10	-0.73	21.18	-0.25	3.32	1.08	3.07	0.03	0.08	0.32	0.00
Col145	11	-0.35	21.18	-0.25	3.32	1.08	3.07	0.02	0.08	0.33	0.00
Col145	12	-0.73	21.18	-0.25	3.32	1.08	3.07	0.03	0.08	0.32	0.00
Col145	13	-0.35	21.18	-0.25	3.32	1.08	3.07	0.02	0.08	0.33	0.00
Col145	14	-0.44	21.18	-0.25	3.32	1.08	3.07	0.02	0.08	0.33	0.00
Col145	15	-0.06	21.18	-0.25	3.32	1.08	3.07	0.00	0.08	0.35	0.00
Col145	16	0.80	8.23	-0.19	3.32	0.81	3.07	0.10	0.06	0.36	0.00
Col145	17	1.09	8.23	-0.19	3.32	0.81	3.07	0.13	0.06	0.40	0.00
Col145	18	0.58	8.23	-0.19	3.32	0.81	3.07	0.07	0.06	0.33	0.00
Col145	19	0.87	8.23	-0.19	3.32	0.81	3.07	0.11	0.06	0.37	0.00
Col145	20	0.45	8.23	-0.19	3.32	0.81	3.07	0.05	0.06	0.32	0.00
Col145	21	0.74	8.23	-0.19	3.32	0.81	3.07	0.09	0.06	0.35	0.00
Col145	22	0.23	8.23	-0.19	3.32	0.81	3.07	0.03	0.06	0.29	0.00
Col145	23	0.53	8.23	-0.19	3.32	0.81	3.07	0.06	0.06	0.33	0.00
Col145	24	0.45	8.23	-0.19	3.32	0.81	3.07	0.05	0.06	0.32	0.00
Col145	25	0.74	8.23	-0.19	3.32	0.81	3.07	0.09	0.06	0.35	0.00
Col145	26	0.23	8.23	-0.19	3.32	0.81	3.07	0.03	0.06	0.29	0.00
Col145	27	0.53	8.23	-0.19	3.32	0.81	3.07	0.06	0.06	0.33	0.00
Col145	28	-0.79	21.18	0.25	3.32	-1.08	3.07	0.04	0.08	0.31	0.00
Col145	29	-0.40	21.18	0.25	3.32	-1.08	3.07	0.02	0.08	0.33	0.00
Col145	30	-0.79	21.18	-0.25	3.32	1.08	3.07	0.04	0.08	0.31	0.00
Col145	31	-0.40	21.18	-0.25	3.32	1.08	3.07	0.02	0.08	0.33	0.00
Col145	32	-0.79	21.18	-0.25	3.32	1.08	3.07	0.04	0.08	0.31	0.00
Col145	33	-0.40	21.18	-0.25	3.32	1.08	3.07	0.02	0.08	0.33	0.00
Col145	34	-0.50	21.18	-0.25	3.32	1.08	3.07	0.02	0.08	0.33	0.00
Col145	35	-0.11	21.18	-0.25	3.32	1.08	3.07	0.01	0.08	0.35	0.00
Col145	36	0.23	8.23	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col145	37	0.23	8.23	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col145	38	1.28	8.23	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col145	39	1.27	8.23	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col145	40	0.93	8.23	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col145	41	0.93	8.23	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col145	42	0.93	8.23	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col145	43	0.93	8.23	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col145	44	0.13	8.23	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col145	45	0.13	8.23	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col145	46	1.34	8.23	0.00	3.32	0.00	3.07	0.16	0.00	0.16	0.00
Col145	47	0.59	8.23	-0.19	3.32	0.81	3.07	0.07	0.06	0.34	0.00
Col145	48	0.88	8.23	-0.19	3.32	0.81	3.07	0.11	0.06	0.37	0.00
Col145	49	0.22	8.23	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col145	50	0.22	8.23	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col145	51	0.13	8.23	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col145	52	0.13	8.23	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col145	53	1.54	8.23	0.00	3.32	0.00	3.07	0.19	0.00	0.19	0.00
Col145	54	1.21	8.23	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col145	55	1.21	8.23	-0.19	3.32	0.81	3.07	0.15	0.06	0.41	0.00
Col145	56	1.21	8.23	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00

Col146	1	1.62	8.13	0.00	3.32	0.00	3.07	0.20	0.00	0.20	0.00
Col146	2	0.22	8.13	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col146	3	1.16	8.13	0.00	3.32	0.00	3.07	0.14	0.00	0.14	0.00
Col146	4	1.16	8.13	0.00	3.32	0.00	3.07	0.14	0.00	0.14	0.00
Col146	5	1.27	8.13	0.00	3.32	0.00	3.07	0.16	0.00	0.16	0.00
Col146	6	0.93	8.13	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col146	7	0.93	8.13	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col146	8	-0.73	21.18	0.26	3.32	-1.11	3.07	0.03	0.08	0.33	0.00
Col146	9	-0.35	21.18	0.26	3.32	-1.11	3.07	0.02	0.08	0.34	0.00
Col146	10	-0.73	21.18	-0.26	3.32	1.11	3.07	0.03	0.08	0.33	0.00
Col146	11	-0.35	21.18	-0.26	3.32	1.11	3.07	0.02	0.08	0.34	0.00
Col146	12	-0.73	21.18	-0.26	3.32	1.11	3.07	0.03	0.08	0.33	0.00
Col146	13	-0.35	21.18	-0.26	3.32	1.11	3.07	0.02	0.08	0.34	0.00
Col146	14	-0.44	21.18	-0.26	3.32	1.11	3.07	0.02	0.08	0.34	0.00
Col146	15	-0.06	21.18	-0.26	3.32	1.11	3.07	0.00	0.08	0.36	0.00
Col146	16	0.80	8.13	-0.19	3.32	0.83	3.07	0.10	0.06	0.37	0.00
Col146	17	1.09	8.13	-0.19	3.32	0.83	3.07	0.13	0.06	0.40	0.00
Col146	18	0.58	8.13	-0.19	3.32	0.83	3.07	0.07	0.06	0.34	0.00
Col146	19	0.87	8.13	-0.19	3.32	0.83	3.07	0.11	0.06	0.38	0.00
Col146	20	0.45	8.13	-0.19	3.32	0.83	3.07	0.06	0.06	0.33	0.00
Col146	21	0.74	8.13	-0.19	3.32	0.83	3.07	0.09	0.06	0.36	0.00
Col146	22	0.23	8.13	-0.19	3.32	0.83	3.07	0.03	0.06	0.30	0.00
Col146	23	0.53	8.13	-0.19	3.32	0.83	3.07	0.06	0.06	0.33	0.00
Col146	24	0.45	8.13	-0.19	3.32	0.83	3.07	0.06	0.06	0.33	0.00
Col146	25	0.74	8.13	-0.19	3.32	0.83	3.07	0.09	0.06	0.36	0.00
Col146	26	0.23	8.13	-0.19	3.32	0.83	3.07	0.03	0.06	0.30	0.00
Col146	27	0.53	8.13	-0.19	3.32	0.83	3.07	0.06	0.06	0.33	0.00
Col146	28	-0.79	21.18	0.26	3.32	-1.11	3.07	0.04	0.08	0.32	0.00
Col146	29	-0.40	21.18	0.26	3.32	-1.11	3.07	0.02	0.08	0.34	0.00
Col146	30	-0.79	21.18	-0.26	3.32	1.11	3.07	0.04	0.08	0.32	0.00
Col146	31	-0.40	21.18	-0.26	3.32	1.11	3.07	0.02	0.08	0.34	0.00
Col146	32	-0.79	21.18	-0.26	3.32	1.11	3.07	0.04	0.08	0.32	0.00
Col146	33	-0.40	21.18	-0.26	3.32	1.11	3.07	0.02	0.08	0.34	0.00
Col146	34	-0.50	21.18	-0.26	3.32	1.11	3.07	0.02	0.08	0.34	0.00
Col146	35	-0.11	21.18	-0.26	3.32	1.11	3.07	0.01	0.08	0.35	0.00
Col146	36	0.23	8.13	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col146	37	0.23	8.13	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col146	38	1.28	8.13	0.00	3.32	0.00	3.07	0.16	0.00	0.16	0.00
Col146	39	1.28	8.13	0.00	3.32	0.00	3.07	0.16	0.00	0.16	0.00
Col146	40	0.93	8.13	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col146	41	0.93	8.13	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col146	42	0.93	8.13	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col146	43	0.93	8.13	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col146	44	0.13	8.13	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col146	45	0.13	8.13	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col146	46	1.34	8.13	0.00	3.32	0.00	3.07	0.17	0.00	0.17	0.00
Col146	47	0.59	8.13	-0.19	3.32	0.83	3.07	0.07	0.06	0.34	0.00
Col146	48	0.88	8.13	-0.19	3.32	0.83	3.07	0.11	0.06	0.38	0.00
Col146	49	0.22	8.13	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col146	50	0.22	8.13	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col146	51	0.13	8.13	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col146	52	0.13	8.13	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col146	53	1.54	8.13	0.00	3.32	0.00	3.07	0.19	0.00	0.19	0.00
Col146	54	1.21	8.13	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col146	55	1.21	8.13	-0.19	3.32	0.83	3.07	0.15	0.06	0.42	0.00
Col146	56	1.21	8.13	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col147	1	1.62	8.07	0.00	3.32	0.00	3.07	0.20	0.00	0.20	0.00
Col147	2	0.22	8.07	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col147	3	1.16	8.07	0.00	3.32	0.00	3.07	0.14	0.00	0.14	0.00
Col147	4	1.16	8.07	0.00	3.32	0.00	3.07	0.14	0.00	0.14	0.00
Col147	5	1.27	8.07	0.00	3.32	0.00	3.07	0.16	0.00	0.16	0.00
Col147	6	0.93	8.07	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col147	7	0.93	8.07	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col147	8	-0.53	21.18	0.26	3.32	-1.12	3.07	0.02	0.08	0.34	0.00
Col147	9	-0.53	21.18	0.26	3.32	-1.12	3.07	0.02	0.08	0.34	0.00

Col147	10	-0.53	21.18	-0.26	3.32	1.12	3.07	0.02	0.08	0.34	0.00
Col147	11	-0.53	21.18	-0.26	3.32	1.12	3.07	0.02	0.08	0.34	0.00
Col147	12	-0.53	21.18	-0.26	3.32	1.12	3.07	0.02	0.08	0.34	0.00
Col147	13	-0.53	21.18	-0.26	3.32	1.12	3.07	0.02	0.08	0.34	0.00
Col147	14	-0.24	21.18	-0.26	3.32	1.12	3.07	0.01	0.08	0.35	0.00
Col147	15	-0.24	21.18	-0.26	3.32	1.12	3.07	0.01	0.08	0.35	0.00
Col147	16	0.95	8.07	-0.19	3.32	0.84	3.07	0.12	0.06	0.39	0.00
Col147	17	0.95	8.07	-0.19	3.32	0.84	3.07	0.12	0.06	0.39	0.00
Col147	18	0.74	8.07	-0.19	3.32	0.84	3.07	0.09	0.06	0.37	0.00
Col147	19	0.74	8.07	-0.19	3.32	0.84	3.07	0.09	0.06	0.37	0.00
Col147	20	0.60	8.07	-0.19	3.32	0.84	3.07	0.07	0.06	0.35	0.00
Col147	21	0.60	8.07	-0.19	3.32	0.84	3.07	0.07	0.06	0.35	0.00
Col147	22	0.39	8.07	-0.19	3.32	0.84	3.07	0.05	0.06	0.32	0.00
Col147	23	0.39	8.07	-0.19	3.32	0.84	3.07	0.05	0.06	0.32	0.00
Col147	24	0.60	8.07	-0.19	3.32	0.84	3.07	0.07	0.06	0.35	0.00
Col147	25	0.60	8.07	-0.19	3.32	0.84	3.07	0.07	0.06	0.35	0.00
Col147	26	0.39	8.07	-0.19	3.32	0.84	3.07	0.05	0.06	0.32	0.00
Col147	27	0.39	8.07	-0.19	3.32	0.84	3.07	0.05	0.06	0.32	0.00
Col147	28	-0.58	21.18	0.26	3.32	-1.12	3.07	0.03	0.08	0.34	0.00
Col147	29	-0.58	21.18	0.26	3.32	-1.12	3.07	0.03	0.08	0.34	0.00
Col147	30	-0.58	21.18	-0.26	3.32	1.12	3.07	0.03	0.08	0.34	0.00
Col147	31	-0.58	21.18	-0.26	3.32	1.12	3.07	0.03	0.08	0.34	0.00
Col147	32	-0.58	21.18	-0.26	3.32	1.12	3.07	0.03	0.08	0.34	0.00
Col147	33	-0.58	21.18	-0.26	3.32	1.12	3.07	0.03	0.08	0.34	0.00
Col147	34	-0.30	21.18	-0.26	3.32	1.12	3.07	0.01	0.08	0.35	0.00
Col147	35	-0.30	21.18	-0.26	3.32	1.12	3.07	0.01	0.08	0.35	0.00
Col147	36	0.23	8.07	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col147	37	0.23	8.07	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col147	38	1.27	8.07	0.00	3.32	0.00	3.07	0.16	0.00	0.16	0.00
Col147	39	1.27	8.07	0.00	3.32	0.00	3.07	0.16	0.00	0.16	0.00
Col147	40	0.93	8.07	0.00	3.32	0.00	3.07	0.12	0.00	0.12	0.00
Col147	41	0.93	8.07	0.00	3.32	0.00	3.07	0.12	0.00	0.12	0.00
Col147	42	0.93	8.07	0.00	3.32	0.00	3.07	0.12	0.00	0.12	0.00
Col147	43	0.93	8.07	0.00	3.32	0.00	3.07	0.12	0.00	0.12	0.00
Col147	44	0.13	8.07	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col147	45	0.13	8.07	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col147	46	1.32	8.07	0.00	3.32	0.00	3.07	0.16	0.00	0.16	0.00
Col147	47	0.72	8.07	-0.19	3.32	0.84	3.07	0.09	0.06	0.36	0.00
Col147	48	0.72	8.07	-0.19	3.32	0.84	3.07	0.09	0.06	0.36	0.00
Col147	49	0.22	8.07	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col147	50	0.22	8.07	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col147	51	0.13	8.07	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col147	52	0.13	8.07	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col147	53	1.50	8.07	0.00	3.32	0.00	3.07	0.19	0.00	0.19	0.00
Col147	54	1.18	8.07	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col147	55	1.18	8.07	-0.19	3.32	0.84	3.07	0.15	0.06	0.42	0.00
Col147	56	1.18	8.07	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col148	1	1.62	8.13	0.00	3.32	0.00	3.07	0.20	0.00	0.20	0.00
Col148	2	0.22	8.13	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col148	3	1.16	8.13	0.00	3.32	0.00	3.07	0.14	0.00	0.14	0.00
Col148	4	1.16	8.13	0.00	3.32	0.00	3.07	0.14	0.00	0.14	0.00
Col148	5	1.27	8.13	0.00	3.32	0.00	3.07	0.16	0.00	0.16	0.00
Col148	6	0.93	8.13	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col148	7	0.93	8.13	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col148	8	-0.35	21.18	0.26	3.32	-1.11	3.07	0.02	0.08	0.34	0.00
Col148	9	-0.73	21.18	0.26	3.32	-1.11	3.07	0.03	0.08	0.33	0.00
Col148	10	-0.35	21.18	-0.26	3.32	1.11	3.07	0.02	0.08	0.34	0.00
Col148	11	-0.73	21.18	-0.26	3.32	1.11	3.07	0.03	0.08	0.33	0.00
Col148	12	-0.35	21.18	-0.26	3.32	1.11	3.07	0.02	0.08	0.34	0.00
Col148	13	-0.73	21.18	-0.26	3.32	1.11	3.07	0.03	0.08	0.33	0.00
Col148	14	-0.06	21.18	-0.26	3.32	1.11	3.07	0.00	0.08	0.36	0.00
Col148	15	-0.44	21.18	-0.26	3.32	1.11	3.07	0.02	0.08	0.34	0.00
Col148	16	1.09	8.13	-0.19	3.32	0.83	3.07	0.13	0.06	0.40	0.00
Col148	17	0.80	8.13	-0.19	3.32	0.83	3.07	0.10	0.06	0.37	0.00
Col148	18	0.87	8.13	-0.19	3.32	0.83	3.07	0.11	0.06	0.38	0.00

Col48	19	0.58	8.13	-0.19	3.32	0.83	3.07	0.07	0.06	0.34	0.00
Col48	20	0.74	8.13	-0.19	3.32	0.83	3.07	0.09	0.06	0.36	0.00
Col48	21	0.45	8.13	-0.19	3.32	0.83	3.07	0.06	0.06	0.33	0.00
Col48	22	0.53	8.13	-0.19	3.32	0.83	3.07	0.06	0.06	0.33	0.00
Col48	23	0.23	8.13	-0.19	3.32	0.83	3.07	0.03	0.06	0.30	0.00
Col48	24	0.74	8.13	-0.19	3.32	0.83	3.07	0.09	0.06	0.36	0.00
Col48	25	0.45	8.13	-0.19	3.32	0.83	3.07	0.06	0.06	0.33	0.00
Col48	26	0.53	8.13	-0.19	3.32	0.83	3.07	0.06	0.06	0.33	0.00
Col48	27	0.23	8.13	-0.19	3.32	0.83	3.07	0.03	0.06	0.30	0.00
Col48	28	-0.40	21.18	0.26	3.32	-1.11	3.07	0.02	0.08	0.34	0.00
Col48	29	-0.79	21.18	0.26	3.32	-1.11	3.07	0.04	0.08	0.32	0.00
Col48	30	-0.40	21.18	-0.26	3.32	1.11	3.07	0.02	0.08	0.34	0.00
Col48	31	-0.79	21.18	-0.26	3.32	1.11	3.07	0.04	0.08	0.32	0.00
Col48	32	-0.40	21.18	-0.26	3.32	1.11	3.07	0.02	0.08	0.34	0.00
Col48	33	-0.79	21.18	-0.26	3.32	1.11	3.07	0.04	0.08	0.32	0.00
Col48	34	-0.11	21.18	-0.26	3.32	1.11	3.07	0.01	0.08	0.35	0.00
Col48	35	-0.50	21.18	-0.26	3.32	1.11	3.07	0.02	0.08	0.34	0.00
Col48	36	0.23	8.13	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col48	37	0.23	8.13	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col48	38	1.28	8.13	0.00	3.32	0.00	3.07	0.16	0.00	0.16	0.00
Col48	39	1.28	8.13	0.00	3.32	0.00	3.07	0.16	0.00	0.16	0.00
Col48	40	0.93	8.13	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col48	41	0.93	8.13	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col48	42	0.93	8.13	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col48	43	0.93	8.13	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col48	44	0.13	8.13	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col48	45	0.13	8.13	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col48	46	1.34	8.13	0.00	3.32	0.00	3.07	0.17	0.00	0.17	0.00
Col48	47	0.88	8.13	-0.19	3.32	0.83	3.07	0.11	0.06	0.38	0.00
Col48	48	0.59	8.13	-0.19	3.32	0.83	3.07	0.07	0.06	0.34	0.00
Col48	49	0.22	8.13	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col48	50	0.22	8.13	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col48	51	0.13	8.13	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col48	52	0.13	8.13	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col48	53	1.51	8.13	0.00	3.32	0.00	3.07	0.19	0.00	0.19	0.00
Col48	54	1.19	8.13	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col48	55	1.19	8.13	-0.19	3.32	0.83	3.07	0.15	0.06	0.42	0.00
Col48	56	1.19	8.13	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col49	1	1.62	8.23	0.00	3.32	0.00	3.07	0.20	0.00	0.20	0.00
Col49	2	0.22	8.23	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col49	3	1.16	8.23	0.00	3.32	0.00	3.07	0.14	0.00	0.14	0.00
Col49	4	1.16	8.23	0.00	3.32	0.00	3.07	0.14	0.00	0.14	0.00
Col49	5	1.27	8.23	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col49	6	0.92	8.23	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col49	7	0.92	8.23	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col49	8	-0.35	21.18	0.25	3.32	-1.08	3.07	0.02	0.08	0.33	0.00
Col49	9	-0.73	21.18	0.25	3.32	-1.08	3.07	0.03	0.08	0.32	0.00
Col49	10	-0.35	21.18	-0.25	3.32	1.08	3.07	0.02	0.08	0.33	0.00
Col49	11	-0.73	21.18	-0.25	3.32	1.08	3.07	0.03	0.08	0.32	0.00
Col49	12	-0.35	21.18	-0.25	3.32	1.08	3.07	0.02	0.08	0.33	0.00
Col49	13	-0.73	21.18	-0.25	3.32	1.08	3.07	0.03	0.08	0.32	0.00
Col49	14	-0.06	21.18	-0.25	3.32	1.08	3.07	0.00	0.08	0.35	0.00
Col49	15	-0.44	21.18	-0.25	3.32	1.08	3.07	0.02	0.08	0.33	0.00
Col49	16	1.09	8.23	-0.19	3.32	0.81	3.07	0.13	0.06	0.40	0.00
Col49	17	0.80	8.23	-0.19	3.32	0.81	3.07	0.10	0.06	0.36	0.00
Col49	18	0.87	8.23	-0.19	3.32	0.81	3.07	0.11	0.06	0.37	0.00
Col49	19	0.58	8.23	-0.19	3.32	0.81	3.07	0.07	0.06	0.33	0.00
Col49	20	0.74	8.23	-0.19	3.32	0.81	3.07	0.09	0.06	0.35	0.00
Col49	21	0.45	8.23	-0.19	3.32	0.81	3.07	0.05	0.06	0.32	0.00
Col49	22	0.53	8.23	-0.19	3.32	0.81	3.07	0.06	0.06	0.33	0.00
Col49	23	0.23	8.23	-0.19	3.32	0.81	3.07	0.03	0.06	0.29	0.00
Col49	24	0.74	8.23	-0.19	3.32	0.81	3.07	0.09	0.06	0.35	0.00
Col49	25	0.45	8.23	-0.19	3.32	0.81	3.07	0.05	0.06	0.32	0.00
Col49	26	0.53	8.23	-0.19	3.32	0.81	3.07	0.06	0.06	0.33	0.00
Col49	27	0.23	8.23	-0.19	3.32	0.81	3.07	0.03	0.06	0.29	0.00

Col149	28	-0.40	21.18	0.25	3.32	-1.08	3.07	0.02	0.08	0.33	0.00
Col149	29	-0.79	21.18	0.25	3.32	-1.08	3.07	0.04	0.08	0.31	0.00
Col149	30	-0.40	21.18	-0.25	3.32	1.08	3.07	0.02	0.08	0.33	0.00
Col149	31	-0.79	21.18	-0.25	3.32	1.08	3.07	0.04	0.08	0.31	0.00
Col149	32	-0.40	21.18	-0.25	3.32	1.08	3.07	0.02	0.08	0.33	0.00
Col149	33	-0.79	21.18	-0.25	3.32	1.08	3.07	0.04	0.08	0.31	0.00
Col149	34	-0.11	21.18	-0.25	3.32	1.08	3.07	0.01	0.08	0.35	0.00
Col149	35	-0.50	21.18	-0.25	3.32	1.08	3.07	0.02	0.08	0.33	0.00
Col149	36	0.23	8.23	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col149	37	0.23	8.23	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col149	38	1.27	8.23	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col149	39	1.28	8.23	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col149	40	0.93	8.23	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col149	41	0.93	8.23	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col149	42	0.93	8.23	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col149	43	0.93	8.23	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col149	44	0.13	8.23	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col149	45	0.13	8.23	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col149	46	1.34	8.23	0.00	3.32	0.00	3.07	0.16	0.00	0.16	0.00
Col149	47	0.88	8.23	-0.19	3.32	0.81	3.07	0.11	0.06	0.37	0.00
Col149	48	0.59	8.23	-0.19	3.32	0.81	3.07	0.07	0.06	0.34	0.00
Col149	49	0.22	8.23	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col149	50	0.22	8.23	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col149	51	0.13	8.23	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col149	52	0.13	8.23	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col149	53	1.51	8.23	0.00	3.32	0.00	3.07	0.18	0.00	0.18	0.00
Col149	54	1.19	8.23	0.00	3.32	0.00	3.07	0.14	0.00	0.14	0.00
Col149	55	1.19	8.23	-0.19	3.32	0.81	3.07	0.14	0.06	0.41	0.00
Col149	56	1.19	8.23	0.00	3.32	0.00	3.07	0.14	0.00	0.14	0.00
Col150	1	1.62	8.34	0.00	3.32	0.00	3.07	0.19	0.00	0.19	0.00
Col150	2	0.22	8.34	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col150	3	1.16	8.34	0.00	3.32	0.00	3.07	0.14	0.00	0.14	0.00
Col150	4	1.16	8.34	0.00	3.32	0.00	3.07	0.14	0.00	0.14	0.00
Col150	5	1.27	8.34	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col150	6	0.92	8.34	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col150	7	0.92	8.34	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col150	8	-0.35	21.18	0.25	3.32	-1.05	3.07	0.02	0.08	0.33	0.00
Col150	9	-0.73	21.18	0.25	3.32	-1.05	3.07	0.03	0.08	0.31	0.00
Col150	10	-0.35	21.18	-0.25	3.32	1.05	3.07	0.02	0.08	0.33	0.00
Col150	11	-0.73	21.18	-0.25	3.32	1.05	3.07	0.03	0.08	0.31	0.00
Col150	12	-0.35	21.18	-0.25	3.32	1.05	3.07	0.02	0.08	0.33	0.00
Col150	13	-0.73	21.18	-0.25	3.32	1.05	3.07	0.03	0.08	0.31	0.00
Col150	14	-0.06	21.18	-0.25	3.32	1.05	3.07	0.00	0.08	0.34	0.00
Col150	15	-0.44	21.18	-0.25	3.32	1.05	3.07	0.02	0.08	0.32	0.00
Col150	16	1.09	8.34	-0.19	3.32	0.79	3.07	0.13	0.06	0.39	0.00
Col150	17	0.80	8.34	-0.19	3.32	0.79	3.07	0.10	0.06	0.35	0.00
Col150	18	0.87	8.34	-0.19	3.32	0.79	3.07	0.10	0.06	0.36	0.00
Col150	19	0.58	8.34	-0.19	3.32	0.79	3.07	0.07	0.06	0.33	0.00
Col150	20	0.74	8.34	-0.19	3.32	0.79	3.07	0.09	0.06	0.35	0.00
Col150	21	0.45	8.34	-0.19	3.32	0.79	3.07	0.05	0.06	0.31	0.00
Col150	22	0.52	8.34	-0.19	3.32	0.79	3.07	0.06	0.06	0.32	0.00
Col150	23	0.23	8.34	-0.19	3.32	0.79	3.07	0.03	0.06	0.29	0.00
Col150	24	0.74	8.34	-0.19	3.32	0.79	3.07	0.09	0.06	0.35	0.00
Col150	25	0.45	8.34	-0.19	3.32	0.79	3.07	0.05	0.06	0.31	0.00
Col150	26	0.52	8.34	-0.19	3.32	0.79	3.07	0.06	0.06	0.32	0.00
Col150	27	0.23	8.34	-0.19	3.32	0.79	3.07	0.03	0.06	0.29	0.00
Col150	28	-0.40	21.18	0.25	3.32	-1.05	3.07	0.02	0.08	0.32	0.00
Col150	29	-0.79	21.18	0.25	3.32	-1.05	3.07	0.04	0.08	0.31	0.00
Col150	30	-0.40	21.18	-0.25	3.32	1.05	3.07	0.02	0.08	0.32	0.00
Col150	31	-0.79	21.18	-0.25	3.32	1.05	3.07	0.04	0.08	0.31	0.00
Col150	32	-0.40	21.18	-0.25	3.32	1.05	3.07	0.02	0.08	0.32	0.00
Col150	33	-0.79	21.18	-0.25	3.32	1.05	3.07	0.04	0.08	0.31	0.00
Col150	34	-0.11	21.18	-0.25	3.32	1.05	3.07	0.01	0.08	0.34	0.00
Col150	35	-0.50	21.18	-0.25	3.32	1.05	3.07	0.02	0.08	0.32	0.00
Col150	36	0.23	8.34	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00

Col150	37	0.23	8.34	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col150	38	1.27	8.34	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col150	39	1.27	8.34	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col150	40	0.93	8.34	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col150	41	0.93	8.34	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col150	42	0.93	8.34	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col150	43	0.93	8.34	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col150	44	0.13	8.34	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col150	45	0.13	8.34	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col150	46	1.34	8.34	0.00	3.32	0.00	3.07	0.16	0.00	0.16	0.00
Col150	47	0.88	8.34	-0.19	3.32	0.79	3.07	0.11	0.06	0.36	0.00
Col150	48	0.59	8.34	-0.19	3.32	0.79	3.07	0.07	0.06	0.33	0.00
Col150	49	0.22	8.34	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col150	50	0.22	8.34	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col150	51	0.13	8.34	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col150	52	0.13	8.34	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col150	53	1.50	8.34	0.00	3.32	0.00	3.07	0.18	0.00	0.18	0.00
Col150	54	1.18	8.34	0.00	3.32	0.00	3.07	0.14	0.00	0.14	0.00
Col150	55	1.18	8.34	-0.19	3.32	0.79	3.07	0.14	0.06	0.40	0.00
Col150	56	1.18	8.34	0.00	3.32	0.00	3.07	0.14	0.00	0.14	0.00
Col151	1	1.62	8.44	0.00	3.32	0.00	3.07	0.19	0.00	0.19	0.00
Col151	2	0.22	8.44	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col151	3	1.16	8.44	0.00	3.32	0.00	3.07	0.14	0.00	0.14	0.00
Col151	4	1.16	8.44	0.00	3.32	0.00	3.07	0.14	0.00	0.14	0.00
Col151	5	1.27	8.44	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col151	6	0.92	8.44	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col151	7	0.92	8.44	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col151	8	-0.35	21.18	0.25	3.32	-1.03	3.07	0.02	0.07	0.32	0.00
Col151	9	-0.74	21.18	0.25	3.32	-1.03	3.07	0.03	0.07	0.30	0.00
Col151	10	-0.35	21.18	-0.25	3.32	1.03	3.07	0.02	0.07	0.32	0.00
Col151	11	-0.74	21.18	-0.25	3.32	1.03	3.07	0.03	0.07	0.30	0.00
Col151	12	-0.35	21.18	-0.25	3.32	1.03	3.07	0.02	0.07	0.32	0.00
Col151	13	-0.74	21.18	-0.25	3.32	1.03	3.07	0.03	0.07	0.30	0.00
Col151	14	-0.06	21.18	-0.25	3.32	1.03	3.07	0.00	0.07	0.33	0.00
Col151	15	-0.44	21.18	-0.25	3.32	1.03	3.07	0.02	0.07	0.31	0.00
Col151	16	1.09	8.44	-0.19	3.32	0.77	3.07	0.13	0.06	0.38	0.00
Col151	17	0.80	8.44	-0.19	3.32	0.77	3.07	0.09	0.06	0.35	0.00
Col151	18	0.87	8.44	-0.19	3.32	0.77	3.07	0.10	0.06	0.35	0.00
Col151	19	0.58	8.44	-0.19	3.32	0.77	3.07	0.07	0.06	0.32	0.00
Col151	20	0.74	8.44	-0.19	3.32	0.77	3.07	0.09	0.06	0.34	0.00
Col151	21	0.45	8.44	-0.19	3.32	0.77	3.07	0.05	0.06	0.30	0.00
Col151	22	0.52	8.44	-0.19	3.32	0.77	3.07	0.06	0.06	0.31	0.00
Col151	23	0.23	8.44	-0.19	3.32	0.77	3.07	0.03	0.06	0.28	0.00
Col151	24	0.74	8.44	-0.19	3.32	0.77	3.07	0.09	0.06	0.34	0.00
Col151	25	0.45	8.44	-0.19	3.32	0.77	3.07	0.05	0.06	0.30	0.00
Col151	26	0.52	8.44	-0.19	3.32	0.77	3.07	0.06	0.06	0.31	0.00
Col151	27	0.23	8.44	-0.19	3.32	0.77	3.07	0.03	0.06	0.28	0.00
Col151	28	-0.40	21.18	0.25	3.32	-1.03	3.07	0.02	0.07	0.32	0.00
Col151	29	-0.79	21.18	0.25	3.32	-1.03	3.07	0.04	0.07	0.30	0.00
Col151	30	-0.40	21.18	-0.25	3.32	1.03	3.07	0.02	0.07	0.32	0.00
Col151	31	-0.79	21.18	-0.25	3.32	1.03	3.07	0.04	0.07	0.30	0.00
Col151	32	-0.40	21.18	-0.25	3.32	1.03	3.07	0.02	0.07	0.32	0.00
Col151	33	-0.79	21.18	-0.25	3.32	1.03	3.07	0.04	0.07	0.30	0.00
Col151	34	-0.11	21.18	-0.25	3.32	1.03	3.07	0.01	0.07	0.33	0.00
Col151	35	-0.50	21.18	-0.25	3.32	1.03	3.07	0.02	0.07	0.31	0.00
Col151	36	0.23	8.44	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col151	37	0.23	8.44	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col151	38	1.27	8.44	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col151	39	1.27	8.44	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col151	40	0.93	8.44	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col151	41	0.93	8.44	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col151	42	0.93	8.44	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col151	43	0.93	8.44	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col151	44	0.13	8.44	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col151	45	0.13	8.44	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00

Col51	46	1.34	8.44	0.00	3.32	0.00	3.07	0.16	0.00	0.16	0.00
Col51	47	0.88	8.44	-0.19	3.32	0.77	3.07	0.10	0.06	0.35	0.00
Col51	48	0.59	8.44	-0.19	3.32	0.77	3.07	0.07	0.06	0.32	0.00
Col51	49	0.22	8.44	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col51	50	0.22	8.44	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col51	51	0.13	8.44	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col51	52	0.13	8.44	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col51	53	1.27	8.44	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col51	54	1.01	8.44	0.00	3.32	0.00	3.07	0.12	0.00	0.12	0.00
Col51	55	1.01	8.44	-0.19	3.32	0.77	3.07	0.12	0.06	0.37	0.00
Col51	56	1.01	8.44	0.00	3.32	0.00	3.07	0.12	0.00	0.12	0.00
Col52	1	1.62	8.55	0.00	3.32	0.00	3.07	0.19	0.00	0.19	0.00
Col52	2	0.22	8.55	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col52	3	1.16	8.55	0.00	3.32	0.00	3.07	0.14	0.00	0.14	0.00
Col52	4	1.16	8.55	0.00	3.32	0.00	3.07	0.14	0.00	0.14	0.00
Col52	5	1.27	8.55	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col52	6	0.92	8.55	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col52	7	0.92	8.55	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col52	8	-0.35	21.18	0.24	3.32	-1.00	3.07	0.02	0.07	0.31	0.00
Col52	9	-0.74	21.18	0.24	3.32	-1.00	3.07	0.03	0.07	0.29	0.00
Col52	10	-0.35	21.18	-0.24	3.32	1.00	3.07	0.02	0.07	0.31	0.00
Col52	11	-0.74	21.18	-0.24	3.32	1.00	3.07	0.03	0.07	0.29	0.00
Col52	12	-0.35	21.18	-0.24	3.32	1.00	3.07	0.02	0.07	0.31	0.00
Col52	13	-0.74	21.18	-0.24	3.32	1.00	3.07	0.03	0.07	0.29	0.00
Col52	14	-0.06	21.18	-0.24	3.32	1.00	3.07	0.00	0.07	0.32	0.00
Col52	15	-0.45	21.18	-0.24	3.32	1.00	3.07	0.02	0.07	0.30	0.00
Col52	16	1.09	8.55	-0.18	3.32	0.75	3.07	0.13	0.06	0.37	0.00
Col52	17	0.80	8.55	-0.18	3.32	0.75	3.07	0.09	0.06	0.34	0.00
Col52	18	0.87	8.55	-0.18	3.32	0.75	3.07	0.10	0.06	0.35	0.00
Col52	19	0.58	8.55	-0.18	3.32	0.75	3.07	0.07	0.06	0.31	0.00
Col52	20	0.74	8.55	-0.18	3.32	0.75	3.07	0.09	0.06	0.33	0.00
Col52	21	0.45	8.55	-0.18	3.32	0.75	3.07	0.05	0.06	0.30	0.00
Col52	22	0.52	8.55	-0.18	3.32	0.75	3.07	0.06	0.06	0.31	0.00
Col52	23	0.23	8.55	-0.18	3.32	0.75	3.07	0.03	0.06	0.27	0.00
Col52	24	0.74	8.55	-0.18	3.32	0.75	3.07	0.09	0.06	0.33	0.00
Col52	25	0.45	8.55	-0.18	3.32	0.75	3.07	0.05	0.06	0.30	0.00
Col52	26	0.52	8.55	-0.18	3.32	0.75	3.07	0.06	0.06	0.31	0.00
Col52	27	0.23	8.55	-0.18	3.32	0.75	3.07	0.03	0.06	0.27	0.00
Col52	28	-0.40	21.18	0.24	3.32	-1.00	3.07	0.02	0.07	0.31	0.00
Col52	29	-0.79	21.18	0.24	3.32	-1.00	3.07	0.04	0.07	0.29	0.00
Col52	30	-0.40	21.18	-0.24	3.32	1.00	3.07	0.02	0.07	0.31	0.00
Col52	31	-0.79	21.18	-0.24	3.32	1.00	3.07	0.04	0.07	0.29	0.00
Col52	32	-0.40	21.18	-0.24	3.32	1.00	3.07	0.02	0.07	0.31	0.00
Col52	33	-0.79	21.18	-0.24	3.32	1.00	3.07	0.04	0.07	0.29	0.00
Col52	34	-0.11	21.18	-0.24	3.32	1.00	3.07	0.01	0.07	0.32	0.00
Col52	35	-0.50	21.18	-0.24	3.32	1.00	3.07	0.02	0.07	0.30	0.00
Col52	36	0.23	8.55	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col52	37	0.23	8.55	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col52	38	1.27	8.55	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col52	39	1.27	8.55	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col52	40	0.93	8.55	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col52	41	0.93	8.55	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col52	42	0.93	8.55	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col52	43	0.93	8.55	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col52	44	0.12	8.55	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col52	45	0.12	8.55	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col52	46	1.34	8.55	0.00	3.32	0.00	3.07	0.16	0.00	0.16	0.00
Col52	47	0.88	8.55	-0.18	3.32	0.75	3.07	0.10	0.06	0.35	0.00
Col52	48	0.59	8.55	-0.18	3.32	0.75	3.07	0.07	0.06	0.31	0.00
Col52	49	0.22	8.55	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col52	50	0.22	8.55	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col52	51	0.13	8.55	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col52	52	0.13	8.55	0.00	3.32	0.00	3.07	0.02	0.00	0.02	0.00
Col52	53	1.16	8.55	0.00	3.32	0.00	3.07	0.14	0.00	0.14	0.00
Col52	54	0.93	8.55	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00

Col152	55	0.93	8.55	-0.18	3.32	0.75	3.07	0.11	0.06	0.35	0.00
Col152	56	0.93	8.55	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col153	1	1.62	8.65	0.00	3.32	0.00	3.07	0.19	0.00	0.19	0.00
Col153	2	0.22	8.65	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col153	3	1.16	8.65	0.00	3.32	0.00	3.07	0.13	0.00	0.13	0.00
Col153	4	1.16	8.65	0.00	3.32	0.00	3.07	0.13	0.00	0.13	0.00
Col153	5	1.27	8.65	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col153	6	0.92	8.65	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col153	7	0.92	8.65	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col153	8	-0.35	21.18	0.24	3.32	-0.98	3.07	0.02	0.07	0.30	0.00
Col153	9	-0.74	21.18	0.24	3.32	-0.98	3.07	0.03	0.07	0.28	0.00
Col153	10	-0.35	21.18	-0.24	3.32	0.98	3.07	0.02	0.07	0.30	0.00
Col153	11	-0.74	21.18	-0.24	3.32	0.98	3.07	0.03	0.07	0.28	0.00
Col153	12	-0.35	21.18	-0.24	3.32	0.98	3.07	0.02	0.07	0.30	0.00
Col153	13	-0.74	21.18	-0.24	3.32	0.98	3.07	0.03	0.07	0.28	0.00
Col153	14	-0.06	21.18	-0.24	3.32	0.98	3.07	0.00	0.07	0.31	0.00
Col153	15	-0.45	21.18	-0.24	3.32	0.98	3.07	0.02	0.07	0.30	0.00
Col153	16	1.09	8.65	-0.18	3.32	0.73	3.07	0.13	0.05	0.36	0.00
Col153	17	0.80	8.65	-0.18	3.32	0.73	3.07	0.09	0.05	0.33	0.00
Col153	18	0.87	8.65	-0.18	3.32	0.73	3.07	0.10	0.05	0.34	0.00
Col153	19	0.58	8.65	-0.18	3.32	0.73	3.07	0.07	0.05	0.31	0.00
Col153	20	0.74	8.65	-0.18	3.32	0.73	3.07	0.09	0.05	0.32	0.00
Col153	21	0.45	8.65	-0.18	3.32	0.73	3.07	0.05	0.05	0.29	0.00
Col153	22	0.52	8.65	-0.18	3.32	0.73	3.07	0.06	0.05	0.30	0.00
Col153	23	0.23	8.65	-0.18	3.32	0.73	3.07	0.03	0.05	0.27	0.00
Col153	24	0.74	8.65	-0.18	3.32	0.73	3.07	0.09	0.05	0.32	0.00
Col153	25	0.45	8.65	-0.18	3.32	0.73	3.07	0.05	0.05	0.29	0.00
Col153	26	0.52	8.65	-0.18	3.32	0.73	3.07	0.06	0.05	0.30	0.00
Col153	27	0.23	8.65	-0.18	3.32	0.73	3.07	0.03	0.05	0.27	0.00
Col153	28	-0.40	21.18	0.24	3.32	-0.98	3.07	0.02	0.07	0.30	0.00
Col153	29	-0.79	21.18	0.24	3.32	-0.98	3.07	0.04	0.07	0.28	0.00
Col153	30	-0.40	21.18	-0.24	3.32	0.98	3.07	0.02	0.07	0.30	0.00
Col153	31	-0.79	21.18	-0.24	3.32	0.98	3.07	0.04	0.07	0.28	0.00
Col153	32	-0.40	21.18	-0.24	3.32	0.98	3.07	0.02	0.07	0.30	0.00
Col153	33	-0.79	21.18	-0.24	3.32	0.98	3.07	0.04	0.07	0.28	0.00
Col153	34	-0.11	21.18	-0.24	3.32	0.98	3.07	0.01	0.07	0.31	0.00
Col153	35	-0.50	21.18	-0.24	3.32	0.98	3.07	0.02	0.07	0.29	0.00
Col153	36	0.22	8.65	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col153	37	0.22	8.65	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col153	38	1.27	8.65	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col153	39	1.27	8.65	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col153	40	0.93	8.65	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col153	41	0.93	8.65	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col153	42	0.93	8.65	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col153	43	0.93	8.65	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col153	44	0.12	8.65	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col153	45	0.12	8.65	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col153	46	1.34	8.65	0.00	3.32	0.00	3.07	0.15	0.00	0.15	0.00
Col153	47	0.88	8.65	-0.18	3.32	0.73	3.07	0.10	0.05	0.34	0.00
Col153	48	0.59	8.65	-0.18	3.32	0.73	3.07	0.07	0.05	0.31	0.00
Col153	49	0.22	8.65	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col153	50	0.22	8.65	0.00	3.32	0.00	3.07	0.03	0.00	0.03	0.00
Col153	51	0.13	8.65	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col153	52	0.13	8.65	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col153	53	1.16	8.65	0.00	3.32	0.00	3.07	0.13	0.00	0.13	0.00
Col153	54	0.93	8.65	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00
Col153	55	0.93	8.65	-0.18	3.32	0.73	3.07	0.11	0.05	0.35	0.00
Col153	56	0.93	8.65	0.00	3.32	0.00	3.07	0.11	0.00	0.11	0.00

COLUMN REACTIONS:

Id	Load		In_Plane		Out_Plane
	Id	Vert (k)	Horz (k)	Horz (k)	
Col142	1	1.62	0.00	0.00	

Col42	2	0.22	0.00	0.00
Col42	3	1.16	0.00	0.00
Col42	4	1.16	0.00	0.00
Col42	5	1.27	0.00	0.00
Col42	6	0.92	0.00	0.00
Col42	7	0.92	0.00	0.00
Col42	8	-0.74	0.00	-0.24
Col42	9	-0.35	0.00	-0.24
Col42	10	-0.74	0.00	0.24
Col42	11	-0.35	0.00	0.24
Col42	12	-0.74	0.00	0.24
Col42	13	-0.35	0.00	0.24
Col42	14	-0.45	0.00	0.24
Col42	15	-0.06	0.00	0.24
Col42	16	0.80	0.00	0.18
Col42	17	1.09	0.00	0.18
Col42	18	0.58	0.00	0.18
Col42	19	0.87	0.00	0.18
Col42	20	0.45	0.00	0.18
Col42	21	0.74	0.00	0.18
Col42	22	0.23	0.00	0.18
Col42	23	0.52	0.00	0.18
Col42	24	0.45	0.00	0.18
Col42	25	0.74	0.00	0.18
Col42	26	0.23	0.00	0.18
Col42	27	0.52	0.00	0.18
Col42	28	-0.79	0.00	-0.24
Col42	29	-0.40	0.00	-0.24
Col42	30	-0.79	0.00	0.24
Col42	31	-0.40	0.00	0.24
Col42	32	-0.79	0.00	0.24
Col42	33	-0.40	0.00	0.24
Col42	34	-0.50	0.00	0.24
Col42	35	-0.11	0.00	0.24
Col42	36	0.23	0.00	0.00
Col42	37	0.23	0.00	0.00
Col42	38	1.27	0.00	0.00
Col42	39	1.27	0.00	0.00
Col42	40	0.93	0.00	0.00
Col42	41	0.93	0.00	0.00
Col42	42	0.93	0.00	0.00
Col42	43	0.93	0.00	0.00
Col42	44	0.12	0.00	0.00
Col42	45	0.12	0.00	0.00
Col42	46	1.34	0.00	0.00
Col42	47	0.59	0.00	0.18
Col42	48	0.88	0.00	0.18
Col42	49	0.22	0.00	0.00
Col42	50	0.22	0.00	0.00
Col42	51	0.13	0.00	0.00
Col42	52	0.13	0.00	0.00
Col42	53	1.17	0.00	0.00
Col42	54	0.93	0.00	0.00
Col42	55	0.93	0.00	0.18
Col42	56	0.93	0.00	0.00
Col43	1	1.62	0.00	0.00
Col43	2	0.22	0.00	0.00
Col43	3	1.16	0.00	0.00
Col43	4	1.16	0.00	0.00
Col43	5	1.27	0.00	0.00
Col43	6	0.92	0.00	0.00
Col43	7	0.92	0.00	0.00
Col43	8	-0.74	0.00	-0.25
Col43	9	-0.35	0.00	-0.25
Col43	10	-0.74	0.00	0.25

Col43	11	-0.35	0.00	0.25
Col43	12	-0.74	0.00	0.25
Col43	13	-0.35	0.00	0.25
Col43	14	-0.44	0.00	0.25
Col43	15	-0.06	0.00	0.25
Col43	16	0.80	0.00	0.19
Col43	17	1.09	0.00	0.19
Col43	18	0.58	0.00	0.19
Col43	19	0.87	0.00	0.19
Col43	20	0.45	0.00	0.19
Col43	21	0.74	0.00	0.19
Col43	22	0.23	0.00	0.19
Col43	23	0.52	0.00	0.19
Col43	24	0.45	0.00	0.19
Col43	25	0.74	0.00	0.19
Col43	26	0.23	0.00	0.19
Col43	27	0.52	0.00	0.19
Col43	28	-0.79	0.00	-0.25
Col43	29	-0.40	0.00	-0.25
Col43	30	-0.79	0.00	0.25
Col43	31	-0.40	0.00	0.25
Col43	32	-0.79	0.00	0.25
Col43	33	-0.40	0.00	0.25
Col43	34	-0.50	0.00	0.25
Col43	35	-0.11	0.00	0.25
Col43	36	0.23	0.00	0.00
Col43	37	0.23	0.00	0.00
Col43	38	1.27	0.00	0.00
Col43	39	1.27	0.00	0.00
Col43	40	0.93	0.00	0.00
Col43	41	0.93	0.00	0.00
Col43	42	0.93	0.00	0.00
Col43	43	0.93	0.00	0.00
Col43	44	0.13	0.00	0.00
Col43	45	0.13	0.00	0.00
Col43	46	1.34	0.00	0.00
Col43	47	0.59	0.00	0.19
Col43	48	0.88	0.00	0.19
Col43	49	0.22	0.00	0.00
Col43	50	0.22	0.00	0.00
Col43	51	0.13	0.00	0.00
Col43	52	0.13	0.00	0.00
Col43	53	1.41	0.00	0.00
Col43	54	1.12	0.00	0.00
Col43	55	1.12	0.00	0.19
Col43	56	1.12	0.00	0.00
Col44	1	1.62	0.00	0.00
Col44	2	0.22	0.00	0.00
Col44	3	1.16	0.00	0.00
Col44	4	1.16	0.00	0.00
Col44	5	1.27	0.00	0.00
Col44	6	0.92	0.00	0.00
Col44	7	0.92	0.00	0.00
Col44	8	-0.73	0.00	-0.25
Col44	9	-0.35	0.00	-0.25
Col44	10	-0.73	0.00	0.25
Col44	11	-0.35	0.00	0.25
Col44	12	-0.73	0.00	0.25
Col44	13	-0.35	0.00	0.25
Col44	14	-0.44	0.00	0.25
Col44	15	-0.06	0.00	0.25
Col44	16	0.80	0.00	0.19
Col44	17	1.09	0.00	0.19
Col44	18	0.58	0.00	0.19
Col44	19	0.87	0.00	0.19

Col144	20	0.45	0.00	0.19
Col144	21	0.74	0.00	0.19
Col144	22	0.23	0.00	0.19
Col144	23	0.52	0.00	0.19
Col144	24	0.45	0.00	0.19
Col144	25	0.74	0.00	0.19
Col144	26	0.23	0.00	0.19
Col144	27	0.52	0.00	0.19
Col144	28	-0.79	0.00	-0.25
Col144	29	-0.40	0.00	-0.25
Col144	30	-0.79	0.00	0.25
Col144	31	-0.40	0.00	0.25
Col144	32	-0.79	0.00	0.25
Col144	33	-0.40	0.00	0.25
Col144	34	-0.50	0.00	0.25
Col144	35	-0.11	0.00	0.25
Col144	36	0.23	0.00	0.00
Col144	37	0.23	0.00	0.00
Col144	38	1.27	0.00	0.00
Col144	39	1.27	0.00	0.00
Col144	40	0.93	0.00	0.00
Col144	41	0.93	0.00	0.00
Col144	42	0.93	0.00	0.00
Col144	43	0.93	0.00	0.00
Col144	44	0.13	0.00	0.00
Col144	45	0.13	0.00	0.00
Col144	46	1.34	0.00	0.00
Col144	47	0.59	0.00	0.19
Col144	48	0.88	0.00	0.19
Col144	49	0.22	0.00	0.00
Col144	50	0.22	0.00	0.00
Col144	51	0.13	0.00	0.00
Col144	52	0.13	0.00	0.00
Col144	53	1.54	0.00	0.00
Col144	54	1.21	0.00	0.00
Col144	55	1.21	0.00	0.19
Col144	56	1.21	0.00	0.00
Col145	1	1.62	0.00	0.00
Col145	2	0.22	0.00	0.00
Col145	3	1.16	0.00	0.00
Col145	4	1.16	0.00	0.00
Col145	5	1.27	0.00	0.00
Col145	6	0.92	0.00	0.00
Col145	7	0.92	0.00	0.00
Col145	8	-0.73	0.00	-0.25
Col145	9	-0.35	0.00	-0.25
Col145	10	-0.73	0.00	0.25
Col145	11	-0.35	0.00	0.25
Col145	12	-0.73	0.00	0.25
Col145	13	-0.35	0.00	0.25
Col145	14	-0.44	0.00	0.25
Col145	15	-0.06	0.00	0.25
Col145	16	0.80	0.00	0.19
Col145	17	1.09	0.00	0.19
Col145	18	0.58	0.00	0.19
Col145	19	0.87	0.00	0.19
Col145	20	0.45	0.00	0.19
Col145	21	0.74	0.00	0.19
Col145	22	0.23	0.00	0.19
Col145	23	0.53	0.00	0.19
Col145	24	0.45	0.00	0.19
Col145	25	0.74	0.00	0.19
Col145	26	0.23	0.00	0.19
Col145	27	0.53	0.00	0.19
Col145	28	-0.79	0.00	-0.25

Col45	29	-0.40	0.00	-0.25
Col45	30	-0.79	0.00	0.25
Col45	31	-0.40	0.00	0.25
Col45	32	-0.79	0.00	0.25
Col45	33	-0.40	0.00	0.25
Col45	34	-0.50	0.00	0.25
Col45	35	-0.11	0.00	0.25
Col45	36	0.23	0.00	0.00
Col45	37	0.23	0.00	0.00
Col45	38	1.28	0.00	0.00
Col45	39	1.27	0.00	0.00
Col45	40	0.93	0.00	0.00
Col45	41	0.93	0.00	0.00
Col45	42	0.93	0.00	0.00
Col45	43	0.93	0.00	0.00
Col45	44	0.13	0.00	0.00
Col45	45	0.13	0.00	0.00
Col45	46	1.34	0.00	0.00
Col45	47	0.59	0.00	0.19
Col45	48	0.88	0.00	0.19
Col45	49	0.22	0.00	0.00
Col45	50	0.22	0.00	0.00
Col45	51	0.13	0.00	0.00
Col45	52	0.13	0.00	0.00
Col45	53	1.54	0.00	0.00
Col45	54	1.21	0.00	0.00
Col45	55	1.21	0.00	0.19
Col45	56	1.21	0.00	0.00
Col46	1	1.62	0.00	0.00
Col46	2	0.22	0.00	0.00
Col46	3	1.16	0.00	0.00
Col46	4	1.16	0.00	0.00
Col46	5	1.27	0.00	0.00
Col46	6	0.93	0.00	0.00
Col46	7	0.93	0.00	0.00
Col46	8	-0.73	0.00	-0.26
Col46	9	-0.35	0.00	-0.26
Col46	10	-0.73	0.00	0.26
Col46	11	-0.35	0.00	0.26
Col46	12	-0.73	0.00	0.26
Col46	13	-0.35	0.00	0.26
Col46	14	-0.44	0.00	0.26
Col46	15	-0.06	0.00	0.26
Col46	16	0.80	0.00	0.19
Col46	17	1.09	0.00	0.19
Col46	18	0.58	0.00	0.19
Col46	19	0.87	0.00	0.19
Col46	20	0.45	0.00	0.19
Col46	21	0.74	0.00	0.19
Col46	22	0.23	0.00	0.19
Col46	23	0.53	0.00	0.19
Col46	24	0.45	0.00	0.19
Col46	25	0.74	0.00	0.19
Col46	26	0.23	0.00	0.19
Col46	27	0.53	0.00	0.19
Col46	28	-0.79	0.00	-0.26
Col46	29	-0.40	0.00	-0.26
Col46	30	-0.79	0.00	0.26
Col46	31	-0.40	0.00	0.26
Col46	32	-0.79	0.00	0.26
Col46	33	-0.40	0.00	0.26
Col46	34	-0.50	0.00	0.26
Col46	35	-0.11	0.00	0.26
Col46	36	0.23	0.00	0.00
Col46	37	0.23	0.00	0.00

Col46	38	1.28	0.00	0.00
Col46	39	1.28	0.00	0.00
Col46	40	0.93	0.00	0.00
Col46	41	0.93	0.00	0.00
Col46	42	0.93	0.00	0.00
Col46	43	0.93	0.00	0.00
Col46	44	0.13	0.00	0.00
Col46	45	0.13	0.00	0.00
Col46	46	1.34	0.00	0.00
Col46	47	0.59	0.00	0.19
Col46	48	0.88	0.00	0.19
Col46	49	0.22	0.00	0.00
Col46	50	0.22	0.00	0.00
Col46	51	0.13	0.00	0.00
Col46	52	0.13	0.00	0.00
Col46	53	1.54	0.00	0.00
Col46	54	1.21	0.00	0.00
Col46	55	1.21	0.00	0.19
Col46	56	1.21	0.00	0.00
Col47	1	1.62	0.00	0.00
Col47	2	0.22	0.00	0.00
Col47	3	1.16	0.00	0.00
Col47	4	1.16	0.00	0.00
Col47	5	1.27	0.00	0.00
Col47	6	0.93	0.00	0.00
Col47	7	0.93	0.00	0.00
Col47	8	-0.53	0.00	-0.26
Col47	9	-0.53	0.00	-0.26
Col47	10	-0.53	0.00	0.26
Col47	11	-0.53	0.00	0.26
Col47	12	-0.53	0.00	0.26
Col47	13	-0.53	0.00	0.26
Col47	14	-0.24	0.00	0.26
Col47	15	-0.24	0.00	0.26
Col47	16	0.95	0.00	0.19
Col47	17	0.95	0.00	0.19
Col47	18	0.74	0.00	0.19
Col47	19	0.74	0.00	0.19
Col47	20	0.60	0.00	0.19
Col47	21	0.60	0.00	0.19
Col47	22	0.39	0.00	0.19
Col47	23	0.39	0.00	0.19
Col47	24	0.60	0.00	0.19
Col47	25	0.60	0.00	0.19
Col47	26	0.39	0.00	0.19
Col47	27	0.39	0.00	0.19
Col47	28	-0.58	0.00	-0.26
Col47	29	-0.58	0.00	-0.26
Col47	30	-0.58	0.00	0.26
Col47	31	-0.58	0.00	0.26
Col47	32	-0.58	0.00	0.26
Col47	33	-0.58	0.00	0.26
Col47	34	-0.30	0.00	0.26
Col47	35	-0.30	0.00	0.26
Col47	36	0.23	0.00	0.00
Col47	37	0.23	0.00	0.00
Col47	38	1.27	0.00	0.00
Col47	39	1.27	0.00	0.00
Col47	40	0.93	0.00	0.00
Col47	41	0.93	0.00	0.00
Col47	42	0.93	0.00	0.00
Col47	43	0.93	0.00	0.00
Col47	44	0.13	0.00	0.00
Col47	45	0.13	0.00	0.00
Col47	46	1.32	0.00	0.00

Col47	47	0.72	0.00	0.19
Col47	48	0.72	0.00	0.19
Col47	49	0.22	0.00	0.00
Col47	50	0.22	0.00	0.00
Col47	51	0.13	0.00	0.00
Col47	52	0.13	0.00	0.00
Col47	53	1.50	0.00	0.00
Col47	54	1.18	0.00	0.00
Col47	55	1.18	0.00	0.19
Col47	56	1.18	0.00	0.00
Col48	1	1.62	0.00	0.00
Col48	2	0.22	0.00	0.00
Col48	3	1.16	0.00	0.00
Col48	4	1.16	0.00	0.00
Col48	5	1.27	0.00	0.00
Col48	6	0.93	0.00	0.00
Col48	7	0.93	0.00	0.00
Col48	8	-0.35	0.00	-0.26
Col48	9	-0.73	0.00	-0.26
Col48	10	-0.35	0.00	0.26
Col48	11	-0.73	0.00	0.26
Col48	12	-0.35	0.00	0.26
Col48	13	-0.73	0.00	0.26
Col48	14	-0.06	0.00	0.26
Col48	15	-0.44	0.00	0.26
Col48	16	1.09	0.00	0.19
Col48	17	0.80	0.00	0.19
Col48	18	0.87	0.00	0.19
Col48	19	0.58	0.00	0.19
Col48	20	0.74	0.00	0.19
Col48	21	0.45	0.00	0.19
Col48	22	0.53	0.00	0.19
Col48	23	0.23	0.00	0.19
Col48	24	0.74	0.00	0.19
Col48	25	0.45	0.00	0.19
Col48	26	0.53	0.00	0.19
Col48	27	0.23	0.00	0.19
Col48	28	-0.40	0.00	-0.26
Col48	29	-0.79	0.00	-0.26
Col48	30	-0.40	0.00	0.26
Col48	31	-0.79	0.00	0.26
Col48	32	-0.40	0.00	0.26
Col48	33	-0.79	0.00	0.26
Col48	34	-0.11	0.00	0.26
Col48	35	-0.50	0.00	0.26
Col48	36	0.23	0.00	0.00
Col48	37	0.23	0.00	0.00
Col48	38	1.28	0.00	0.00
Col48	39	1.28	0.00	0.00
Col48	40	0.93	0.00	0.00
Col48	41	0.93	0.00	0.00
Col48	42	0.93	0.00	0.00
Col48	43	0.93	0.00	0.00
Col48	44	0.13	0.00	0.00
Col48	45	0.13	0.00	0.00
Col48	46	1.34	0.00	0.00
Col48	47	0.88	0.00	0.19
Col48	48	0.59	0.00	0.19
Col48	49	0.22	0.00	0.00
Col48	50	0.22	0.00	0.00
Col48	51	0.13	0.00	0.00
Col48	52	0.13	0.00	0.00
Col48	53	1.51	0.00	0.00
Col48	54	1.19	0.00	0.00
Col48	55	1.19	0.00	0.19

Col148	56	1.19	0.00	0.00
Col149	1	1.62	0.00	0.00
Col149	2	0.22	0.00	0.00
Col149	3	1.16	0.00	0.00
Col149	4	1.16	0.00	0.00
Col149	5	1.27	0.00	0.00
Col149	6	0.92	0.00	0.00
Col149	7	0.92	0.00	0.00
Col149	8	-0.35	0.00	-0.25
Col149	9	-0.73	0.00	-0.25
Col149	10	-0.35	0.00	0.25
Col149	11	-0.73	0.00	0.25
Col149	12	-0.35	0.00	0.25
Col149	13	-0.73	0.00	0.25
Col149	14	-0.06	0.00	0.25
Col149	15	-0.44	0.00	0.25
Col149	16	1.09	0.00	0.19
Col149	17	0.80	0.00	0.19
Col149	18	0.87	0.00	0.19
Col149	19	0.58	0.00	0.19
Col149	20	0.74	0.00	0.19
Col149	21	0.45	0.00	0.19
Col149	22	0.53	0.00	0.19
Col149	23	0.23	0.00	0.19
Col149	24	0.74	0.00	0.19
Col149	25	0.45	0.00	0.19
Col149	26	0.53	0.00	0.19
Col149	27	0.23	0.00	0.19
Col149	28	-0.40	0.00	-0.25
Col149	29	-0.79	0.00	-0.25
Col149	30	-0.40	0.00	0.25
Col149	31	-0.79	0.00	0.25
Col149	32	-0.40	0.00	0.25
Col149	33	-0.79	0.00	0.25
Col149	34	-0.11	0.00	0.25
Col149	35	-0.50	0.00	0.25
Col149	36	0.23	0.00	0.00
Col149	37	0.23	0.00	0.00
Col149	38	1.27	0.00	0.00
Col149	39	1.28	0.00	0.00
Col149	40	0.93	0.00	0.00
Col149	41	0.93	0.00	0.00
Col149	42	0.93	0.00	0.00
Col149	43	0.93	0.00	0.00
Col149	44	0.13	0.00	0.00
Col149	45	0.13	0.00	0.00
Col149	46	1.34	0.00	0.00
Col149	47	0.88	0.00	0.19
Col149	48	0.59	0.00	0.19
Col149	49	0.22	0.00	0.00
Col149	50	0.22	0.00	0.00
Col149	51	0.13	0.00	0.00
Col149	52	0.13	0.00	0.00
Col149	53	1.51	0.00	0.00
Col149	54	1.19	0.00	0.00
Col149	55	1.19	0.00	0.19
Col149	56	1.19	0.00	0.00
Col150	1	1.62	0.00	0.00
Col150	2	0.22	0.00	0.00
Col150	3	1.16	0.00	0.00
Col150	4	1.16	0.00	0.00
Col150	5	1.27	0.00	0.00
Col150	6	0.92	0.00	0.00
Col150	7	0.92	0.00	0.00
Col150	8	-0.35	0.00	-0.25

Col50	9	-0.73	0.00	-0.25
Col50	10	-0.35	0.00	0.25
Col50	11	-0.73	0.00	0.25
Col50	12	-0.35	0.00	0.25
Col50	13	-0.73	0.00	0.25
Col50	14	-0.06	0.00	0.25
Col50	15	-0.44	0.00	0.25
Col50	16	1.09	0.00	0.19
Col50	17	0.80	0.00	0.19
Col50	18	0.87	0.00	0.19
Col50	19	0.58	0.00	0.19
Col50	20	0.74	0.00	0.19
Col50	21	0.45	0.00	0.19
Col50	22	0.52	0.00	0.19
Col50	23	0.23	0.00	0.19
Col50	24	0.74	0.00	0.19
Col50	25	0.45	0.00	0.19
Col50	26	0.52	0.00	0.19
Col50	27	0.23	0.00	0.19
Col50	28	-0.40	0.00	-0.25
Col50	29	-0.79	0.00	-0.25
Col50	30	-0.40	0.00	0.25
Col50	31	-0.79	0.00	0.25
Col50	32	-0.40	0.00	0.25
Col50	33	-0.79	0.00	0.25
Col50	34	-0.11	0.00	0.25
Col50	35	-0.50	0.00	0.25
Col50	36	0.23	0.00	0.00
Col50	37	0.23	0.00	0.00
Col50	38	1.27	0.00	0.00
Col50	39	1.27	0.00	0.00
Col50	40	0.93	0.00	0.00
Col50	41	0.93	0.00	0.00
Col50	42	0.93	0.00	0.00
Col50	43	0.93	0.00	0.00
Col50	44	0.13	0.00	0.00
Col50	45	0.13	0.00	0.00
Col50	46	1.34	0.00	0.00
Col50	47	0.88	0.00	0.19
Col50	48	0.59	0.00	0.19
Col50	49	0.22	0.00	0.00
Col50	50	0.22	0.00	0.00
Col50	51	0.13	0.00	0.00
Col50	52	0.13	0.00	0.00
Col50	53	1.50	0.00	0.00
Col50	54	1.18	0.00	0.00
Col50	55	1.18	0.00	0.19
Col50	56	1.18	0.00	0.00
Col51	1	1.62	0.00	0.00
Col51	2	0.22	0.00	0.00
Col51	3	1.16	0.00	0.00
Col51	4	1.16	0.00	0.00
Col51	5	1.27	0.00	0.00
Col51	6	0.92	0.00	0.00
Col51	7	0.92	0.00	0.00
Col51	8	-0.35	0.00	-0.25
Col51	9	-0.74	0.00	-0.25
Col51	10	-0.35	0.00	0.25
Col51	11	-0.74	0.00	0.25
Col51	12	-0.35	0.00	0.25
Col51	13	-0.74	0.00	0.25
Col51	14	-0.06	0.00	0.25
Col51	15	-0.44	0.00	0.25
Col51	16	1.09	0.00	0.19
Col51	17	0.80	0.00	0.19

Col51	18	0.87	0.00	0.19
Col51	19	0.58	0.00	0.19
Col51	20	0.74	0.00	0.19
Col51	21	0.45	0.00	0.19
Col51	22	0.52	0.00	0.19
Col51	23	0.23	0.00	0.19
Col51	24	0.74	0.00	0.19
Col51	25	0.45	0.00	0.19
Col51	26	0.52	0.00	0.19
Col51	27	0.23	0.00	0.19
Col51	28	-0.40	0.00	-0.25
Col51	29	-0.79	0.00	-0.25
Col51	30	-0.40	0.00	0.25
Col51	31	-0.79	0.00	0.25
Col51	32	-0.40	0.00	0.25
Col51	33	-0.79	0.00	0.25
Col51	34	-0.11	0.00	0.25
Col51	35	-0.50	0.00	0.25
Col51	36	0.23	0.00	0.00
Col51	37	0.23	0.00	0.00
Col51	38	1.27	0.00	0.00
Col51	39	1.27	0.00	0.00
Col51	40	0.93	0.00	0.00
Col51	41	0.93	0.00	0.00
Col51	42	0.93	0.00	0.00
Col51	43	0.93	0.00	0.00
Col51	44	0.13	0.00	0.00
Col51	45	0.13	0.00	0.00
Col51	46	1.34	0.00	0.00
Col51	47	0.88	0.00	0.19
Col51	48	0.59	0.00	0.19
Col51	49	0.22	0.00	0.00
Col51	50	0.22	0.00	0.00
Col51	51	0.13	0.00	0.00
Col51	52	0.13	0.00	0.00
Col51	53	1.27	0.00	0.00
Col51	54	1.01	0.00	0.00
Col51	55	1.01	0.00	0.19
Col51	56	1.01	0.00	0.00
Col52	1	1.62	0.00	0.00
Col52	2	0.22	0.00	0.00
Col52	3	1.16	0.00	0.00
Col52	4	1.16	0.00	0.00
Col52	5	1.27	0.00	0.00
Col52	6	0.92	0.00	0.00
Col52	7	0.92	0.00	0.00
Col52	8	-0.35	0.00	-0.24
Col52	9	-0.74	0.00	-0.24
Col52	10	-0.35	0.00	0.24
Col52	11	-0.74	0.00	0.24
Col52	12	-0.35	0.00	0.24
Col52	13	-0.74	0.00	0.24
Col52	14	-0.06	0.00	0.24
Col52	15	-0.45	0.00	0.24
Col52	16	1.09	0.00	0.18
Col52	17	0.80	0.00	0.18
Col52	18	0.87	0.00	0.18
Col52	19	0.58	0.00	0.18
Col52	20	0.74	0.00	0.18
Col52	21	0.45	0.00	0.18
Col52	22	0.52	0.00	0.18
Col52	23	0.23	0.00	0.18
Col52	24	0.74	0.00	0.18
Col52	25	0.45	0.00	0.18
Col52	26	0.52	0.00	0.18

Col52	27	0.23	0.00	0.18
Col52	28	-0.40	0.00	-0.24
Col52	29	-0.79	0.00	-0.24
Col52	30	-0.40	0.00	0.24
Col52	31	-0.79	0.00	0.24
Col52	32	-0.40	0.00	0.24
Col52	33	-0.79	0.00	0.24
Col52	34	-0.11	0.00	0.24
Col52	35	-0.50	0.00	0.24
Col52	36	0.23	0.00	0.00
Col52	37	0.23	0.00	0.00
Col52	38	1.27	0.00	0.00
Col52	39	1.27	0.00	0.00
Col52	40	0.93	0.00	0.00
Col52	41	0.93	0.00	0.00
Col52	42	0.93	0.00	0.00
Col52	43	0.93	0.00	0.00
Col52	44	0.12	0.00	0.00
Col52	45	0.12	0.00	0.00
Col52	46	1.34	0.00	0.00
Col52	47	0.88	0.00	0.18
Col52	48	0.59	0.00	0.18
Col52	49	0.22	0.00	0.00
Col52	50	0.22	0.00	0.00
Col52	51	0.13	0.00	0.00
Col52	52	0.13	0.00	0.00
Col52	53	1.16	0.00	0.00
Col52	54	0.93	0.00	0.00
Col52	55	0.93	0.00	0.18
Col52	56	0.93	0.00	0.00
Col53	1	1.62	0.00	0.00
Col53	2	0.22	0.00	0.00
Col53	3	1.16	0.00	0.00
Col53	4	1.16	0.00	0.00
Col53	5	1.27	0.00	0.00
Col53	6	0.92	0.00	0.00
Col53	7	0.92	0.00	0.00
Col53	8	-0.35	0.00	-0.24
Col53	9	-0.74	0.00	-0.24
Col53	10	-0.35	0.00	0.24
Col53	11	-0.74	0.00	0.24
Col53	12	-0.35	0.00	0.24
Col53	13	-0.74	0.00	0.24
Col53	14	-0.06	0.00	0.24
Col53	15	-0.45	0.00	0.24
Col53	16	1.09	0.00	0.18
Col53	17	0.80	0.00	0.18
Col53	18	0.87	0.00	0.18
Col53	19	0.58	0.00	0.18
Col53	20	0.74	0.00	0.18
Col53	21	0.45	0.00	0.18
Col53	22	0.52	0.00	0.18
Col53	23	0.23	0.00	0.18
Col53	24	0.74	0.00	0.18
Col53	25	0.45	0.00	0.18
Col53	26	0.52	0.00	0.18
Col53	27	0.23	0.00	0.18
Col53	28	-0.40	0.00	-0.24
Col53	29	-0.79	0.00	-0.24
Col53	30	-0.40	0.00	0.24
Col53	31	-0.79	0.00	0.24
Col53	32	-0.40	0.00	0.24
Col53	33	-0.79	0.00	0.24
Col53	34	-0.11	0.00	0.24
Col53	35	-0.50	0.00	0.24

Col53	36	0.22	0.00	0.00
Col53	37	0.22	0.00	0.00
Col53	38	1.27	0.00	0.00
Col53	39	1.27	0.00	0.00
Col53	40	0.93	0.00	0.00
Col53	41	0.93	0.00	0.00
Col53	42	0.93	0.00	0.00
Col53	43	0.93	0.00	0.00
Col53	44	0.12	0.00	0.00
Col53	45	0.12	0.00	0.00
Col53	46	1.34	0.00	0.00
Col53	47	0.88	0.00	0.18
Col53	48	0.59	0.00	0.18
Col53	49	0.22	0.00	0.00
Col53	50	0.22	0.00	0.00
Col53	51	0.13	0.00	0.00
Col53	52	0.13	0.00	0.00
Col53	53	1.16	0.00	0.00
Col53	54	0.93	0.00	0.00
Col53	55	0.93	0.00	0.18
Col53	56	0.93	0.00	0.00

COLUMN DEFLECTIONS:

Load		Deflection(in)	
Id	Id	Calc	Limit
-----	----	-----	-----
Col42	1	0.00	1.09
Col42	2	0.00	1.09
Col42	3	0.00	1.09
Col42	4	0.00	1.09
Col42	5	0.00	1.09
Col42	6	0.00	1.09
Col42	7	0.00	1.09
Col42	8	-0.43	1.09
Col42	9	-0.43	1.09
Col42	10	0.43	1.09
Col42	11	0.43	1.09
Col42	12	0.43	1.09
Col42	13	0.43	1.09
Col42	14	0.43	1.09
Col42	15	0.43	1.09
Col42	16	0.33	1.09
Col42	17	0.33	1.09
Col42	18	0.33	1.09
Col42	19	0.33	1.09
Col42	20	0.33	1.09
Col42	21	0.33	1.09
Col42	22	0.33	1.09
Col42	23	0.33	1.09
Col42	24	0.33	1.09
Col42	25	0.33	1.09
Col42	26	0.33	1.09
Col42	27	0.33	1.09
Col42	28	-0.43	1.09
Col42	29	-0.43	1.09
Col42	30	0.43	1.09
Col42	31	0.43	1.09
Col42	32	0.43	1.09
Col42	33	0.43	1.09
Col42	34	0.43	1.09
Col42	35	0.43	1.09
Col42	36	0.00	1.09
Col42	37	0.00	1.09
Col42	38	0.00	1.09

Col42	39	0.00	1.09
Col42	40	0.00	1.09
Col42	41	0.00	1.09
Col42	42	0.00	1.09
Col42	43	0.00	1.09
Col42	44	0.00	1.09
Col42	45	0.00	1.09
Col42	46	0.00	1.09
Col42	47	0.20	1.09
Col42	48	0.20	1.09
Col42	49	0.00	1.09
Col42	50	0.00	1.09
Col42	51	0.33	1.09
Col42	52	0.00	1.09
Col43	1	0.00	1.10
Col43	2	0.00	1.10
Col43	3	0.00	1.10
Col43	4	0.00	1.10
Col43	5	0.00	1.10
Col43	6	0.00	1.10
Col43	7	0.00	1.10
Col43	8	-0.46	1.10
Col43	9	-0.46	1.10
Col43	10	0.46	1.10
Col43	11	0.46	1.10
Col43	12	0.46	1.10
Col43	13	0.46	1.10
Col43	14	0.46	1.10
Col43	15	0.46	1.10
Col43	16	0.34	1.10
Col43	17	0.34	1.10
Col43	18	0.34	1.10
Col43	19	0.34	1.10
Col43	20	0.34	1.10
Col43	21	0.34	1.10
Col43	22	0.34	1.10
Col43	23	0.34	1.10
Col43	24	0.34	1.10
Col43	25	0.34	1.10
Col43	26	0.34	1.10
Col43	27	0.34	1.10
Col43	28	-0.46	1.10
Col43	29	-0.46	1.10
Col43	30	0.46	1.10
Col43	31	0.46	1.10
Col43	32	0.46	1.10
Col43	33	0.46	1.10
Col43	34	0.46	1.10
Col43	35	0.46	1.10
Col43	36	0.00	1.10
Col43	37	0.00	1.10
Col43	38	0.00	1.10
Col43	39	0.00	1.10
Col43	40	0.00	1.10
Col43	41	0.00	1.10
Col43	42	0.00	1.10
Col43	43	0.00	1.10
Col43	44	0.00	1.10
Col43	45	0.00	1.10
Col43	46	0.00	1.10
Col43	47	0.21	1.10
Col43	48	0.21	1.10
Col43	49	0.00	1.10
Col43	50	0.00	1.10
Col43	51	0.34	1.10

Col43	52	0.00	1.10
Col44	1	0.00	1.12
Col44	2	0.00	1.12
Col44	3	0.00	1.12
Col44	4	0.00	1.12
Col44	5	0.00	1.12
Col44	6	0.00	1.12
Col44	7	0.00	1.12
Col44	8	-0.48	1.12
Col44	9	-0.48	1.12
Col44	10	0.48	1.12
Col44	11	0.48	1.12
Col44	12	0.48	1.12
Col44	13	0.48	1.12
Col44	14	0.48	1.12
Col44	15	0.48	1.12
Col44	16	0.36	1.12
Col44	17	0.36	1.12
Col44	18	0.36	1.12
Col44	19	0.36	1.12
Col44	20	0.36	1.12
Col44	21	0.36	1.12
Col44	22	0.36	1.12
Col44	23	0.36	1.12
Col44	24	0.36	1.12
Col44	25	0.36	1.12
Col44	26	0.36	1.12
Col44	27	0.36	1.12
Col44	28	-0.48	1.12
Col44	29	-0.48	1.12
Col44	30	0.48	1.12
Col44	31	0.48	1.12
Col44	32	0.48	1.12
Col44	33	0.48	1.12
Col44	34	0.48	1.12
Col44	35	0.48	1.12
Col44	36	0.00	1.12
Col44	37	0.00	1.12
Col44	38	0.00	1.12
Col44	39	0.00	1.12
Col44	40	0.00	1.12
Col44	41	0.00	1.12
Col44	42	0.00	1.12
Col44	43	0.00	1.12
Col44	44	0.00	1.12
Col44	45	0.00	1.12
Col44	46	0.00	1.12
Col44	47	0.22	1.12
Col44	48	0.22	1.12
Col44	49	0.00	1.12
Col44	50	0.00	1.12
Col44	51	0.36	1.12
Col44	52	0.00	1.12
Col45	1	0.00	1.13
Col45	2	0.00	1.13
Col45	3	0.00	1.13
Col45	4	0.00	1.13
Col45	5	0.00	1.13
Col45	6	0.00	1.13
Col45	7	0.00	1.13
Col45	8	-0.50	1.13
Col45	9	-0.50	1.13
Col45	10	0.50	1.13
Col45	11	0.50	1.13
Col45	12	0.50	1.13

Col45	13	0.50	1.13
Col45	14	0.50	1.13
Col45	15	0.50	1.13
Col45	16	0.38	1.13
Col45	17	0.38	1.13
Col45	18	0.38	1.13
Col45	19	0.38	1.13
Col45	20	0.38	1.13
Col45	21	0.38	1.13
Col45	22	0.38	1.13
Col45	23	0.38	1.13
Col45	24	0.38	1.13
Col45	25	0.38	1.13
Col45	26	0.38	1.13
Col45	27	0.38	1.13
Col45	28	-0.50	1.13
Col45	29	-0.50	1.13
Col45	30	0.50	1.13
Col45	31	0.50	1.13
Col45	32	0.50	1.13
Col45	33	0.50	1.13
Col45	34	0.50	1.13
Col45	35	0.50	1.13
Col45	36	0.00	1.13
Col45	37	0.00	1.13
Col45	38	0.00	1.13
Col45	39	0.00	1.13
Col45	40	0.00	1.13
Col45	41	0.00	1.13
Col45	42	0.00	1.13
Col45	43	0.00	1.13
Col45	44	0.00	1.13
Col45	45	0.00	1.13
Col45	46	0.00	1.13
Col45	47	0.23	1.13
Col45	48	0.23	1.13
Col45	49	0.00	1.13
Col45	50	0.00	1.13
Col45	51	0.38	1.13
Col45	52	0.00	1.13
Col46	1	0.00	1.14
Col46	2	0.00	1.14
Col46	3	0.00	1.14
Col46	4	0.00	1.14
Col46	5	0.00	1.14
Col46	6	0.00	1.14
Col46	7	0.00	1.14
Col46	8	-0.53	1.14
Col46	9	-0.53	1.14
Col46	10	0.53	1.14
Col46	11	0.53	1.14
Col46	12	0.53	1.14
Col46	13	0.53	1.14
Col46	14	0.53	1.14
Col46	15	0.53	1.14
Col46	16	0.40	1.14
Col46	17	0.40	1.14
Col46	18	0.40	1.14
Col46	19	0.40	1.14
Col46	20	0.40	1.14
Col46	21	0.40	1.14
Col46	22	0.40	1.14
Col46	23	0.40	1.14
Col46	24	0.40	1.14
Col46	25	0.40	1.14

Col46	26	0.40	1.14
Col46	27	0.40	1.14
Col46	28	-0.53	1.14
Col46	29	-0.53	1.14
Col46	30	0.53	1.14
Col46	31	0.53	1.14
Col46	32	0.53	1.14
Col46	33	0.53	1.14
Col46	34	0.53	1.14
Col46	35	0.53	1.14
Col46	36	0.00	1.14
Col46	37	0.00	1.14
Col46	38	0.00	1.14
Col46	39	0.00	1.14
Col46	40	0.00	1.14
Col46	41	0.00	1.14
Col46	42	0.00	1.14
Col46	43	0.00	1.14
Col46	44	0.00	1.14
Col46	45	0.00	1.14
Col46	46	0.00	1.14
Col46	47	0.24	1.14
Col46	48	0.24	1.14
Col46	49	0.00	1.14
Col46	50	0.00	1.14
Col46	51	0.40	1.14
Col46	52	0.00	1.14
Col47	1	0.00	1.15
Col47	2	0.00	1.15
Col47	3	0.00	1.15
Col47	4	0.00	1.15
Col47	5	0.00	1.15
Col47	6	0.00	1.15
Col47	7	0.00	1.15
Col47	8	-0.54	1.15
Col47	9	-0.54	1.15
Col47	10	0.54	1.15
Col47	11	0.54	1.15
Col47	12	0.54	1.15
Col47	13	0.54	1.15
Col47	14	0.54	1.15
Col47	15	0.54	1.15
Col47	16	0.41	1.15
Col47	17	0.41	1.15
Col47	18	0.41	1.15
Col47	19	0.41	1.15
Col47	20	0.41	1.15
Col47	21	0.41	1.15
Col47	22	0.41	1.15
Col47	23	0.41	1.15
Col47	24	0.41	1.15
Col47	25	0.41	1.15
Col47	26	0.41	1.15
Col47	27	0.41	1.15
Col47	28	-0.54	1.15
Col47	29	-0.54	1.15
Col47	30	0.54	1.15
Col47	31	0.54	1.15
Col47	32	0.54	1.15
Col47	33	0.54	1.15
Col47	34	0.54	1.15
Col47	35	0.54	1.15
Col47	36	0.00	1.15
Col47	37	0.00	1.15
Col47	38	0.00	1.15

Col47	39	0.00	1.15
Col47	40	0.00	1.15
Col47	41	0.00	1.15
Col47	42	0.00	1.15
Col47	43	0.00	1.15
Col47	44	0.00	1.15
Col47	45	0.00	1.15
Col47	46	0.00	1.15
Col47	47	0.25	1.15
Col47	48	0.25	1.15
Col47	49	0.00	1.15
Col47	50	0.00	1.15
Col47	51	0.41	1.15
Col47	52	0.00	1.15
Col48	1	0.00	1.14
Col48	2	0.00	1.14
Col48	3	0.00	1.14
Col48	4	0.00	1.14
Col48	5	0.00	1.14
Col48	6	0.00	1.14
Col48	7	0.00	1.14
Col48	8	-0.53	1.14
Col48	9	-0.53	1.14
Col48	10	0.53	1.14
Col48	11	0.53	1.14
Col48	12	0.53	1.14
Col48	13	0.53	1.14
Col48	14	0.53	1.14
Col48	15	0.53	1.14
Col48	16	0.40	1.14
Col48	17	0.40	1.14
Col48	18	0.40	1.14
Col48	19	0.40	1.14
Col48	20	0.40	1.14
Col48	21	0.40	1.14
Col48	22	0.40	1.14
Col48	23	0.40	1.14
Col48	24	0.40	1.14
Col48	25	0.40	1.14
Col48	26	0.40	1.14
Col48	27	0.40	1.14
Col48	28	-0.53	1.14
Col48	29	-0.53	1.14
Col48	30	0.53	1.14
Col48	31	0.53	1.14
Col48	32	0.53	1.14
Col48	33	0.53	1.14
Col48	34	0.53	1.14
Col48	35	0.53	1.14
Col48	36	0.00	1.14
Col48	37	0.00	1.14
Col48	38	0.00	1.14
Col48	39	0.00	1.14
Col48	40	0.00	1.14
Col48	41	0.00	1.14
Col48	42	0.00	1.14
Col48	43	0.00	1.14
Col48	44	0.00	1.14
Col48	45	0.00	1.14
Col48	46	0.00	1.14
Col48	47	0.24	1.14
Col48	48	0.24	1.14
Col48	49	0.00	1.14
Col48	50	0.00	1.14
Col48	51	0.40	1.14

Col48	52	0.00	1.14
Col49	1	0.00	1.13
Col49	2	0.00	1.13
Col49	3	0.00	1.13
Col49	4	0.00	1.13
Col49	5	0.00	1.13
Col49	6	0.00	1.13
Col49	7	0.00	1.13
Col49	8	-0.50	1.13
Col49	9	-0.50	1.13
Col49	10	0.50	1.13
Col49	11	0.50	1.13
Col49	12	0.50	1.13
Col49	13	0.50	1.13
Col49	14	0.50	1.13
Col49	15	0.50	1.13
Col49	16	0.38	1.13
Col49	17	0.38	1.13
Col49	18	0.38	1.13
Col49	19	0.38	1.13
Col49	20	0.38	1.13
Col49	21	0.38	1.13
Col49	22	0.38	1.13
Col49	23	0.38	1.13
Col49	24	0.38	1.13
Col49	25	0.38	1.13
Col49	26	0.38	1.13
Col49	27	0.38	1.13
Col49	28	-0.50	1.13
Col49	29	-0.50	1.13
Col49	30	0.50	1.13
Col49	31	0.50	1.13
Col49	32	0.50	1.13
Col49	33	0.50	1.13
Col49	34	0.50	1.13
Col49	35	0.50	1.13
Col49	36	0.00	1.13
Col49	37	0.00	1.13
Col49	38	0.00	1.13
Col49	39	0.00	1.13
Col49	40	0.00	1.13
Col49	41	0.00	1.13
Col49	42	0.00	1.13
Col49	43	0.00	1.13
Col49	44	0.00	1.13
Col49	45	0.00	1.13
Col49	46	0.00	1.13
Col49	47	0.23	1.13
Col49	48	0.23	1.13
Col49	49	0.00	1.13
Col49	50	0.00	1.13
Col49	51	0.38	1.13
Col49	52	0.00	1.13
Col50	1	0.00	1.12
Col50	2	0.00	1.12
Col50	3	0.00	1.12
Col50	4	0.00	1.12
Col50	5	0.00	1.12
Col50	6	0.00	1.12
Col50	7	0.00	1.12
Col50	8	-0.48	1.12
Col50	9	-0.48	1.12
Col50	10	0.48	1.12
Col50	11	0.48	1.12
Col50	12	0.48	1.12

Col50	13	0.48	1.12
Col50	14	0.48	1.12
Col50	15	0.48	1.12
Col50	16	0.36	1.12
Col50	17	0.36	1.12
Col50	18	0.36	1.12
Col50	19	0.36	1.12
Col50	20	0.36	1.12
Col50	21	0.36	1.12
Col50	22	0.36	1.12
Col50	23	0.36	1.12
Col50	24	0.36	1.12
Col50	25	0.36	1.12
Col50	26	0.36	1.12
Col50	27	0.36	1.12
Col50	28	-0.48	1.12
Col50	29	-0.48	1.12
Col50	30	0.48	1.12
Col50	31	0.48	1.12
Col50	32	0.48	1.12
Col50	33	0.48	1.12
Col50	34	0.48	1.12
Col50	35	0.48	1.12
Col50	36	0.00	1.12
Col50	37	0.00	1.12
Col50	38	0.00	1.12
Col50	39	0.00	1.12
Col50	40	0.00	1.12
Col50	41	0.00	1.12
Col50	42	0.00	1.12
Col50	43	0.00	1.12
Col50	44	0.00	1.12
Col50	45	0.00	1.12
Col50	46	0.00	1.12
Col50	47	0.22	1.12
Col50	48	0.22	1.12
Col50	49	0.00	1.12
Col50	50	0.00	1.12
Col50	51	0.36	1.12
Col50	52	0.00	1.12
Col51	1	0.00	1.10
Col51	2	0.00	1.10
Col51	3	0.00	1.10
Col51	4	0.00	1.10
Col51	5	0.00	1.10
Col51	6	0.00	1.10
Col51	7	0.00	1.10
Col51	8	-0.46	1.10
Col51	9	-0.46	1.10
Col51	10	0.46	1.10
Col51	11	0.46	1.10
Col51	12	0.46	1.10
Col51	13	0.46	1.10
Col51	14	0.46	1.10
Col51	15	0.46	1.10
Col51	16	0.34	1.10
Col51	17	0.34	1.10
Col51	18	0.34	1.10
Col51	19	0.34	1.10
Col51	20	0.34	1.10
Col51	21	0.34	1.10
Col51	22	0.34	1.10
Col51	23	0.34	1.10
Col51	24	0.34	1.10
Col51	25	0.34	1.10

Col51	26	0.34	1.10
Col51	27	0.34	1.10
Col51	28	-0.46	1.10
Col51	29	-0.46	1.10
Col51	30	0.46	1.10
Col51	31	0.46	1.10
Col51	32	0.46	1.10
Col51	33	0.46	1.10
Col51	34	0.46	1.10
Col51	35	0.46	1.10
Col51	36	0.00	1.10
Col51	37	0.00	1.10
Col51	38	0.00	1.10
Col51	39	0.00	1.10
Col51	40	0.00	1.10
Col51	41	0.00	1.10
Col51	42	0.00	1.10
Col51	43	0.00	1.10
Col51	44	0.00	1.10
Col51	45	0.00	1.10
Col51	46	0.00	1.10
Col51	47	0.21	1.10
Col51	48	0.21	1.10
Col51	49	0.00	1.10
Col51	50	0.00	1.10
Col51	51	0.34	1.10
Col51	52	0.00	1.10
Col52	1	0.00	1.09
Col52	2	0.00	1.09
Col52	3	0.00	1.09
Col52	4	0.00	1.09
Col52	5	0.00	1.09
Col52	6	0.00	1.09
Col52	7	0.00	1.09
Col52	8	-0.43	1.09
Col52	9	-0.43	1.09
Col52	10	0.43	1.09
Col52	11	0.43	1.09
Col52	12	0.43	1.09
Col52	13	0.43	1.09
Col52	14	0.43	1.09
Col52	15	0.43	1.09
Col52	16	0.33	1.09
Col52	17	0.33	1.09
Col52	18	0.33	1.09
Col52	19	0.33	1.09
Col52	20	0.33	1.09
Col52	21	0.33	1.09
Col52	22	0.33	1.09
Col52	23	0.33	1.09
Col52	24	0.33	1.09
Col52	25	0.33	1.09
Col52	26	0.33	1.09
Col52	27	0.33	1.09
Col52	28	-0.43	1.09
Col52	29	-0.43	1.09
Col52	30	0.43	1.09
Col52	31	0.43	1.09
Col52	32	0.43	1.09
Col52	33	0.43	1.09
Col52	34	0.43	1.09
Col52	35	0.43	1.09
Col52	36	0.00	1.09
Col52	37	0.00	1.09
Col52	38	0.00	1.09

Col52	39	0.00	1.09
Col52	40	0.00	1.09
Col52	41	0.00	1.09
Col52	42	0.00	1.09
Col52	43	0.00	1.09
Col52	44	0.00	1.09
Col52	45	0.00	1.09
Col52	46	0.00	1.09
Col52	47	0.20	1.09
Col52	48	0.20	1.09
Col52	49	0.00	1.09
Col52	50	0.00	1.09
Col52	51	0.33	1.09
Col52	52	0.00	1.09
Col53	1	0.00	1.07
Col53	2	0.00	1.07
Col53	3	0.00	1.07
Col53	4	0.00	1.07
Col53	5	0.00	1.07
Col53	6	0.00	1.07
Col53	7	0.00	1.07
Col53	8	-0.41	1.07
Col53	9	-0.41	1.07
Col53	10	0.41	1.07
Col53	11	0.41	1.07
Col53	12	0.41	1.07
Col53	13	0.41	1.07
Col53	14	0.41	1.07
Col53	15	0.41	1.07
Col53	16	0.31	1.07
Col53	17	0.31	1.07
Col53	18	0.31	1.07
Col53	19	0.31	1.07
Col53	20	0.31	1.07
Col53	21	0.31	1.07
Col53	22	0.31	1.07
Col53	23	0.31	1.07
Col53	24	0.31	1.07
Col53	25	0.31	1.07
Col53	26	0.31	1.07
Col53	27	0.31	1.07
Col53	28	-0.41	1.07
Col53	29	-0.41	1.07
Col53	30	0.41	1.07
Col53	31	0.41	1.07
Col53	32	0.41	1.07
Col53	33	0.41	1.07
Col53	34	0.41	1.07
Col53	35	0.41	1.07
Col53	36	0.00	1.07
Col53	37	0.00	1.07
Col53	38	0.00	1.07
Col53	39	0.00	1.07
Col53	40	0.00	1.07
Col53	41	0.00	1.07
Col53	42	0.00	1.07
Col53	43	0.00	1.07
Col53	44	0.00	1.07
Col53	45	0.00	1.07
Col53	46	0.00	1.07
Col53	47	0.19	1.07
Col53	48	0.19	1.07
Col53	49	0.00	1.07
Col53	50	0.00	1.07
Col53	51	0.31	1.07

Col53 52 0.00 1.07

COLUMN KL/R RATIO, MOMENT REDUCTION:

Id	Major (ft)	--Minor (ft)--		----KL/R----		Available Reduction Factor	
		Bend	Axial	Major	Minor	Out	In
Col42	16.3	0.1	0.1	85	2	0.00	0.00
Col43	16.5	0.1	0.1	86	2	0.00	0.00
Col44	16.7	0.1	0.1	87	2	0.00	0.00
Col45	17.0	0.1	0.1	88	2	0.00	0.00
Col46	17.2	0.1	0.1	89	2	0.00	0.00
Col47	17.3	0.1	0.1	90	2	0.00	0.00
Col48	17.2	0.1	0.1	89	2	0.00	0.00
Col49	17.0	0.1	0.1	88	2	0.00	0.00
Col50	16.7	0.1	0.1	87	2	0.00	0.00
Col51	16.5	0.1	0.1	86	2	0.00	0.00
Col52	16.3	0.1	0.1	85	2	0.00	0.00
Col53	16.1	0.1	0.1	84	2	0.00	0.00

PANEL DATA:

Table with 5 columns: Bay, Part, Type, Gage, Yield. Row 1: 1, PBR29, PR, 29.00, 60.0

MOMENTS & DEFLECTION:

Table with 13 columns: Span Id, Locate (ft) Start, End, Load, Moment (ft-lb/ft) Calc, Limit, Midspan Calc, Limit, End Calc, Limit, Max UC, Deflect (in) Calc, Limit. Rows 1-10 showing panel data.

WP - Wind_Pressure
WS - Wind_Suction

WALL LAYOUT:

Wall Id	Orn	LeftEW Offset	BackSW Offset	Wall Length	Load Width
7	L	0.00	30.00	14.00	5.00

MEMBER LAYOUT:

Locate			---Web(in)---		-Flange(in)-		Length	Weight	----Max_Load----		
Id	(ft)	Part	Depth	Thick	Width	Thick	(ft)	(lb)	Id	UC	Report
Col56	4.7	6X2C16	6.00	16ga	2.00	16ga	17.3	38.0	8	0.44	Deflect
Col57	9.3	6X2C16	6.00	16ga	2.00	16ga	17.3	38.0	8	0.44	Deflect
Total=								75.9			

DESIGN ACTIONS/STRENGTH:

								-----Unity Check-----			
Load		-Axial(k)-		-Shear(k)-		Moment(f-k)				Axial+	Shear+
Id	Id	Calc	Limit	Calc	Limit	Calc	Limit	Axial	Shear	Moment	Moment
Col56	1	0.57	8.04	0.00	3.32	0.00	3.07	0.07	0.00	0.07	0.00
Col56	2	0.10	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col56	3	0.42	8.04	0.00	3.32	0.00	3.07	0.05	0.00	0.05	0.00
Col56	4	0.42	8.04	0.00	3.32	0.00	3.07	0.05	0.00	0.05	0.00
Col56	5	0.45	8.04	0.00	3.32	0.00	3.07	0.06	0.00	0.06	0.00
Col56	6	0.34	8.04	0.00	3.32	0.00	3.07	0.04	0.00	0.04	0.00
Col56	7	0.34	8.04	0.00	3.32	0.00	3.07	0.04	0.00	0.04	0.00
Col56	8	-0.21	21.18	0.24	3.32	-1.05	3.07	0.01	0.07	0.33	0.00
Col56	9	-0.08	21.18	0.24	3.32	-1.05	3.07	0.00	0.07	0.34	0.00
Col56	10	-0.21	21.18	-0.24	3.32	1.05	3.07	0.01	0.07	0.33	0.00
Col56	11	-0.08	21.18	-0.24	3.32	1.05	3.07	0.00	0.07	0.34	0.00
Col56	12	-0.21	21.18	-0.24	3.32	1.05	3.07	0.01	0.07	0.33	0.00
Col56	13	-0.08	21.18	-0.24	3.32	1.05	3.07	0.00	0.07	0.34	0.00
Col56	14	-0.12	21.18	-0.24	3.32	1.05	3.07	0.01	0.07	0.34	0.00
Col56	15	0.01	8.04	-0.24	3.32	1.05	3.07	0.00	0.07	0.34	0.00
Col56	16	0.30	8.04	-0.18	3.32	0.79	3.07	0.04	0.05	0.29	0.00
Col56	17	0.39	8.04	-0.18	3.32	0.79	3.07	0.05	0.05	0.31	0.00
Col56	18	0.23	8.04	-0.18	3.32	0.79	3.07	0.03	0.05	0.28	0.00
Col56	19	0.32	8.04	-0.18	3.32	0.79	3.07	0.04	0.05	0.30	0.00
Col56	20	0.18	8.04	-0.18	3.32	0.79	3.07	0.02	0.05	0.28	0.00
Col56	21	0.28	8.04	-0.18	3.32	0.79	3.07	0.03	0.05	0.29	0.00
Col56	22	0.11	8.04	-0.18	3.32	0.79	3.07	0.01	0.05	0.27	0.00
Col56	23	0.21	8.04	-0.18	3.32	0.79	3.07	0.03	0.05	0.28	0.00
Col56	24	0.18	8.04	-0.18	3.32	0.79	3.07	0.02	0.05	0.28	0.00
Col56	25	0.28	8.04	-0.18	3.32	0.79	3.07	0.03	0.05	0.29	0.00
Col56	26	0.11	8.04	-0.18	3.32	0.79	3.07	0.01	0.05	0.27	0.00
Col56	27	0.21	8.04	-0.18	3.32	0.79	3.07	0.03	0.05	0.28	0.00
Col56	28	-0.23	21.18	0.24	3.32	-1.05	3.07	0.01	0.07	0.33	0.00
Col56	29	-0.10	21.18	0.24	3.32	-1.05	3.07	0.00	0.07	0.34	0.00
Col56	30	-0.23	21.18	-0.24	3.32	1.05	3.07	0.01	0.07	0.33	0.00
Col56	31	-0.10	21.18	-0.24	3.32	1.05	3.07	0.00	0.07	0.34	0.00
Col56	32	-0.23	21.18	-0.24	3.32	1.05	3.07	0.01	0.07	0.33	0.00
Col56	33	-0.10	21.18	-0.24	3.32	1.05	3.07	0.00	0.07	0.34	0.00
Col56	34	-0.14	21.18	-0.24	3.32	1.05	3.07	0.01	0.07	0.34	0.00
Col56	35	-0.01	21.18	-0.24	3.32	1.05	3.07	0.00	0.07	0.34	0.00
Col56	36	0.11	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col56	37	0.11	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col56	38	0.46	8.04	0.00	3.32	0.00	3.07	0.06	0.00	0.06	0.00
Col56	39	0.46	8.04	0.00	3.32	0.00	3.07	0.06	0.00	0.06	0.00

Col56	40	0.34	8.04	0.00	3.32	0.00	3.07	0.04	0.00	0.04	0.00
Col56	41	0.34	8.04	0.00	3.32	0.00	3.07	0.04	0.00	0.04	0.00
Col56	42	0.34	8.04	0.00	3.32	0.00	3.07	0.04	0.00	0.04	0.00
Col56	43	0.34	8.04	0.00	3.32	0.00	3.07	0.04	0.00	0.04	0.00
Col56	44	0.07	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col56	45	0.07	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col56	46	0.48	8.04	0.00	3.32	0.00	3.07	0.06	0.00	0.06	0.00
Col56	47	0.23	8.04	-0.18	3.32	0.79	3.07	0.03	0.05	0.29	0.00
Col56	48	0.32	8.04	-0.18	3.32	0.79	3.07	0.04	0.05	0.30	0.00
Col56	49	0.10	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col56	50	0.10	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col56	51	0.07	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col56	52	0.07	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col56	53	0.54	8.04	0.00	3.32	0.00	3.07	0.07	0.00	0.07	0.00
Col56	54	0.43	8.04	0.00	3.32	0.00	3.07	0.05	0.00	0.05	0.00
Col56	55	0.43	8.04	-0.18	3.32	0.79	3.07	0.05	0.05	0.31	0.00
Col56	56	0.43	8.04	0.00	3.32	0.00	3.07	0.05	0.00	0.05	0.00
Col57	1	0.57	8.04	0.00	3.32	0.00	3.07	0.07	0.00	0.07	0.00
Col57	2	0.10	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col57	3	0.42	8.04	0.00	3.32	0.00	3.07	0.05	0.00	0.05	0.00
Col57	4	0.42	8.04	0.00	3.32	0.00	3.07	0.05	0.00	0.05	0.00
Col57	5	0.45	8.04	0.00	3.32	0.00	3.07	0.06	0.00	0.06	0.00
Col57	6	0.34	8.04	0.00	3.32	0.00	3.07	0.04	0.00	0.04	0.00
Col57	7	0.34	8.04	0.00	3.32	0.00	3.07	0.04	0.00	0.04	0.00
Col57	8	-0.21	21.18	0.24	3.32	-1.05	3.07	0.01	0.07	0.33	0.00
Col57	9	-0.08	21.18	0.24	3.32	-1.05	3.07	0.00	0.07	0.34	0.00
Col57	10	-0.21	21.18	-0.24	3.32	1.05	3.07	0.01	0.07	0.33	0.00
Col57	11	-0.08	21.18	-0.24	3.32	1.05	3.07	0.00	0.07	0.34	0.00
Col57	12	-0.21	21.18	-0.24	3.32	1.05	3.07	0.01	0.07	0.33	0.00
Col57	13	-0.08	21.18	-0.24	3.32	1.05	3.07	0.00	0.07	0.34	0.00
Col57	14	-0.12	21.18	-0.24	3.32	1.05	3.07	0.01	0.07	0.34	0.00
Col57	15	0.01	8.04	-0.24	3.32	1.05	3.07	0.00	0.07	0.34	0.00
Col57	16	0.30	8.04	-0.18	3.32	0.79	3.07	0.04	0.05	0.29	0.00
Col57	17	0.39	8.04	-0.18	3.32	0.79	3.07	0.05	0.05	0.31	0.00
Col57	18	0.23	8.04	-0.18	3.32	0.79	3.07	0.03	0.05	0.28	0.00
Col57	19	0.32	8.04	-0.18	3.32	0.79	3.07	0.04	0.05	0.30	0.00
Col57	20	0.18	8.04	-0.18	3.32	0.79	3.07	0.02	0.05	0.28	0.00
Col57	21	0.28	8.04	-0.18	3.32	0.79	3.07	0.03	0.05	0.29	0.00
Col57	22	0.11	8.04	-0.18	3.32	0.79	3.07	0.01	0.05	0.27	0.00
Col57	23	0.21	8.04	-0.18	3.32	0.79	3.07	0.03	0.05	0.28	0.00
Col57	24	0.18	8.04	-0.18	3.32	0.79	3.07	0.02	0.05	0.28	0.00
Col57	25	0.28	8.04	-0.18	3.32	0.79	3.07	0.03	0.05	0.29	0.00
Col57	26	0.11	8.04	-0.18	3.32	0.79	3.07	0.01	0.05	0.27	0.00
Col57	27	0.21	8.04	-0.18	3.32	0.79	3.07	0.03	0.05	0.28	0.00
Col57	28	-0.23	21.18	0.24	3.32	-1.05	3.07	0.01	0.07	0.33	0.00
Col57	29	-0.10	21.18	0.24	3.32	-1.05	3.07	0.00	0.07	0.34	0.00
Col57	30	-0.23	21.18	-0.24	3.32	1.05	3.07	0.01	0.07	0.33	0.00
Col57	31	-0.10	21.18	-0.24	3.32	1.05	3.07	0.00	0.07	0.34	0.00
Col57	32	-0.23	21.18	-0.24	3.32	1.05	3.07	0.01	0.07	0.33	0.00
Col57	33	-0.10	21.18	-0.24	3.32	1.05	3.07	0.00	0.07	0.34	0.00
Col57	34	-0.14	21.18	-0.24	3.32	1.05	3.07	0.01	0.07	0.34	0.00
Col57	35	-0.01	21.18	-0.24	3.32	1.05	3.07	0.00	0.07	0.34	0.00
Col57	36	0.11	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col57	37	0.11	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col57	38	0.46	8.04	0.00	3.32	0.00	3.07	0.06	0.00	0.06	0.00
Col57	39	0.46	8.04	0.00	3.32	0.00	3.07	0.06	0.00	0.06	0.00
Col57	40	0.34	8.04	0.00	3.32	0.00	3.07	0.04	0.00	0.04	0.00
Col57	41	0.34	8.04	0.00	3.32	0.00	3.07	0.04	0.00	0.04	0.00
Col57	42	0.34	8.04	0.00	3.32	0.00	3.07	0.04	0.00	0.04	0.00
Col57	43	0.34	8.04	0.00	3.32	0.00	3.07	0.04	0.00	0.04	0.00
Col57	44	0.07	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col57	45	0.07	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col57	46	0.48	8.04	0.00	3.32	0.00	3.07	0.06	0.00	0.06	0.00
Col57	47	0.23	8.04	-0.18	3.32	0.79	3.07	0.03	0.05	0.29	0.00
Col57	48	0.32	8.04	-0.18	3.32	0.79	3.07	0.04	0.05	0.30	0.00

Col57	49	0.10	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col57	50	0.10	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col57	51	0.07	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col57	52	0.07	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col57	53	0.54	8.04	0.00	3.32	0.00	3.07	0.07	0.00	0.07	0.00
Col57	54	0.43	8.04	0.00	3.32	0.00	3.07	0.05	0.00	0.05	0.00
Col57	55	0.43	8.04	-0.18	3.32	0.79	3.07	0.05	0.05	0.31	0.00
Col57	56	0.43	8.04	0.00	3.32	0.00	3.07	0.05	0.00	0.05	0.00

COLUMN REACTIONS:

Id	Load		In_Plane	Out_Plane
	Id	Vert (k)	Horz (k)	Horz (k)
Col56	1	0.57	0.00	0.00
Col56	2	0.10	0.00	0.00
Col56	3	0.42	0.00	0.00
Col56	4	0.42	0.00	0.00
Col56	5	0.45	0.00	0.00
Col56	6	0.34	0.00	0.00
Col56	7	0.34	0.00	0.00
Col56	8	-0.21	0.00	-0.24
Col56	9	-0.08	0.00	-0.24
Col56	10	-0.21	0.00	0.24
Col56	11	-0.08	0.00	0.24
Col56	12	-0.21	0.00	0.24
Col56	13	-0.08	0.00	0.24
Col56	14	-0.12	0.00	0.24
Col56	15	0.01	0.00	0.24
Col56	16	0.30	0.00	0.18
Col56	17	0.39	0.00	0.18
Col56	18	0.23	0.00	0.18
Col56	19	0.32	0.00	0.18
Col56	20	0.18	0.00	0.18
Col56	21	0.28	0.00	0.18
Col56	22	0.11	0.00	0.18
Col56	23	0.21	0.00	0.18
Col56	24	0.18	0.00	0.18
Col56	25	0.28	0.00	0.18
Col56	26	0.11	0.00	0.18
Col56	27	0.21	0.00	0.18
Col56	28	-0.23	0.00	-0.24
Col56	29	-0.10	0.00	-0.24
Col56	30	-0.23	0.00	0.24
Col56	31	-0.10	0.00	0.24
Col56	32	-0.23	0.00	0.24
Col56	33	-0.10	0.00	0.24
Col56	34	-0.14	0.00	0.24
Col56	35	-0.01	0.00	0.24
Col56	36	0.11	0.00	0.00
Col56	37	0.11	0.00	0.00
Col56	38	0.46	0.00	0.00
Col56	39	0.46	0.00	0.00
Col56	40	0.34	0.00	0.00
Col56	41	0.34	0.00	0.00
Col56	42	0.34	0.00	0.00
Col56	43	0.34	0.00	0.00
Col56	44	0.07	0.00	0.00
Col56	45	0.07	0.00	0.00
Col56	46	0.48	0.00	0.00
Col56	47	0.23	0.00	0.18
Col56	48	0.32	0.00	0.18
Col56	49	0.10	0.00	0.00
Col56	50	0.10	0.00	0.00
Col56	51	0.07	0.00	0.00

Col56	52	0.07	0.00	0.00
Col56	53	0.54	0.00	0.00
Col56	54	0.43	0.00	0.00
Col56	55	0.43	0.00	0.18
Col56	56	0.43	0.00	0.00
Col57	1	0.57	0.00	0.00
Col57	2	0.10	0.00	0.00
Col57	3	0.42	0.00	0.00
Col57	4	0.42	0.00	0.00
Col57	5	0.45	0.00	0.00
Col57	6	0.34	0.00	0.00
Col57	7	0.34	0.00	0.00
Col57	8	-0.21	0.00	-0.24
Col57	9	-0.08	0.00	-0.24
Col57	10	-0.21	0.00	0.24
Col57	11	-0.08	0.00	0.24
Col57	12	-0.21	0.00	0.24
Col57	13	-0.08	0.00	0.24
Col57	14	-0.12	0.00	0.24
Col57	15	0.01	0.00	0.24
Col57	16	0.30	0.00	0.18
Col57	17	0.39	0.00	0.18
Col57	18	0.23	0.00	0.18
Col57	19	0.32	0.00	0.18
Col57	20	0.18	0.00	0.18
Col57	21	0.28	0.00	0.18
Col57	22	0.11	0.00	0.18
Col57	23	0.21	0.00	0.18
Col57	24	0.18	0.00	0.18
Col57	25	0.28	0.00	0.18
Col57	26	0.11	0.00	0.18
Col57	27	0.21	0.00	0.18
Col57	28	-0.23	0.00	-0.24
Col57	29	-0.10	0.00	-0.24
Col57	30	-0.23	0.00	0.24
Col57	31	-0.10	0.00	0.24
Col57	32	-0.23	0.00	0.24
Col57	33	-0.10	0.00	0.24
Col57	34	-0.14	0.00	0.24
Col57	35	-0.01	0.00	0.24
Col57	36	0.11	0.00	0.00
Col57	37	0.11	0.00	0.00
Col57	38	0.46	0.00	0.00
Col57	39	0.46	0.00	0.00
Col57	40	0.34	0.00	0.00
Col57	41	0.34	0.00	0.00
Col57	42	0.34	0.00	0.00
Col57	43	0.34	0.00	0.00
Col57	44	0.07	0.00	0.00
Col57	45	0.07	0.00	0.00
Col57	46	0.48	0.00	0.00
Col57	47	0.23	0.00	0.18
Col57	48	0.32	0.00	0.18
Col57	49	0.10	0.00	0.00
Col57	50	0.10	0.00	0.00
Col57	51	0.07	0.00	0.00
Col57	52	0.07	0.00	0.00
Col57	53	0.54	0.00	0.00
Col57	54	0.43	0.00	0.00
Col57	55	0.43	0.00	0.18
Col57	56	0.43	0.00	0.00

COLUMN DEFLECTIONS:
Load Deflection(in)

Id	Id	Calc	Limit
-----	-----	-----	-----
Col56	1	0.00	1.16
Col56	2	0.00	1.16
Col56	3	0.00	1.16
Col56	4	0.00	1.16
Col56	5	0.00	1.16
Col56	6	0.00	1.16
Col56	7	0.00	1.16
Col56	8	-0.51	1.16
Col56	9	-0.51	1.16
Col56	10	0.51	1.16
Col56	11	0.51	1.16
Col56	12	0.51	1.16
Col56	13	0.51	1.16
Col56	14	0.51	1.16
Col56	15	0.51	1.16
Col56	16	0.39	1.16
Col56	17	0.39	1.16
Col56	18	0.39	1.16
Col56	19	0.39	1.16
Col56	20	0.39	1.16
Col56	21	0.39	1.16
Col56	22	0.39	1.16
Col56	23	0.39	1.16
Col56	24	0.39	1.16
Col56	25	0.39	1.16
Col56	26	0.39	1.16
Col56	27	0.39	1.16
Col56	28	-0.51	1.16
Col56	29	-0.51	1.16
Col56	30	0.51	1.16
Col56	31	0.51	1.16
Col56	32	0.51	1.16
Col56	33	0.51	1.16
Col56	34	0.51	1.16
Col56	35	0.51	1.16
Col56	36	0.00	1.16
Col56	37	0.00	1.16
Col56	38	0.00	1.16
Col56	39	0.00	1.16
Col56	40	0.00	1.16
Col56	41	0.00	1.16
Col56	42	0.00	1.16
Col56	43	0.00	1.16
Col56	44	0.00	1.16
Col56	45	0.00	1.16
Col56	46	0.00	1.16
Col56	47	0.23	1.16
Col56	48	0.23	1.16
Col56	49	0.00	1.16
Col56	50	0.00	1.16
Col56	51	0.39	1.16
Col56	52	0.00	1.16
Col57	1	0.00	1.16
Col57	2	0.00	1.16
Col57	3	0.00	1.16
Col57	4	0.00	1.16
Col57	5	0.00	1.16
Col57	6	0.00	1.16
Col57	7	0.00	1.16
Col57	8	-0.51	1.16
Col57	9	-0.51	1.16
Col57	10	0.51	1.16
Col57	11	0.51	1.16

Col57	12	0.51	1.16
Col57	13	0.51	1.16
Col57	14	0.51	1.16
Col57	15	0.51	1.16
Col57	16	0.39	1.16
Col57	17	0.39	1.16
Col57	18	0.39	1.16
Col57	19	0.39	1.16
Col57	20	0.39	1.16
Col57	21	0.39	1.16
Col57	22	0.39	1.16
Col57	23	0.39	1.16
Col57	24	0.39	1.16
Col57	25	0.39	1.16
Col57	26	0.39	1.16
Col57	27	0.39	1.16
Col57	28	-0.51	1.16
Col57	29	-0.51	1.16
Col57	30	0.51	1.16
Col57	31	0.51	1.16
Col57	32	0.51	1.16
Col57	33	0.51	1.16
Col57	34	0.51	1.16
Col57	35	0.51	1.16
Col57	36	0.00	1.16
Col57	37	0.00	1.16
Col57	38	0.00	1.16
Col57	39	0.00	1.16
Col57	40	0.00	1.16
Col57	41	0.00	1.16
Col57	42	0.00	1.16
Col57	43	0.00	1.16
Col57	44	0.00	1.16
Col57	45	0.00	1.16
Col57	46	0.00	1.16
Col57	47	0.23	1.16
Col57	48	0.23	1.16
Col57	49	0.00	1.16
Col57	50	0.00	1.16
Col57	51	0.39	1.16
Col57	52	0.00	1.16

COLUMN KL/R RATIO, MOMENT REDUCTION:

Id	Major (ft)	--Minor (ft)--		----KL/R----		Available Reduction Factor	
		Bend	Axial	Major	Minor	Out	In
		-----	-----	-----	-----	-----	-----
Col56	17.3	0.1	0.1	90	2	0.00	0.00
Col57	17.3	0.1	0.1	90	2	0.00	0.00

WALL LAYOUT:

Wall Id	Orn	LeftEW Offset	BackSW Offset	Wall Length	Load Width
8	L	14.00	30.00	14.00	5.00

MEMBER LAYOUT:

Locate			---Web(in)---		-Flange(in)-		Length (ft)	Weight (lb)	----Max_Load----		
Id	(ft)	Part	Depth	Thick	Width	Thick			Id	UC	Report
Col60	4.7	6X2C16	6.00	16ga	2.00	16ga	17.3	38.0	8	0.44	Deflect
Col61	9.3	6X2C16	6.00	16ga	2.00	16ga	17.3	38.0	8	0.44	Deflect
Total=								75.9			

DESIGN ACTIONS/STRENGTH:

								-----Unity Check-----			
Id	Load Id	-Axial(k)-		-Shear(k)-		Moment(f-k)		Axial	Shear	Axial+ Shear+	
		Calc	Limit	Calc	Limit	Calc	Limit			Moment	Moment
Col60	1	0.57	8.04	0.00	3.32	0.00	3.07	0.07	0.00	0.07	0.00
Col60	2	0.10	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col60	3	0.42	8.04	0.00	3.32	0.00	3.07	0.05	0.00	0.05	0.00
Col60	4	0.42	8.04	0.00	3.32	0.00	3.07	0.05	0.00	0.05	0.00
Col60	5	0.45	8.04	0.00	3.32	0.00	3.07	0.06	0.00	0.06	0.00
Col60	6	0.34	8.04	0.00	3.32	0.00	3.07	0.04	0.00	0.04	0.00
Col60	7	0.34	8.04	0.00	3.32	0.00	3.07	0.04	0.00	0.04	0.00
Col60	8	-0.21	21.18	0.24	3.32	-1.05	3.07	0.01	0.07	0.33	0.00
Col60	9	-0.08	21.18	0.24	3.32	-1.05	3.07	0.00	0.07	0.34	0.00
Col60	10	-0.21	21.18	-0.24	3.32	1.05	3.07	0.01	0.07	0.33	0.00
Col60	11	-0.08	21.18	-0.24	3.32	1.05	3.07	0.00	0.07	0.34	0.00
Col60	12	-0.21	21.18	-0.24	3.32	1.05	3.07	0.01	0.07	0.33	0.00
Col60	13	-0.08	21.18	-0.24	3.32	1.05	3.07	0.00	0.07	0.34	0.00
Col60	14	-0.12	21.18	-0.24	3.32	1.05	3.07	0.01	0.07	0.34	0.00
Col60	15	0.01	8.04	-0.24	3.32	1.05	3.07	0.00	0.07	0.34	0.00
Col60	16	0.30	8.04	-0.18	3.32	0.79	3.07	0.04	0.05	0.29	0.00
Col60	17	0.39	8.04	-0.18	3.32	0.79	3.07	0.05	0.05	0.31	0.00
Col60	18	0.23	8.04	-0.18	3.32	0.79	3.07	0.03	0.05	0.28	0.00
Col60	19	0.32	8.04	-0.18	3.32	0.79	3.07	0.04	0.05	0.30	0.00
Col60	20	0.18	8.04	-0.18	3.32	0.79	3.07	0.02	0.05	0.28	0.00
Col60	21	0.28	8.04	-0.18	3.32	0.79	3.07	0.03	0.05	0.29	0.00
Col60	22	0.11	8.04	-0.18	3.32	0.79	3.07	0.01	0.05	0.27	0.00
Col60	23	0.21	8.04	-0.18	3.32	0.79	3.07	0.03	0.05	0.28	0.00
Col60	24	0.18	8.04	-0.18	3.32	0.79	3.07	0.02	0.05	0.28	0.00
Col60	25	0.28	8.04	-0.18	3.32	0.79	3.07	0.03	0.05	0.29	0.00
Col60	26	0.11	8.04	-0.18	3.32	0.79	3.07	0.01	0.05	0.27	0.00
Col60	27	0.21	8.04	-0.18	3.32	0.79	3.07	0.03	0.05	0.28	0.00
Col60	28	-0.23	21.18	0.24	3.32	-1.05	3.07	0.01	0.07	0.33	0.00
Col60	29	-0.10	21.18	0.24	3.32	-1.05	3.07	0.00	0.07	0.34	0.00
Col60	30	-0.23	21.18	-0.24	3.32	1.05	3.07	0.01	0.07	0.33	0.00
Col60	31	-0.10	21.18	-0.24	3.32	1.05	3.07	0.00	0.07	0.34	0.00
Col60	32	-0.23	21.18	-0.24	3.32	1.05	3.07	0.01	0.07	0.33	0.00
Col60	33	-0.10	21.18	-0.24	3.32	1.05	3.07	0.00	0.07	0.34	0.00
Col60	34	-0.14	21.18	-0.24	3.32	1.05	3.07	0.01	0.07	0.34	0.00
Col60	35	-0.01	21.18	-0.24	3.32	1.05	3.07	0.00	0.07	0.34	0.00
Col60	36	0.11	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col60	37	0.11	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col60	38	0.46	8.04	0.00	3.32	0.00	3.07	0.06	0.00	0.06	0.00
Col60	39	0.46	8.04	0.00	3.32	0.00	3.07	0.06	0.00	0.06	0.00

Col60	40	0.34	8.04	0.00	3.32	0.00	3.07	0.04	0.00	0.04	0.00
Col60	41	0.34	8.04	0.00	3.32	0.00	3.07	0.04	0.00	0.04	0.00
Col60	42	0.34	8.04	0.00	3.32	0.00	3.07	0.04	0.00	0.04	0.00
Col60	43	0.34	8.04	0.00	3.32	0.00	3.07	0.04	0.00	0.04	0.00
Col60	44	0.07	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col60	45	0.07	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col60	46	0.48	8.04	0.00	3.32	0.00	3.07	0.06	0.00	0.06	0.00
Col60	47	0.23	8.04	-0.18	3.32	0.79	3.07	0.03	0.05	0.29	0.00
Col60	48	0.32	8.04	-0.18	3.32	0.79	3.07	0.04	0.05	0.30	0.00
Col60	49	0.10	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col60	50	0.10	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col60	51	0.07	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col60	52	0.07	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col60	53	0.54	8.04	0.00	3.32	0.00	3.07	0.07	0.00	0.07	0.00
Col60	54	0.43	8.04	0.00	3.32	0.00	3.07	0.05	0.00	0.05	0.00
Col60	55	0.43	8.04	-0.18	3.32	0.79	3.07	0.05	0.05	0.31	0.00
Col60	56	0.43	8.04	0.00	3.32	0.00	3.07	0.05	0.00	0.05	0.00
Col61	1	0.57	8.04	0.00	3.32	0.00	3.07	0.07	0.00	0.07	0.00
Col61	2	0.10	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col61	3	0.42	8.04	0.00	3.32	0.00	3.07	0.05	0.00	0.05	0.00
Col61	4	0.42	8.04	0.00	3.32	0.00	3.07	0.05	0.00	0.05	0.00
Col61	5	0.45	8.04	0.00	3.32	0.00	3.07	0.06	0.00	0.06	0.00
Col61	6	0.34	8.04	0.00	3.32	0.00	3.07	0.04	0.00	0.04	0.00
Col61	7	0.34	8.04	0.00	3.32	0.00	3.07	0.04	0.00	0.04	0.00
Col61	8	-0.21	21.18	0.24	3.32	-1.05	3.07	0.01	0.07	0.33	0.00
Col61	9	-0.08	21.18	0.24	3.32	-1.05	3.07	0.00	0.07	0.34	0.00
Col61	10	-0.21	21.18	-0.24	3.32	1.05	3.07	0.01	0.07	0.33	0.00
Col61	11	-0.08	21.18	-0.24	3.32	1.05	3.07	0.00	0.07	0.34	0.00
Col61	12	-0.21	21.18	-0.24	3.32	1.05	3.07	0.01	0.07	0.33	0.00
Col61	13	-0.08	21.18	-0.24	3.32	1.05	3.07	0.00	0.07	0.34	0.00
Col61	14	-0.12	21.18	-0.24	3.32	1.05	3.07	0.01	0.07	0.34	0.00
Col61	15	0.01	8.04	-0.24	3.32	1.05	3.07	0.00	0.07	0.34	0.00
Col61	16	0.30	8.04	-0.18	3.32	0.79	3.07	0.04	0.05	0.29	0.00
Col61	17	0.39	8.04	-0.18	3.32	0.79	3.07	0.05	0.05	0.31	0.00
Col61	18	0.23	8.04	-0.18	3.32	0.79	3.07	0.03	0.05	0.28	0.00
Col61	19	0.32	8.04	-0.18	3.32	0.79	3.07	0.04	0.05	0.30	0.00
Col61	20	0.18	8.04	-0.18	3.32	0.79	3.07	0.02	0.05	0.28	0.00
Col61	21	0.28	8.04	-0.18	3.32	0.79	3.07	0.03	0.05	0.29	0.00
Col61	22	0.11	8.04	-0.18	3.32	0.79	3.07	0.01	0.05	0.27	0.00
Col61	23	0.21	8.04	-0.18	3.32	0.79	3.07	0.03	0.05	0.28	0.00
Col61	24	0.18	8.04	-0.18	3.32	0.79	3.07	0.02	0.05	0.28	0.00
Col61	25	0.28	8.04	-0.18	3.32	0.79	3.07	0.03	0.05	0.29	0.00
Col61	26	0.11	8.04	-0.18	3.32	0.79	3.07	0.01	0.05	0.27	0.00
Col61	27	0.21	8.04	-0.18	3.32	0.79	3.07	0.03	0.05	0.28	0.00
Col61	28	-0.23	21.18	0.24	3.32	-1.05	3.07	0.01	0.07	0.33	0.00
Col61	29	-0.10	21.18	0.24	3.32	-1.05	3.07	0.00	0.07	0.34	0.00
Col61	30	-0.23	21.18	-0.24	3.32	1.05	3.07	0.01	0.07	0.33	0.00
Col61	31	-0.10	21.18	-0.24	3.32	1.05	3.07	0.00	0.07	0.34	0.00
Col61	32	-0.23	21.18	-0.24	3.32	1.05	3.07	0.01	0.07	0.33	0.00
Col61	33	-0.10	21.18	-0.24	3.32	1.05	3.07	0.00	0.07	0.34	0.00
Col61	34	-0.14	21.18	-0.24	3.32	1.05	3.07	0.01	0.07	0.34	0.00
Col61	35	-0.01	21.18	-0.24	3.32	1.05	3.07	0.00	0.07	0.34	0.00
Col61	36	0.11	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col61	37	0.11	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col61	38	0.46	8.04	0.00	3.32	0.00	3.07	0.06	0.00	0.06	0.00
Col61	39	0.46	8.04	0.00	3.32	0.00	3.07	0.06	0.00	0.06	0.00
Col61	40	0.34	8.04	0.00	3.32	0.00	3.07	0.04	0.00	0.04	0.00
Col61	41	0.34	8.04	0.00	3.32	0.00	3.07	0.04	0.00	0.04	0.00
Col61	42	0.34	8.04	0.00	3.32	0.00	3.07	0.04	0.00	0.04	0.00
Col61	43	0.34	8.04	0.00	3.32	0.00	3.07	0.04	0.00	0.04	0.00
Col61	44	0.07	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col61	45	0.07	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col61	46	0.48	8.04	0.00	3.32	0.00	3.07	0.06	0.00	0.06	0.00
Col61	47	0.23	8.04	-0.18	3.32	0.79	3.07	0.03	0.05	0.29	0.00
Col61	48	0.32	8.04	-0.18	3.32	0.79	3.07	0.04	0.05	0.30	0.00

Col61	49	0.10	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col61	50	0.10	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col61	51	0.07	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col61	52	0.07	8.04	0.00	3.32	0.00	3.07	0.01	0.00	0.01	0.00
Col61	53	0.54	8.04	0.00	3.32	0.00	3.07	0.07	0.00	0.07	0.00
Col61	54	0.43	8.04	0.00	3.32	0.00	3.07	0.05	0.00	0.05	0.00
Col61	55	0.43	8.04	-0.18	3.32	0.79	3.07	0.05	0.05	0.31	0.00
Col61	56	0.43	8.04	0.00	3.32	0.00	3.07	0.05	0.00	0.05	0.00

COLUMN REACTIONS:

Id	Load		In_Plane	Out_Plane
	Id	Vert (k)	Horz (k)	Horz (k)
Col60	1	0.57	0.00	0.00
Col60	2	0.10	0.00	0.00
Col60	3	0.42	0.00	0.00
Col60	4	0.42	0.00	0.00
Col60	5	0.45	0.00	0.00
Col60	6	0.34	0.00	0.00
Col60	7	0.34	0.00	0.00
Col60	8	-0.21	0.00	-0.24
Col60	9	-0.08	0.00	-0.24
Col60	10	-0.21	0.00	0.24
Col60	11	-0.08	0.00	0.24
Col60	12	-0.21	0.00	0.24
Col60	13	-0.08	0.00	0.24
Col60	14	-0.12	0.00	0.24
Col60	15	0.01	0.00	0.24
Col60	16	0.30	0.00	0.18
Col60	17	0.39	0.00	0.18
Col60	18	0.23	0.00	0.18
Col60	19	0.32	0.00	0.18
Col60	20	0.18	0.00	0.18
Col60	21	0.28	0.00	0.18
Col60	22	0.11	0.00	0.18
Col60	23	0.21	0.00	0.18
Col60	24	0.18	0.00	0.18
Col60	25	0.28	0.00	0.18
Col60	26	0.11	0.00	0.18
Col60	27	0.21	0.00	0.18
Col60	28	-0.23	0.00	-0.24
Col60	29	-0.10	0.00	-0.24
Col60	30	-0.23	0.00	0.24
Col60	31	-0.10	0.00	0.24
Col60	32	-0.23	0.00	0.24
Col60	33	-0.10	0.00	0.24
Col60	34	-0.14	0.00	0.24
Col60	35	-0.01	0.00	0.24
Col60	36	0.11	0.00	0.00
Col60	37	0.11	0.00	0.00
Col60	38	0.46	0.00	0.00
Col60	39	0.46	0.00	0.00
Col60	40	0.34	0.00	0.00
Col60	41	0.34	0.00	0.00
Col60	42	0.34	0.00	0.00
Col60	43	0.34	0.00	0.00
Col60	44	0.07	0.00	0.00
Col60	45	0.07	0.00	0.00
Col60	46	0.48	0.00	0.00
Col60	47	0.23	0.00	0.18
Col60	48	0.32	0.00	0.18
Col60	49	0.10	0.00	0.00
Col60	50	0.10	0.00	0.00
Col60	51	0.07	0.00	0.00

Col160	52	0.07	0.00	0.00
Col160	53	0.54	0.00	0.00
Col160	54	0.43	0.00	0.00
Col160	55	0.43	0.00	0.18
Col160	56	0.43	0.00	0.00
Col161	1	0.57	0.00	0.00
Col161	2	0.10	0.00	0.00
Col161	3	0.42	0.00	0.00
Col161	4	0.42	0.00	0.00
Col161	5	0.45	0.00	0.00
Col161	6	0.34	0.00	0.00
Col161	7	0.34	0.00	0.00
Col161	8	-0.21	0.00	-0.24
Col161	9	-0.08	0.00	-0.24
Col161	10	-0.21	0.00	0.24
Col161	11	-0.08	0.00	0.24
Col161	12	-0.21	0.00	0.24
Col161	13	-0.08	0.00	0.24
Col161	14	-0.12	0.00	0.24
Col161	15	0.01	0.00	0.24
Col161	16	0.30	0.00	0.18
Col161	17	0.39	0.00	0.18
Col161	18	0.23	0.00	0.18
Col161	19	0.32	0.00	0.18
Col161	20	0.18	0.00	0.18
Col161	21	0.28	0.00	0.18
Col161	22	0.11	0.00	0.18
Col161	23	0.21	0.00	0.18
Col161	24	0.18	0.00	0.18
Col161	25	0.28	0.00	0.18
Col161	26	0.11	0.00	0.18
Col161	27	0.21	0.00	0.18
Col161	28	-0.23	0.00	-0.24
Col161	29	-0.10	0.00	-0.24
Col161	30	-0.23	0.00	0.24
Col161	31	-0.10	0.00	0.24
Col161	32	-0.23	0.00	0.24
Col161	33	-0.10	0.00	0.24
Col161	34	-0.14	0.00	0.24
Col161	35	-0.01	0.00	0.24
Col161	36	0.11	0.00	0.00
Col161	37	0.11	0.00	0.00
Col161	38	0.46	0.00	0.00
Col161	39	0.46	0.00	0.00
Col161	40	0.34	0.00	0.00
Col161	41	0.34	0.00	0.00
Col161	42	0.34	0.00	0.00
Col161	43	0.34	0.00	0.00
Col161	44	0.07	0.00	0.00
Col161	45	0.07	0.00	0.00
Col161	46	0.48	0.00	0.00
Col161	47	0.23	0.00	0.18
Col161	48	0.32	0.00	0.18
Col161	49	0.10	0.00	0.00
Col161	50	0.10	0.00	0.00
Col161	51	0.07	0.00	0.00
Col161	52	0.07	0.00	0.00
Col161	53	0.54	0.00	0.00
Col161	54	0.43	0.00	0.00
Col161	55	0.43	0.00	0.18
Col161	56	0.43	0.00	0.00

COLUMN DEFLECTIONS:

Load	Deflection(in)
------	----------------

Id	Id	Calc	Limit
-----	-----	-----	-----
Col160	1	0.00	1.16
Col160	2	0.00	1.16
Col160	3	0.00	1.16
Col160	4	0.00	1.16
Col160	5	0.00	1.16
Col160	6	0.00	1.16
Col160	7	0.00	1.16
Col160	8	-0.51	1.16
Col160	9	-0.51	1.16
Col160	10	0.51	1.16
Col160	11	0.51	1.16
Col160	12	0.51	1.16
Col160	13	0.51	1.16
Col160	14	0.51	1.16
Col160	15	0.51	1.16
Col160	16	0.39	1.16
Col160	17	0.39	1.16
Col160	18	0.39	1.16
Col160	19	0.39	1.16
Col160	20	0.39	1.16
Col160	21	0.39	1.16
Col160	22	0.39	1.16
Col160	23	0.39	1.16
Col160	24	0.39	1.16
Col160	25	0.39	1.16
Col160	26	0.39	1.16
Col160	27	0.39	1.16
Col160	28	-0.51	1.16
Col160	29	-0.51	1.16
Col160	30	0.51	1.16
Col160	31	0.51	1.16
Col160	32	0.51	1.16
Col160	33	0.51	1.16
Col160	34	0.51	1.16
Col160	35	0.51	1.16
Col160	36	0.00	1.16
Col160	37	0.00	1.16
Col160	38	0.00	1.16
Col160	39	0.00	1.16
Col160	40	0.00	1.16
Col160	41	0.00	1.16
Col160	42	0.00	1.16
Col160	43	0.00	1.16
Col160	44	0.00	1.16
Col160	45	0.00	1.16
Col160	46	0.00	1.16
Col160	47	0.23	1.16
Col160	48	0.23	1.16
Col160	49	0.00	1.16
Col160	50	0.00	1.16
Col160	51	0.39	1.16
Col160	52	0.00	1.16
Col161	1	0.00	1.16
Col161	2	0.00	1.16
Col161	3	0.00	1.16
Col161	4	0.00	1.16
Col161	5	0.00	1.16
Col161	6	0.00	1.16
Col161	7	0.00	1.16
Col161	8	-0.51	1.16
Col161	9	-0.51	1.16
Col161	10	0.51	1.16
Col161	11	0.51	1.16

Col161	12	0.51	1.16
Col161	13	0.51	1.16
Col161	14	0.51	1.16
Col161	15	0.51	1.16
Col161	16	0.39	1.16
Col161	17	0.39	1.16
Col161	18	0.39	1.16
Col161	19	0.39	1.16
Col161	20	0.39	1.16
Col161	21	0.39	1.16
Col161	22	0.39	1.16
Col161	23	0.39	1.16
Col161	24	0.39	1.16
Col161	25	0.39	1.16
Col161	26	0.39	1.16
Col161	27	0.39	1.16
Col161	28	-0.51	1.16
Col161	29	-0.51	1.16
Col161	30	0.51	1.16
Col161	31	0.51	1.16
Col161	32	0.51	1.16
Col161	33	0.51	1.16
Col161	34	0.51	1.16
Col161	35	0.51	1.16
Col161	36	0.00	1.16
Col161	37	0.00	1.16
Col161	38	0.00	1.16
Col161	39	0.00	1.16
Col161	40	0.00	1.16
Col161	41	0.00	1.16
Col161	42	0.00	1.16
Col161	43	0.00	1.16
Col161	44	0.00	1.16
Col161	45	0.00	1.16
Col161	46	0.00	1.16
Col161	47	0.23	1.16
Col161	48	0.23	1.16
Col161	49	0.00	1.16
Col161	50	0.00	1.16
Col161	51	0.39	1.16
Col161	52	0.00	1.16

COLUMN KL/R RATIO, MOMENT REDUCTION:

Id	Major (ft)	--Minor (ft)--		----KL/R----		Available Reduction Factor	
		Bend	Axial	Major	Minor	Out	In
Col160	17.3	0.1	0.1	90	2	0.00	0.00
Col161	17.3	0.1	0.1	90	2	0.00	0.00

PANEL DATA:

Bay	Part	Type	Gage	Yield
---	-----	---	-----	-----
1	PBR29	PR	29.00	60.0

MOMENTS & DEFLECTION:

			-----Moment (ft-lb/ft)-----									
Span Id	Locate (ft)		Load	Start		Midspan		End		Max UC	Deflect (in)	
	Start	End		Calc	Limit	Calc	Limit	Calc	Limit		Calc	Limit
----	-----	-----	----	-----	-----	-----	-----	-----	-----	-----	-----	-----
1	0.00	4.67	WP	0.0	107.0	-10.5	70.2	13.1	107.0	0.15	-0.03	0.93
			WS	0.0	70.2	10.5	107.0	-13.1	70.2	0.19	0.03	0.93
2	4.67	9.33	WP	13.1	107.0	-3.3	70.2	13.1	107.0	0.12	0.00	0.93
			WS	-13.1	70.2	3.3	107.0	-13.1	70.2	0.19	0.00	0.93
3	9.33	14.00	WP	13.1	107.0	-10.5	70.2	0.0	107.0	0.15	-0.03	0.93
			WS	-13.1	70.2	10.5	107.0	0.0	107.0	0.19	0.03	0.93

WP - Wind Pressure
WS - Wind Suction

.. No Warnings