



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20110360, Building Permit - Commercial  
Address: 970 NW BLUE PKWY, Unit:A, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Failed	Monday, April 18, 2011

Corrective Action Required  
1 MISC

TOP OF TYPE [1] WALL NOT CONSTRUCTED PER DETAIL 6/A101.

Corrective Action Required  
2 MISC

PVC ROOF DRAIN PIPING PENETRATES TYPE [1] WALL AT EAST END OF CORRIDOR. CONSULT A/E FOR DIRECTION COMPLIANT WITH UL-LISTED PENETRATION DESIGN. A/E MUST ISSUE WRITTEN DIRECTION.

**Comments:**