CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRCOM20210263Address:1801 NW OBRIEN RD, LEES SUMMIT, MO 64081520 NW HOPE LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:	
Sidewalk Inspection		Eric Sharp	Partial	Tuesday, October 04, 2022	
Corrective Action Required:					
1	Misc	Forms were placed and aggregate was present and compacted. Still needs to drill and set epoxy dowel bars. Needs to adjust turning space to meet ADA compliance. RP 8-19-21			
Informational:					
2	Misc	Corrections were made to 8-23-21	o the turning spaces. They u	used 4K KCMMB mix. RP	
Informational:					
3	Misc	Sidewalk meets LS and AE ramp. RP 8-27-21	DA specs. Still needs to fram	ne and pour 1 more ADA	
Informational:					
4	Misc		ggregate was present and co Ilk for turning space. RP 9-1	•	
Corrective Action Required:					
5	Misc	Footprints in the sidewall 9-10-21	k, needs to remove and rep	lace sidewalk. RP	
Informational:					
6	Misc		riguez Mechanical concerni aced and aggregate was pre		
Informational:					
7	Misc	ADA ramp and sidewalk a	t Moore and O'Brien meet	LS and ADA specs. RP	

		11-12-21	
Informati	onal:		
8	Misc	Contractor working on forming up sidewalk in front of building in hopes to pour early next week. No inspection called in and sidewalk forming and aggregate fill was incomplete. will need inspection prior to pouring. 9/14/22 ES	
		Contractor still working on forming up sidewalk and getting aggregate in. 9/15/22 ES	
		Contractor working on sidewalk framing and getting aggregate in. No pre inspections request or completed. 9/16/22 ES	
		et with Dakota from True plane concrete and Nick Scott from PW about DA ramp/curbs at NW corner of Moore and Hope Ln. They need to rip out d flatten a small section of curbing to get ADA compliant for ramp that will poss Moore. Existing sidewalk on NE corner of Moore is only 4' wide so will atch that with new. They will also have a large truncated dome section to ake new sidewalk coming on back side of curb on Hope Ln function for both rectional crossings. 9/28/22 ES	
		Sidewalk at Moore and Hope lane intersection was still framed up ready to pour after curbing was completed yesterday. 9/29/22am ES	
		Dakota's crew working on sidewalks on Hope Ln north of new apartment building. 9/30/22 ES	

Dakota's crew was pouring ADA ramps at corner of Hope Ln and Moore. 10/4/22 $\ensuremath{\mathsf{ES}}$

Comments: