

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20220590  
Address: 520 NW CHIPMAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Michael Harkins	Failed	Wednesday, October 05, 2022

Corrective Action Required:

1	Miscellaneous Correction	CHAIR UP MATS & SPACE OFF EDGES 3" NO GROUND CONTACT PROVIDE # 3 TIES ON COLUMNS
---	--------------------------	---

**Comments:**