

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215033
Address: 2022 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Ryan Heckman	Passed	Wednesday, October 05, 2022

Informational:

1	Misc	9-21-22 RH. Aggregate was not compacted.
		9-28-22 RH. Driveway was formed up and aggregate was placed and compacted.
		10-5-22 RH. Driveway meets LS specification.

Comments: