

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20220590  
Address: 520 NW CHIPMAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Michael Harkins	Partial	Wednesday, October 05, 2022

Corrective Action Required:

1	Miscellaneous Correction	-(4) FOOTINGS FOR CANOPY SW CORNER OF BLDG (3) GRADE BEAMS IN BLDG SLAB OK TO POUR -
---	--------------------------	---

PROVIDE # 3 TIES @ 2" OC ON TOP OF COLUMNS  
PER PLAN

**Comments:**